

February 18, 2019

Mr. Scott Auman  
Stark Wilson Duncan Architects Inc.  
315 Nichols Road, Suite 228  
Kansas City, MO 64112

**RE: WATER SUPPLY  
LEE'S SUMMIT SENIOR COMMUNITY  
LEE'S SUMMIT, MISSOURI**

Dear Mr. Auman,

The proposed single feed water main extension from 1000 SE Princeton Drive to proposed SE Oldham Parkway main entrance will provide over 2600 GPM @ 20 PSI. This exceeds the fire-flow requirements listed in IFC Appendix B including the reduction for fire sprinklers. The proposed single feed water main extension is also sufficient to meet the anticipated 488 GPM attic fire sprinkler system hydraulic demand, including 100 GPM fire department hose allowance.

My attached water model/hydraulic calculations and sketch are based upon the following:

Assumed water supply at Ranson Road and 12<sup>th</sup> Street:

I used the available fire hydrant flow test information from flow testing at 2100 SE Blue Parkway, adjusted for elevation plus a 10% reduction to the residual pressure. With the Ranson Road/ 12<sup>th</sup> Street location being closer to the water tower, the actual pressures and flow should exceed what I have utilized.

Existing water mains in the residential neighborhood south of the proposed facility:

I have utilized interconnected 8" watermains.

New proposed water main extension:

A single feed 12" water main extension from the existing dead-end road at 1000 SE Princeton Drive to the proposed main entrance to the facility at SE Oldham. My calculations include a single-feed "dead-end" type arrangement with supply coming from Princeton Drive only. My calculations do not include a looped supply with the proposed main extension connection back to the existing main in SE Ranson Road.

Contact me with any questions at [craig.barulich@wfp.us](mailto:craig.barulich@wfp.us) or 193-321-9208.

Sincerely,

Craig Barulich, CET  
Contract Sales Representative

WESTERN STATES FIRE PROTECTION CO.  
NATIONAL FIRE SUPPRESSION DIVISION

Job Name : LEE'S SUMMIT SENIOR - WATER MODEL  
Drawing :  
Location :  
Remote Area :  
Contract :  
Data File : LEES SUMMIT SENIOR WATER MODEL.WXF


# Water Supply Curve C

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 1  
Date

City Water Supply:  
C1 - Static Pressure : 59  
C2 - Residual Pressure: 51  
C2 - Residual Flow : 1363

Demand:  
D1 - Elevation : -11.694  
D2 - System Flow :  
D2 - System Pressure : 31.618  
Hose ( Demand ) : 2649  
D3 - System Demand : 2649  
Safety Margin : 0.031



# Fittings Used Summary

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 2  
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 3  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	59.0	51	1363.0	31.649	2649.0	31.618

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H1	1023.0		0.0	2649.0	
22	1050.0		-9.56		
21	1050.0		-4.87		
A	1050.0		31.57		
1	1050.0		30.77		
2	1050.0		28.96		
3	1050.0		23.12		
4	1050.0		21.55		
5	1050.0		20.86		
6	1050.0		17.89		
7	1050.0		11.12		
8	1050.0		14.48		
9	1050.0		17.21		
10	1050.0		18.06		
11	1050.0		23.78		
12	1050.0		28.95		
3A	1050.0		22.58		
3B	1050.0		22.59		
3C	1050.0		21.66		
6A	1050.0		18.78		
TEST	1050.0		31.62		

# Final Calculations : Hazen-Williams

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 4  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H1 to 22	1023 1050	H2649	2649.00 2649.0	12 12.34	T G	93.767 9.377	320.000 103.144	140	0.0 -11.694			
						0.0	423.144	0.0050	2.135	Vel =	7.11	
22 to 21	1050 1050		0.0 2649.0	12 12.34	T G	93.767 9.377	770.000 159.404	140	-9.559 0.0			
						56.26	929.404	0.0050	4.688	Vel =	7.11	
21 to 7	1050 1050		0.0 2649.0	8 8.27	G	6.326 0.0	445.000 6.326	140	-4.871 0.0			
						0.0	451.326	0.0354	15.986	Vel =	15.82	
7			0.0 2649.00						11.115	K Factor =	794.56	
A to 1	1050 1050		-1187.43 -1187.43	12 12.34	T G	93.767 9.377	590.000 103.144	140	31.567 0.0			
						0.0	693.144	-0.0011	-0.792	Vel =	3.19	
1 to 2	1050 1050		0.0 -1187.43	8 8.27	T G	55.354 6.326	165.000 61.680	140	30.775 0.0			
						0.0	226.680	-0.0080	-1.820	Vel =	7.09	
2 to 3	1050 1050		13.09 -1174.34	8 8.27	T G	55.354 6.326	680.000 61.680	140	28.955 0.0			
						0.0	741.680	-0.0079	-5.833	Vel =	7.01	
3 to 4	1050 1050		601.16 -573.18	8 8.27	T G	55.354 6.326	690.000 61.680	140	23.122 0.0			
						0.0	751.680	-0.0021	-1.568	Vel =	3.42	
4 to 5	1050 1050		0.0 -573.18	8 8.27	T G	55.354 6.326	270.000 61.680	140	21.554 0.0			
						0.0	331.680	-0.0021	-0.692	Vel =	3.42	
5 to 6	1050 1050		-451.75 -1024.93	8 8.27	T G	55.354 6.326	425.000 61.680	140	20.862 0.0			
						0.0	486.680	-0.0061	-2.976	Vel =	6.12	
6 to 7	1050 1050		-375.46 -1400.39	8 8.27	T G	55.354 6.326	560.000 61.680	140	17.886 0.0			
						0.0	621.680	-0.0109	-6.771	Vel =	8.36	
7 to 8	1050 1050		2649.00 1248.61	8 8.27	T G	55.354 6.326	320.000 61.680	140	11.115 0.0			
						0.0	381.680	0.0088	3.362	Vel =	7.46	
8 to 9	1050 1050		-679.54 569.07	8 8.27	T G	55.354 6.326	1225.000 102.800	140	14.477 0.0			
						41.12	1327.800	0.0021	2.734	Vel =	3.40	
9 to 10	1050 1050		0.0 569.07	8 8.27	T G	55.354 6.326	350.000 61.680	140	17.211 0.0			
						0.0	411.680	0.0021	0.847	Vel =	3.40	
10 to 11	1050 1050		231.58 800.65	8 8.27	T G	55.354 6.326	1375.000 102.800	140	18.058 0.0			
						41.12	1477.800	0.0039	5.722	Vel =	4.78	
11 to 12	1050 1050		674.01 1474.66	8 8.27	T G	55.354 6.326	370.000 61.680	140	23.780 0.0			
						0.0	431.680	0.0120	5.174	Vel =	8.81	

# Final Calculations : Hazen-Williams

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 5  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
12 to A	1050 1050		-13.09 1461.57	8 8.27	T G	55.354 6.326 0.0	160.000 61.680 221.680	140 0.0118	28.954 0.0 2.613		Vel = 8.73	
A			0.0 1461.57						31.567		K Factor = 260.14	
2 to 12	1050 1050		-13.09 -13.09	8 8.27	T G	55.354 6.326 0.0	585.000 61.680 646.680	140 0	28.955 0.0 -0.001		Vel = 0.08	
12			0.0 -13.09						28.954		K Factor = -2.43	
3 to 3A	1050 1050		-601.16 -601.16	8 8.27	T G	55.354 6.326 0.0	175.000 61.680 236.680	140 -0.0023	23.122 0.0 -0.539		Vel = 3.59	
3A to 3B	1050 1050		649.83 48.67	8 8.27	T G	55.354 6.326 0.0	400.000 61.680 461.680	140 0	22.583 0.0 0.010		Vel = 0.29	
3B to 11	1050 1050		625.34 674.01	8 8.27	T G	55.354 6.326 0.0	360.000 61.680 421.680	140 0.0028	22.593 0.0 1.187		Vel = 4.03	
11			0.0 674.01						23.780		K Factor = 138.22	
3A to 3C	1050 1050		-649.83 -649.83	8 8.27	T G	55.354 6.326 0.0	290.000 61.680 351.680	140 -0.0026	22.583 0.0 -0.926		Vel = 3.88	
3C to 3B	1050 1050		1275.17 625.34	8 8.27	T G	55.354 6.326 0.0	320.000 61.680 381.680	140 0.0025	21.657 0.0 0.936		Vel = 3.74	
3B			0.0 625.34						22.593		K Factor = 131.56	
3C to 6A	1050 1050		-823.42 -823.42	8 8.27	T G	55.354 6.326 0.0	645.000 61.680 706.680	140 -0.0041	21.657 0.0 -2.881		Vel = 4.92	
6A			0.0 -823.42						18.776		K Factor = -190.03	
3C to 5	1050 1050		-451.75 -451.75	8 8.27	T G L	55.354 6.326 20.56	510.000 82.240 592.240	140 -0.0013	21.657 0.0 -0.795		Vel = 2.70	
5			0.0 -451.75						20.862		K Factor = -98.91	
6 to 6A	1050 1050		375.46 375.46	8 8.27	T G L	55.354 6.326 20.56	850.000 82.240 932.240	140 0.0010	17.886 0.0 0.890		Vel = 2.24	
6A to 10	1050 1050		-823.43 -447.97	8 8.27	T G L	55.354 6.326 20.56	460.000 82.240 542.240	140 -0.0013	18.776 0.0 -0.718		Vel = 2.68	
			0.0									




# Final Calculations : Hazen-Williams

Your Company Name  
LEE'S SUMMIT SENIOR - WATER MODEL

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			-447.97						18.058		K Factor = -105.42	
8 to 10	1050 1050		679.54	8	T G 2L	55.354 6.326 41.12	1150.000 102.800 1252.800	140	14.477 0.0 3.581		Vel = 4.06	
10			0.0 679.54						18.058		K Factor = 159.91	
A to TEST	1050 1050		2649.00	12		0.0	10.000	140	31.567 0.0 0.051		Vel = 7.11	
TEST			0.0 2649.00						31.618		K Factor = 471.10	



**CALCULATED AVAILABLE WATER SUPPLY**  
**MAIN ENTRANCE SE OLDHAM PARKWAY**  
**1023' ELEV**  
**2600+ GPM AVAIL @ 20 PSI**

- BUILDING SETBACKS:**  
 FRONT = 15' MINIMUM  
 REAR = 20' MINIMUM  
 SIDE = 10' MINIMUM
- PARKING SETBACKS:**  
 NORTH = 20' MIN. ALONG STREET FRONTAGE  
 EAST = 6' MIN. FROM SIDE PROPERTY LINE; ALONG STREET FRONTAGE  
 SOUTH = 20' MIN. FROM RESIDENTIAL DISTRICT (LANDSCAPE BUFFER)  
 WEST = 6' MIN. FROM SIDE PROPERTY LINE
- GREEN SPACE:**  
 PERIMETER GREEN = 20' MINIMUM LANDSCAPE STRIP ALONG STREET FRONTAGE
- ZONING:**  
 ZONING EXISTING: CP-2 PLANNED COMMUNITY COMMERCIAL  
 EAST: AG - AGRICULTURE  
 SOUTH: R-1 SINGLE FAMILY RESIDENTIAL  
 WEST: CP-2 PLANNED COMMUNITY COMMERCIAL  
 NORTH: HIGHWAY 50 AND CP-2 PLANNED COMMUNITY COMMERCIAL
- SITE AREA:**  
 TOTAL SITE = 533,061.97 SQUARE FEET OR 12.24 ACRES±  
 STREET R/W TO BE DEDICATED: 0.91 ACRES  
 NET LAND AREA REMAINING: 11.33 ACRES  
 LOT 1 = 10.45 ACRES  
 LOT 2 = 0.87 ACRES
- PLANNED USE:**  
 UNDEVELOPED  
 SENIOR LIVING COMMUNITY
- BUILDING HEIGHT:**  
 HEIGHT ABOVE GRADE:  
 MEMORY CARE = 21'-0"±  
 ASSISTED LIVING = 26'-10"±  
 INDEPENDENT LIVING = 50'-3"±
- NUMBER OF FLOORS:**  
 MEMORY CARE = 1 FLOOR (18 UNITS)  
 ASSISTED LIVING = 1 FLOOR (44 UNITS)  
 INDEPENDENT LIVING = 3 FLOORS (92 TOTAL UNITS)  
 MAX. BUILDING HEIGHT = 50'-3"± (3 STORIES)
- BUILDING AREA:**  
 GROSS FLOOR AREA RATIO (F.A.R.):  
 ASSISTED LIVING = 39,875 SF  
 INDEPENDENT LIVING FLOOR 1 = 38,915 SF  
 FLOOR 2 = 32,925 SF  
 FLOOR 3 = 33,585 SF  
 MEMORY CARE = 12,215 SF  
 TOTAL BUILDING SF = 157,515 SF
- MAX. FLOOR AREA RATIO (F.A.R.):**  
 MAX. F.A.R. ALLOWED = 0.55 F.A.R. = 250,465 SF MAX.  
 ACTUAL F.A.R. = 0.35 F.A.R.
- DWELLING UNITS PER ACRE = 14.74 DU/AC**
- PARKING:**  
 REQUIRED:  
 MEMORY CARE: NURSING HOME/ELDERLY CARE  
 1 FOR EACH 2 BEDS: 18 BEDS = 9 PARKING SPACES  
 PLUS 1 FOR EACH EMPLOYEE ON MAXIMUM SHIFT: 8 EMPLOYEES = 8 PARKING SPACES
- ASSISTED LIVING: NURSING HOME/ELDERLY CARE  
 1 FOR EACH 2 BEDS: 44 BEDS = 22 PARKING SPACES  
 PLUS 1 FOR EACH EMPLOYEE ON MAXIMUM SHIFT: 8 EMPLOYEES = 8 PARKING SPACES
- INDEPENDENT LIVING: RETIREMENT COMMUNITY  
 1 FOR EACH DWELLING UNIT: 91 UNITS = 91 PARKING SPACES  
 PLUS 1 FOR EACH EMPLOYEE ON MAXIMUM SHIFT: 16 EMPLOYEES = 16 PARKING SPACES
- TOTAL PARKING SPACES REQUIRED = 153**  
**TOTAL PARKING SPACES PROVIDED = 156**
- IMPERVIOUS COVERAGE:**  
 VEHICULAR USE AREA = 101,631.70 SF  
 BUILDING & SIDEWALK = 114,928.29 SF  
 TOTAL IMPERVIOUS = 216,559.99 SF  
 TOTAL SITE AREA = 455,391.70 SF (LOT 1)  
 % IMPERVIOUS = 47.56%
- UTILITY COMPANIES:**  
 WATER & SANITARY SEWER:  
 CITY OF LEE'S SUMMIT CITY UTILITIES  
 1200 SE HAMBLEN ROAD  
 LEE'S SUMMIT, MISSOURI 64081  
 (816) 969-1900
- ELECTRIC SERVICE:  
 KANSAS CITY POWER & LIGHT  
 TELE: (816) 471-5275
- GAS SERVICE:  
 SPIRE  
 (800) 582-1234
- FIRE DEPARTMENT:  
 LEE'S SUMMIT FIRE DEPARTMENT  
 207 SE DOUGLAS STREET  
 LEE'S SUMMIT, MO. 64063  
 (816) 969-1300
- AMBULANCE SERVICE:  
 TELE: 911
- SCHOOL DISTRICT:  
 LEE'S SUMMIT OFFICE OF SUPERINTENDENT  
 (816) 986-1000
- COMMUNICATION:  
 AT&T 1-800-246-8464  
 CENTURYLINK 1-800-246-4237


**LEGEND**

---	PROPERTY LINES
---	RIGHT-OF-WAY
---	ROAD CENTERLINE
---	EASEMENT LINES
---	PARKING SETBACK
---	BUILDING SETBACK
---	FOUND MONUMENT
---	TEMPORARY BENCHMARK
---	EXIST. POWER POLE
---	EXIST. ELECTRIC
---	EXIST. ELECTRIC
---	EXIST. GUY WIRE
---	EXIST. TELEPHONE
---	EXIST. FIRE HYDRANT
---	EXIST. WATER MAIN
---	EXIST. WATER VALVE
---	EXIST. GAS MAIN
---	EXIST. CABLE VALVE
---	EXIST. SANITARY
---	EXIST. FLARED END
---	EXIST. DECIDUOUS
---	EXIST. SIGN
---	PROP. SANITARY
---	PROP. FIRE HYDRANT
---	PROP. GATE VALVE
---	PROP. SIGN
---	PROP. FIRE DEPARTMENT
---	EXIST. OVERHEAD
---	EXIST. UNDERGROUND
---	EXIST. GAS LINE
---	EXIST. STORM SEWER
---	EX. WOOD FENCE
---	PROP. PUBLIC SIDEWALK
---	PROP. SANITARY
---	PROP. STORM SEWER
---	PROP. UNDERGROUND
---	PROP. PUBLIC WATER
---	PROP. IRRIGATION
---	PROP. WATER SIDEWALK
---	PROP. FIRE PROTECTION
---	PROP. FENCE
---	EXISTING CONTOUR
---	PROPOSED CONTOUR
---	SPILL CURB (TYPICAL)
---	STANDARD CURE
---	BACK OF CURB


**BENCHMARKS:**  
 MO DNR JA-45: KC METRO ALUMINUM CONCRETE 3"± BELOW PAVEMENT ON T SE RANSON ROAD STAMPED "JA-45" ELEV.=1046.26'  
 PUBLISHED COORDINATES (1988 ADJUST)  
 N: 303273.664M  
 E: 863885.886M  
 GRID=GROUND  
 N: 994990.3460  
 E: 2834265.6110  
 CAF: 0.99989860A

BENCHMARK #41314:  
 NORTHING: 995857.9570  
 EASTING: 2835453.8010  
 SET SQUARE CUT IN CENTER OF CONCR FOR REINFORCED CONCRETE BOX ELEVATION=1007.13' (NAVD 88)

OA CONTROL POINT #310  
 NORTHING: 995873.4445  
 EASTING: 2835537.7320  
 FOUND 1/2" REBAR W/CAP 8" SOUTH (EAST OF REINFORCED CONCRETE BOX ELEVATION=1008.08' (NAVD 88)



USER: ringbauer  
 C:\PHITCH\_B1450  
 v\_topo\_B1450  
 v\_1001-1500\018-1450-Design\AutoCAD\ Preliminary Plans\Sheets\CONVC\_SIT\_B1450.dwg  
 XREFS: v\_1001-1500\018-1450-Design\AutoCAD\ Preliminary Plans\Sheets\CONVC\_SIT\_B1450.dwg  
 2019 9:18am



EXISTING HYDRANT FLOW TEST  
 2100 SE BLUE PARKWAY  
 7/24/17  
 1004' ELEV  
 79 STATIC PSI  
 79 RESIDUAL PSI (71 PSI W/10% REDUCTION)  
 1363 GPM  
 (4000+ GPM AVAIL @ 20 PSI)

ASSUMED AVAILABLE WATER SUPPLY  
 SE RANSON RD / 12TH STREET  
 BASED UPON AVAILABLE TEST INFORMATION  
 AND ADJUSTED FOR ELEVATION  
 1050' ELEV  
 59 STATIC PSI  
 59 RESIDUAL PSI (51 PSI W/10% REDUCTION)  
 1363 GPM  
 (3200+ GPM AVAIL @ 20 PSI)

EXISTING  
 WATER TOWER

