

The Manor at Stoney Creek - 4th Plat and The Reserve at Stoney Creek - 4th Plat

	ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	☐ 6734	49.38	80.29	1,197.29	1,000.00	76.70	6,718.61	20.00
2	☐ 7246	0.00	72.07	1,197.32	1,000.00	68.45	5,940.70	20.00
3	☐ 7248	0.00	73.36	1,197.30	1,000.00	69.74	6,078.63	20.00
4	☐ 7250	0.00	77.69	1,197.29	1,000.00	74.09	6,454.55	20.00
5	☐ 7252	14.30	75.52	1,197.30	1,000.00	68.03	3,340.22	20.00
6	☐ 7254	0.00	76.39	1,197.29	1,000.00	69.04	3,385.15	20.00
7	☐ 7256	0.00	76.82	1,197.29	1,000.00	69.50	3,413.45	20.00
8	☐ 7258	0.00	79.85	1,197.29	1,000.00	75.65	5,561.35	20.00
9	☐ 7262	0.00	71.63	1,197.31	1,000.00	68.03	5,961.98	20.00
10	☐ 7264	0.00	84.19	1,197.29	1,000.00	79.77	5,555.04	20.00
11	☐ 7266	0.00	79.42	1,197.29	1,000.00	74.17	4,537.86	20.00
12	☐ 7268	8.80	69.45	1,197.29	1,000.00	59.21	2,527.39	20.00



The Manor at Stoney Creek - 4th Plat and The Reserve at Stoney Creek - 4th Plat

