

Woodside Ridge First Plat

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	<input type="checkbox"/>	5814	0.00	87.37	1,173.64	1,000.00	77.75	3,523.66	20.00
2	<input type="checkbox"/>	7300	0.00	89.52	1,174.59	1,000.00	81.25	3,973.23	20.00
3	<input type="checkbox"/>	7302	0.00	90.82	1,174.59	1,000.00	80.82	3,411.57	20.00
4	<input type="checkbox"/>	7304	0.00	90.36	1,174.53	1,000.00	80.80	3,557.06	20.00
5	<input type="checkbox"/>	7306	38.00	87.32	1,174.52	1,000.00	77.10	3,325.28	20.00
6	<input type="checkbox"/>	7308	0.00	89.49	1,174.52	1,000.00	79.77	3,482.48	20.00
7	<input type="checkbox"/>	7312	0.00	108.98	1,174.52	1,000.00	99.92	4,270.79	20.00
8	<input type="checkbox"/>	7314	0.00	86.45	1,174.52	1,000.00	75.26	3,033.01	20.00
9	<input type="checkbox"/>	7316	0.00	90.79	1,174.52	1,000.00	79.46	3,112.25	20.00
10	<input type="checkbox"/>	7318	0.00	86.91	1,174.57	1,500.00	71.99	3,876.95	20.00
11	<input type="checkbox"/>	7320	0.00	84.76	1,174.61	1,500.00	73.77	4,905.22	20.00
12	<input type="checkbox"/>	7322	5.10	86.04	1,174.57	1,000.00	73.99	2,840.84	20.00
13	<input type="checkbox"/>	7324	0.00	92.97	1,174.56	1,000.00	84.41	3,967.51	20.00
14	<input type="checkbox"/>	7326	11.20	90.37	1,174.56	1,000.00	79.21	3,135.74	20.00
15	<input type="checkbox"/>	7328	0.00	91.23	1,174.54	1,000.00	82.79	3,961.54	20.00
16	<input type="checkbox"/>	7330	0.00	97.59	1,174.22	1,500.00	86.67	5,683.55	20.00
17	<input type="checkbox"/>	7332	0.00	88.26	1,173.69	1,000.00	78.75	3,586.05	20.00
18	<input type="checkbox"/>	7334	18.20	99.09	1,173.68	1,000.00	85.69	2,996.24	20.00
19	<input type="checkbox"/>	950	0.00	84.77	1,174.64	1,500.00	74.50	5,209.88	20.00



Woodside Ridge First Plat

