

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date: Friday, April 19, 2019

To:

Property Owner: MID-CONTINENT PUBLIC Email:

LIBRARY Fax #: <NO FAX NUMBER>

Applicant: MID-CONTINENT PUBLIC LIBRARY Email: QFUNG@MYMCPL.ORG

Fax #: <NO FAX NUMBER>

Engineer: OLSSON ASSOCIATES (BRIAN LADD) Email: BLADD@OLSSONASSOCIATES.COM

Fax #: (913) 381-1174

Architect: SAPP DESIGN ARCHITECTS Email: STUFFLEBEAM@SDAARCHITECTS.COM

Fax #: <NO FAX NUMBER>

From: Shannon McGuire, Planner

Re:

Application Number: PL2019043

Application Type: Commercial Final Development Plan
Application Name: MID-CONTINENT PUBLIC LIBRARY

Location: 2240 SE BLUE PKWY, LEES SUMMIT, MO 64063

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions

- 1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$39,028.93.
- 2. MoDOT approval of the project is required prior to formal approval.
- 3. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.
- 4. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.
- 5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
- 6. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments