

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Monday, April 22, 2019

To:

Property Owner: OAK VIEW LEES SUMMIT LLC

Email:

Fax #: <NO FAX NUMBER>

Applicant: OAK VIEW CAPITAL PARTNERS, LLC

Email: BRAD@OAKVIEWCP.COM

Fax #: <NO FAX NUMBER>

Engineer: SCHLAGEL & ASSOCIATES

Email: SCHLAGEL & ASSOCIATES

Fax #: (913) 492-8400

From: Hector Soto Jr., Planning Division Manager

Re:

Application Number: PL2018165

Application Type: Commercial Final Development Plan

Application Name: OAKVIEW CLIMATE CONTROLLED STORAGE

Location: 1450 NE DOUGLAS ST, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See

comments below to determine the required revisions and resubmit to the Development Services Department. Resubmit six (6) full size sets of plans (no larger than 24"x36") folded to 8-½"x11", four (4) copies of the comment response letter, and one (1) digital copy following the electronic plan submittal guides as stated above. Revised plans will be reviewed within five (5) business days of the date received.

Required Corrections:

Planning Review	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	Corrections
------------------------	-----------------------------------	---	-------------

1. EXTERIOR MATERIALS. The pre-finished MBCI Masterline - 16 Wall Panel System material shown on the elevations will need to have the optional embossed finish in order to meet City ordinance for approved materials. The standard smooth finish for this product is not allowed.

Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. The plans show additional storm lines being installed as part of this project. The estimate is required to include any storm lines greater than (i.e., but not including) 6 inches in diameter, including any roof drain. Please add this information to the estimate previously provided and provide a signed and sealed copy.

2. Contact the Field Engineering Inspector at (816) 969-1200 at least 48 hours prior to the onset of construction.

3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Complete
--------------------	----------------------------	--	----------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2012 International Fire Code.

Standpipe connections are required in the stairwells.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
