

Summit Orchard Lot 4

	ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	<input type="checkbox"/> 6566	0.00	82.04	1,194.34	1,500.00	69.38	3,841.24	20.00
2	<input type="checkbox"/> 7344	0.00	85.11	1,198.42	1,500.00	81.80	13,916.94	20.00
3	<input type="checkbox"/> 7346	120.00	78.91	1,195.11	1,500.00	67.63	4,189.89	20.00



Summit Orchard Lot 4

