

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date: Monday, May 20, 2019

To:

Property Owner: MIDWEST DIVISION LSH LLC Email:

Fax #: <NO FAX NUMBER>

Applicant: S&ME, Inc. Email: ghuddleston@smeinc.com

Fax #: <NO FAX NUMBER>

Engineer: S&ME, Inc. Email: ghuddleston@smeinc.com

Fax #: <NO FAX NUMBER>

From: Hector Soto Jr., Planning Division Manager

Re:

Application Number: PL2017190

Application Type: Commercial Final Development Plan

Application Name: LEE'S SUMMIT MEDICAL CENTER - HCA MEDICAL OFFICE BUILDING

Location: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Hector Soto Jr.	Planning Division Manager	Approved with Conditions
	(816) 969-1238	Hector.Soto@cityofls.net	

1. BUILDING ELEVATIONS. Provide 3 new copies of the building exterior elevations. Previously submitted copies have been used as markup copies.

Engineering Review	Gene Williams	Senior Staff Engineer	Approved with Conditions
	(816) 969-1223	Gene.Williams@cityofls.net	

- 1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$41,543.61
- 2. Three (3) complete plan sets must be submitted in full-size, paper form prior to formal approval of the Final Development Plan.
- 3. An as-built Record Drawing shall be submitted and approved by the City for the modified detention basin, showing that the basin has been installed according to plan.
- 4. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.
- 5. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.
- 6. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
- 7. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	

- 1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.
- 2. IFC 503.2.1 Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6, and an unobstructed

vertical clearance of not less than 13 feet 6 inches (4115 mm)

Action required- Use CG-2 curbs for the passenger side curbs at the reserved Parking gate island.

Traffic Review	Michael Park	City Traffic Engineer	No Comments
	(816) 969-1820	Michael.Park@cityofls.net	

1. Prior comments were not addressed (non responsive), but those comments did not require plan changes and remain only as suggestions to improve traffic safety and operations on-site and better compliance with current AMC. The suggested changes should have no impact on the public transportation system.

Building Codes ReviewJoe FroggePlans ExaminerNo Comments(816) 969-1241Joe.Frogge@cityofls.net