

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Wednesday, June 19, 2019

To:

Applicant: AJ BROWN INC

Email: ANDREW@AJBROWN.COM

Fax #: <NO FAX NUMBER>

Property Owner: BROWNSTONE
PROPERTIES-LEE'S SUMMIT LLC

Email:

Fax #: <NO FAX NUMBER>

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

From: Shannon McGuire, Planner

Re:

Application Number: PL2019113

Application Type: Commercial Final Development Plan

Application Name: GODDARD SCHOOL FOR EARLY CHILDHOOD DEVELOPMENT

Location: 3395 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See

comments below to determine the required revisions and resubmit to the Development Services Department. Resubmit six (6) full size sets of plans (no larger than 24"x36") folded to 8-½"x11", four (4) copies of the comment response letter, and one (1) digital copy following the electronic plan submittal guides as stated above. Revised plans will be reviewed within five (5) business days of the date received.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	Approved with Conditions
------------------------	-----------------------------------	---	--------------------------

1. Note #6 on sheet A2.1 still lists Country Lane Red as a proposed color. This color is not consistent with the colors of the surrounding development or the approved PDP. Please remove this proposed color from the plans sheets.

Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. The Engineer’s Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee, and right of way fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$34,921.90

2. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.

3. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.

4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

5. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City’s Design and Construction Manual.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. IFC 506.1 - Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type listed in accordance with UL 1037, and shall contain keys to gain necessary access as required by the fire code official. 506.1.1 Locks. An approved lock shall be installed on gates or similar barriers when required by the fire code official.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
