



SCHLAGEL & ASSOCIATES, P.A.

Engineers • Planners • Surveyors • Landscape Architects

June 27, 2019

Sue Pyles, PE
Sr. Staff Engineer
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

RE: PERGOLA PARK, 4TH PLAT PL 2019155 – SANITARY MAIN EXTENSION

Dear Sue:

This letter is regarding comments received May 6, 2019 for the above referenced project to which we have the following responses:

Engineering Review

1. Do the easements shown in this plan set match the final plat moving through the approval process? If not, how will this all be coordinated? An email response to this question is fine.

Response: Clarification has been sent via email.

2. Due to lack of adequate horizontal separation, remove the existing pipe upstream of Ex MH A4 in the vicinity of the structure and replace with Class 50 ductile with zinc coated exterior and 401 super coat interiors.

Response: Note on plan and profile has been updated.

3. Remove RCE from the Engineer's Estimate of Probable Construction Costs and replace with Zinc Coated DIP.

Response: RCE description has been changed to zinc coated DIP.

If you have any further comments or questions regarding this survey, please do not hesitate to contact me. Thank you.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.

Mark A. Breuer, PE
Principal / Engineering Manager
Direct 913-322-7154
mab@schlagelassociates.com

/bl
Enclosures

c: NLVC, LLC