

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Tuesday, July 23, 2019

To:

Property Owner: HY VEE FOOD STORES INC

Email:

Fax #: <NO FAX NUMBER>

Applicant: BURNS & MCDONNELL ENGINEERING
COMPANY INC

Email: WASHEPHERD@BURNSMCD.COM

Fax #: (816) 822-3413

Engineer: BURNS & MCDONNELL ENGINEERING
COMPANY INC

Email: WASHEPHERD@BURNSMCD.COM

Fax #: (816) 822-3413

From: Jennifer Thompson, Planner

Re:

Application Number: PL2019198

Application Type: Commercial Final Development Plan

Application Name: HY-VEE WEST AISLES ONLINE

Location: 310 SW WARD RD, LEES SUMMIT, MO 64081

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Jennifer Thompson (816) 969-1239	Planner Jennifer.Thompson@cityofls.net	Approved with Conditions
------------------------	-------------------------------------	---	--------------------------

1. The proposed wall signs/canopy signs will require separate permit review and approvals.
2. All proposed ground mounted and roof mounted units shall be screened from view by methods approved by the Unified Development Ordinance.

Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$2,901.00
2. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.
3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
4. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
