

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date: Friday, August 09, 2019

To:

Applicant: CLAYTON PROPERTIES GROUP INC Email:

Fax #: <NO FAX NUMBER>

Engineer: OLSSON ASSOCIATES (SHANNON

BUSTER)

Email: SBUSTER@OLSSONASSOCIATES.COM

Fax #: (816) 587-1393

From: Shannon McGuire, Planner

Re:

Application Number: PL2019205

Application Type: Commercial Final Development Plan

Application Name: HAWTHORNE RIDGE POOL

Location: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See comments below to determine the required revisions and resubmit to the Development Services Department. Resubmit six (6) full size sets of plans (no larger than 24"x36") folded to 8-½"x11", four (4) copies of the comment response letter, and one (1) digital copy following the electronic plan submittal guides as stated above. Revised

plans will be reviewed within five (5) business days of the date received.

Required Corrections:

Planning Review	Shannon McGuire	Planner	Corrections
	(816) 969-1237	Shannon.McGuire@cityofls.net	

- 1. All light fixtures on properties within or adjoining residential uses and/or districts shall not exceed 15 feet in height within the perimeter area. For purpose of this standard, the perimeter area shall be measured 100 feet from the property line closest to the residential use and/or district. Outside the perimeter area, the overall height may be increased to 20 feet, measured to the top of the fixture from grade. As this property is within the R-1 residential zoning district the proposed pole lights are limited to 15 feet in height.
- 2. The proposed wall mounted food lighting is not permitted. All outdoor light fixtures shall use full cut-off lenses, to prevent glare and light spill from the project site onto adjacent properties, buildings and roadways. If the intent of these lights is for security lighting, they must be controlled and activated by motion sensor devices and have a maximum duration not to exceed 10 minutes and not to exceed 100 watts for incandescent, 26 watts for compact fluorescent, or 40 watts for other lighting sources.

Engineering Review	Gene Williams	Senior Staff Engineer	Approved with Conditions
	(816) 969-1223	Gene.Williams@cityofls.net	

- 1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost), plus a right of way and tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$11,632.99
- 2. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.
- 3. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.
- 4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
- 5. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2012 International Fire Code.

The clubhose is considered an A2 occupancy and should be designed accordingly when submitting plans for a building permit..

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions