

#### **DEVELOPMENT SERVICES**

# Commercial Final Development Plan Applicant's Letter

Date: Thursday, September 12, 2019

To:

**Property Owner**: ER PROPERTIES LLC Email:

Fax #: <NO FAX NUMBER>

Applicant: STRICKLAND CONSTRUCTION CO INC Email: JACQUELINE@STRICKLANDCONSTRUCTION.COM

Fax #: (913) 747-7272

Engineer: HG CONSULT, INC Email: ksterrett@hgcons.com

Fax #: <NO FAX NUMBER>

From: Jennifer Thompson, Planner

Re:

**Application Number:** PL2019238

Application Type: Commercial Final Development Plan
Application Name: ATTIC STORAGE OF LEES SUMMIT

**Location:** 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

#### **Electronic Plans for Resubmittal**

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

#### **Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

### **Review Status:**

Approved: See below for any conditions of approval.

## **Required Corrections:**

**Building Codes Review** Joe Frogge

(816) 969-1241

Planning Review	Jennifer Thompson (816) 969-1239	Planner Jennifer.Thompson@cityofls.net	No Comments
Engineering Review	Sue Pyles (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions

- 1. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
- 2. Contact the Field Engineering Inspector at (816) 969-1200 at least 48 hours prior to the onset of construction.
- 3. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$11,041.78
- 4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions		
	(816) 969-1303	Jim.Eden@cityofls.net			
All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions					
in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders					
during emergency operations, shall be in accordance with the 2018 International Fire Code.					
Traffic Review	Michael Bark	City Traffic Engineer	Not Required		
Traffic Review	Michael Park	City Traffic Engineer	Not Required		
	(816) 969-1820	Michael.Park@cityofls.net			

Plans Examiner

Joe.Frogge@cityofls.net

Not Required