

**DEVELOPMENT SERVICES**

**Commercial Final Development Plan  
Applicant's Letter**

**Date:** Monday, September 23, 2019

**To:**

**Property Owner:** METCALF BANK

Email:

Fax #: <NO FAX NUMBER>

**Applicant:** OREILLY DEVELOPMENT (DENISE HEINTZ)

Email: DENISE@OREILLYDEVELOPMENT.COM

Fax #: <NO FAX NUMBER>

**Engineer:** OLSSON (JANE EARNHART)

Email: JEARNHART@OLSSON.COM

Fax #: <NO FAX NUMBER>

**Architect:** SWD ARCHITECTS - PAUL STARK

Email: pstark@swdarchitects.com

Fax #: (816) 531-1978

**From:** Jennifer Thompson, Planner

**Re:**

**Application Number:** PL2019218

**Application Type:** Commercial Final Development Plan

**Application Name:** THE PRINCETON LEE'S SUMMIT SENIOR LIVING COMMUNITY

**Location:** 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

**Electronic Plans for Resubmittal**

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

**Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

**Review Status:****Required Corrections:**

<b>Planning Review</b>	Jennifer Thompson (816) 969-1239	Planner Jennifer.Thompson@cityofls.net	No Comments
------------------------	-------------------------------------	---	-------------

<b>Engineering Review</b>	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. Prior to formal approval, an extra full size paper copy of the Final Development Plan shall be required.
2. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), right of way fee, and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$ to be determined based on quote for meter setup fees.
3. Contact Field Engineering Inspections at (816) 969-1200 at least 48 hours prior to the onset of construction.
4. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.
5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
6. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

<b>Fire Review</b>	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

<b>Traffic Review</b>	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

<b>Building Codes Review</b>	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------