



Click image to open Product Page

Luminaire Schedule									
Symbol	Qty	Label	Arrangement	Description	LLD	UDF	LLF	Arr. Lum. Lumens	Arr. Watts
	32	C	SINGLE	CRUS-SC-LED-HQ-50 MTD @ 15'	1.000	1.000	1.000	18633	132.4
	8	W	SINGLE	MCOWP-64-45-11' MH	1.000	1.000	1.000	8129	62.16

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
ALL CALCS AT GRADE	Illuminance	Fc	1.64	86.3	0.0	N.A.	N.A.
CANDPY SUMMARY	Illuminance	Fc	70.19	86.3	41.9	1.68	2.06

Based on the information provided, all dimensions and luminaire locations shown represent recommended positions. The engineer and/or architect must determine the applicability of the layout to existing or future field conditions.

This lighting plan represents illumination levels calculated from laboratory data taken under controlled conditions in accordance with The Illuminating Engineering Society (IES) approved methods. Actual performance of any manufacturer's luminaires may vary due to changes in electrical voltage, tolerance in lamps/LED's and other variable field conditions. Calculations do not include obstructions such as buildings, curbs, landscaping, or any other architectural elements unless noted. Fixture nomenclature noted does not include mounting hardware or poles. This drawing is for photometric evaluation purposes only and should not be used as a construction document or as a final document for ordering product.

Total Project Watts
Total Watts = 4734.08



LIGHTING PROPOSAL LO-149576-1A

SUMMIT ORCHARDS
420 NW CHEPMAN RD
LEE'S SUMMIT, MO

BY:WVE DATE:11/5/19 REV:11-27-19 SHEET 1 OF 1

SCALE: 1"=30'

0 30