

PARKING LOT LIGHTING FIXTURE SCHEDULE											
NOTES:											
1.	FIXTURE SHALL BE RATED FOR OUTDOOR USE.										
2.	PROVIDE 20' SQUARE POLE.										
TYPE MARK	MANUFACTURER	MODEL NUMBER	DRIVER	FINISH	VOLTAGE	LAMP TYPE	LAMP QTY	COLOR TEMP	TOTAL WATTAGE	NOTES	EQUIVALENTS
PL01	SIGNIFY	ECF-S-32L-1.2A-NW-G2-AR-2-UNV-MGY	STD	MEDIUM GRAY	UNV	LED		4000	122	1,2	
PL02	SIGNIFY	ECF-S-48L-1.2A-NW-G2-AR-2-UNV-MGY	STD	MEDIUM GRAY	UNV	LED		4000	122	1,2	
PL02H	SIGNIFY	ECF-S-48L-1.2A-NW-G2-AR-2-UNV-HIS-MGY	STD	MEDIUM GRAY	UNV	LED		4000	122	1,2	
PL03	SIGNIFY	ECF-S-48L-1.2A-NW-G2-AR-3-UNV-MGY	STD	MEDIUM GRAY	UNV	LED		4000	183	1,2	
PL04	SIGNIFY	ECF-S-48L-1.2A-NW-GR-AR-4-UNV-MGY	STD	MEDIUM GRAY	UNV	LED		4000	183	1,2	
PL04aH	SIGNIFY	ECF-S-32L-1.2A-NW-G2-AR-2-UNV-HIS-MGY	STD	MEDIUM GRAY	UNV	LED		4000	122	1,2	
PL05	SIGNIFY	ECF-S-32L-1.2A-NW-G2-AR-5-UNV-MGY	STD	MEDIUM GRAY	UNV	LED		4000	183	1,2	
PL-SG01	BEGA	BEGA-24509K4	DIM	BY ARCH	120	LED		4000	56	1	
PL-WP01	EATON	ENC-E02-LED-E1-BL2-[FINISH]	-	BY ARCH	120	LED		4000	47	1	
PL-WP02	EATON	ENC-E01-LED-E1-BL2-[FINISH]	-	BY ARCH	120	LED		4000	25	1	





POLE BASE COVER BY POLE

MANUFACTURER

1" GROUT COVER

SMOOTH RUB FINISH

STRENGTH

CONCRETE, 2500 PSI MINIMUM

LIGHT POLE AND LIGHTING

FIXTURE)







Sapp Design Associates Architects, P.C. Missouri State Certificate of Authority #000607

816.300.0300

1629 Walnut Kansas City, MO 64108

Company Name

Missouri State Certificate of Authority # SPECIAL NOTICES

n the event the client consents to, allows, authorizes or approves of changes to any plans, specifications or other construction documents, and these changes are not approved in writing by the design professional, the client recognizes that such changes and the results thereof are not the responsibility of the design professional. Therefore, the client agrees to release the design professional from any liability arising from the construction, use or result of such changes. In addition, the client agrees to the fullest extent permitted by law, to indemnify and hold the design professional harmless from any damage, liability or cost (including reasonable attorney's fees and osts of defense) arising from such changes.

The personal seal of the registered Architect or Engineer shall be the legal equivalent of his signature whenever & wherever used, and the owner of the seal shall authenticate this sheet and the specification sections pertaining to this sheet. Responsibility shall be disclaimed for all other plans, specifications, estimates, reports or other documents or instruments relating to or intended to be used for any part or parts of the architectural project.

LIBI ηt

BE

Mid-Contin

Engineer of Record

PRELIMINARY: **UNCERTIFIED FOR** PRE-DEVELOPMENT **PLAN REVIEW**

12/10/2019

JACOB A NELSON, PE MO PE-2009018758 ENGINEERING 3659 SOUTH AVENUE

WWW.TRUE-MEP.COM True Engineering Group LLC Missouri State Certificate of Authority #E-2016000752

SPRINGFIELD, MO 65807

417.708.7025

12/10/2019

Revision No. Description Date

SITE PHOTOMETRIC PLAN

opyright 2019 - Sapp Design Associates, Architects, P.C