
DEVELOPMENT SERVICES

Final Plat
Applicant's Letter

Date: Friday, January 31, 2020

To:

Property Owner: FIVE THIRTY LLC

Email:

Fax #: <NO FAX NUMBER>

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

From: Jennifer Thompson, Planner

Re:

Application Number: PL2019415

Application Type: Final Plat

Application Name: MAIN ORCHARD

Location: 510 NW MAIN ST, LEES SUMMIT, MO 64063
6 NW ORCHARD ST, LEES SUMMIT, MO 64063

Tentative Schedule

Submit revised plans by noon on Wednesday, January 15, 2020 (4 full size paper copies, 1 reduced 8 ½" x 11" copy, and 4 copies of the comment response letter).

Planning Commission Meeting: February 13, 2020 at 05:00 PM

City Council date will be set after all subdivision related public improvements have been completed and a Certificate of Final Acceptance has been issued. In lieu of completion of public improvements, an escrow secured with cash or an irrevocable letter of credit shall be deposited with the City to secure the completion of all public improvements prior to scheduling a City Council date.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Re-submittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns you may have.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at 816-969-1200.

Voluntary Residential Development Surcharge

In a combined effort with both the R-4 and the R-7 School Districts the City of Lee's Summit is working together to educate the development community on a new program, the "Lee's Summit Voluntary Residential Development Surcharge." This is a program which will help raise capital to build new schools for our community. Brochures are available at the front counter of both the Development Services Department. You can also find more information on the City of Lee's Summit web site at www.cityofls.net. (For more information please contact the Board of Education at 986-2400).

Analysis of Final Plat:

GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	No Comments
Planning Review	Jennifer Thompson (816) 969-1239	Planner Jennifer.Thompson@cityofls.net	Corrections

1. Please submit an electronic copy of the legal description in Microsoft Word document.

2. Provide the single-family residential compatibility form.

3. Label the addresses as follows:

Lot 1: 518 NW Main St.

Lot 2: 514 NW Main St.

Lot 3: 510 NW Main St.--existing

Lot 4: 508 NW Main St.

Lot 5: 504 NW Main St.

Lot 6: 500 NW Main St.

Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Corrections
---------------------------	---------------------------------	---	-------------

1. Please add a note concerning stormwater detention being provided for each lot, in accordance with the Master Drainage Plan. Ongoing maintenance and ownership should also be described in this note.

2. Please show a general outline of the location of each detention basin on the plat. A note may be added which references the approved Master Drainage Plan, and discussing the need to construct during the building permit process.

3. Final approval of the plat is contingent upon the sanitary sewer being completed, or security provided in accordance with the Unified Development Ordinance.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
