


Summit View Farms 4th Plat With Maximum Day Demand With Fire Flow

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	☐	7158	0.00	72.12	1,193.43	1,000.00	64.12	2,866.19	20.00
2	☐	7168	0.00	74.72	1,193.43	1,000.00	65.19	2,656.89	20.00
3	☐	7678	0.00	76.04	1,193.49	1,000.00	70.16	3,565.04	20.00
4	☐	7680	5.10	78.18	1,193.43	1,000.00	56.62	1,733.16	20.00
5	☐	7684	8.10	79.49	1,193.45	1,000.00	71.55	3,103.82	20.00
6	☐	7686	4.60	72.55	1,193.44	1,000.00	59.53	2,174.81	20.00
7	☐	8184	0.00	74.72	1,193.44	1,000.00	66.69	2,938.03	20.00
8	☐	8186	6.10	70.38	1,193.44	1,000.00	57.90	2,179.46	20.00



		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	☐	7158	0.00	69.87	1,188.24	0.00	69.87	2,703.68	20.00
2	☐	7168	0.00	72.47	1,188.24	0.00	72.47	2,517.77	20.00
3	☐	7678	0.00	73.84	1,188.41	0.00	73.84	3,371.10	20.00
4	☐	7680	10.20	75.93	1,188.24	0.00	75.93	1,665.18	20.00
5	☐	7684	16.20	77.24	1,188.27	0.00	77.24	2,953.37	20.00
6	☐	7686	9.20	70.31	1,188.27	0.00	70.31	2,070.76	20.00
7	☐	8184	0.00	72.47	1,188.25	0.00	72.47	2,777.64	20.00
8	☐	8186	12.20	68.14	1,188.25	0.00	68.14	2,071.18	20.00

