

March 26, 2020

City of Lee's Summit
Development Services
Attn: Sue Pyles
220 SE Green Street
Lee's Summit, MO 64063

9001 State Line Rd., Ste. 200
Kansas City, MO 64114
[P] 816.361.0440
[F] 816.361.0045
LampRynearson.com

RE: PL2019395 - Summit View Farms 4th Plat, Water Main Plans
Lamp Rynearson Job No. 0318050.02
Response to City Comments

Dear Ms. Pyles:

Enclosed are revised drawings for the above referenced project. The resubmittal addresses the City comments that were received on January 9, 2020 from the January 7, 2020 submittal. Revised drawings were submitted to MDNR on March 18, 2020 to support the Construction Permit application.

The following written responses are provided to indicate the actions to address the City comments. City comments are indicated in *italics* with Lamp Rynearson responses in **bold**.

Engineering Review - Corrections

1. *Line 4-04 is labeled as 4-05 in the label at the tee connection to Line 4-02. If you would like us to redline that revision, please email me that request.*

The label has been corrected.

2. *Engineer's Estimate of Probable Construction Costs:*

- *Remove reference to 90 degree bends, they are not used.*
- *Add a line item for 6"x8" Reducer.*
- *Verify quantities for Items 2, 5, and 6.*
- *Verify unit prices for Items 1-3, they appear slightly low.*

The estimate has been updated, including providing additional bends.

We hope that we have adequately addressed each one of the review comments. Please contact me at dan.mcgee@lamprynearson.com or (816) 361-0440 should you have any questions regarding this submittal.

Sincerely,

LAMP RYNEARSON



Dan McGhee, P.E.
Senior Project Manager

\\L:\Engineering\0318050 SVFDG Summit View Farms 3rd Plat\TRANSMITTALS\OUTGOING\City\Summit View Farms 4th Plat\2020 03 26 SVF4 Water Response Letter.docx

Cc: Bill Kenney, Summit View Farms Development Group, LLC
Enclosure