

April 3, 2020

City of Lee's Summit
Development Services
Attn: Sue Pyles
220 SE Green Street
Lee's Summit, MO 64063

9001 State Line Rd., Ste. 200
Kansas City, MO 64114
[P] 816.361.0440
[F] 816.361.0045
LampRynearson.com

RE: PL2019395 - Summit View Farms 4th Plat, Water Main Plans
Lamp Rynearson Job No. 0318050.02
Responses to City Comments

Dear Ms. Pyles:

Enclosed are revised drawings for the above referenced project. The resubmittal addresses the City comments that were received on April 2, 2020 from the March 26, 2020 resubmittal.

The following written responses are provided to indicate the actions to address the City comments. City comments are indicated in *italics* with Lamp Rynearson responses in **bold**.

Engineering Review - Corrections

- 1. The bend at Line 3 Sta. 1+62.69 is shown as 45 deg in Plan view and 11.25 deg in Profile view. Please reconcile. The 11.25 deg callout appears correct.*
The plan view label has been corrected to 11.25 degrees.
- 2. Please revise the tee callout at Line 4 Sta. 0+00 to 8" x 8" in the Profile view.*
The tee callout has been corrected in the profile view.
- 3. Lines 3-5 all show 8"x6" reducers. Please revise the quantity to 3 in the estimate.*
The quantity of reducers has been updated in the estimate.

We hope that we have adequately addressed each one of the review comments. Please contact me at dan.mcgee@lamprynearson.com or (816) 361-0440 should you have any questions regarding this submittal.

Sincerely,

LAMP RYNEARSON



Dan McGhee, P.E.
Senior Project Manager

\\L:\Engineering\0318050 SVFDG Summit View Farms 3rd Plat\TRANSMITTALS\OUTGOING\City\Summit View Farms 4th Plat\2020 04 03 SVF4 Water Response Letter.docx

Cc: Bill Kenney, Summit View Farms Development Group, LLC
Enclosure