

DEVELOPMENT SERVICES

Date: Tuesday, April 21, 2020

To: ENGINEERING SOLUTIONS
50 SE 30TH ST
LEES SUMMIT, MO 64082

From: Sue Pyles, P.E.
Senior Staff Engineer

Application Number: PL2020101

Application Type: Engineering Plan Review

Application Name: The Estates of Chapel Ridge 2nd Plat
The Townhomes of Chapel Ridge 2nd Plat - Public Sanitary

The Development Services Department received plans for this project on April 08, 2020. We have completed our review and offer the following comments listed below.

- Resubmit one (1) comment response letter, and one (1) digital copy following the electronic plan submittal guides as stated below.
- Revised plans will be reviewed within five (5) business days of the date received.

Engineering Review - Corrections

1. Sheet C.400:
 - KCP&L is now Evergy. Please update the plan set.
 - Sanitary Sewer Note 6 indicates that 3' of compacted fill be placed prior to trenching. This exceeds the 18" required by the City, which is fine. I just wanted to point it out.
2. Sheet C.401: Revise the line weight of the existing water main that will be removed, to match other existing infrastructure.
3. Sheet C.402: Revise the Line A proposed MHs so that the top elevations matches the proposed grade.
4. Sheet C.403:
 - Include the following note: "Compacted Fill shall be placed to a minimum X" above the top of the pipe prior to installation." Revise "X" to match Sanitary Sewer Note 6 on Sheet C.400.
 - Show and label the limits of the compacted fill placement in the Profile view. Use hatching for clarity.
5. Submit an Engineer's Estimate of Probable Construction Costs.

Traffic Review - Not Required

In order to calculate the Engineering Plan Review and Inspection Fee, a sealed Engineer's Opinion of Probable Construction Costs shall accompany your final submittal copies. The itemized estimate (material and installation) shall be sufficiently broken down and shall include the following items, as applicable.

- Public infrastructure, both onsite and offsite.
- Private street construction, including parking lots and driveways.
- Sidewalks located within the right-of-way.
- ADA accessible ramps.
- Sanitary sewer manholes and piping between manholes, including private mains.
- Connection of the building sanitary sewer stub to the public main.
- Waterlines larger than 2 inches in diameter, valves, hydrants, and backflow preventer with vault, if outside the building.
- Stormwater piping greater than 6 inches in diameter, structures, and detention / retention facilities - public or private.
- Water quality features installed to meet the 40-hour extended duration detention requirements.
- Grading for detention / retention ponds.
- Grading to establish proper site drainage.
- Utility infrastructure adjustments to finished grade (i.e. manhole lids, water valves, etc.).
- Erosion and sediment control devices required for construction.
- Re-vegetation and other post-construction erosion and sediment control activities.

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact me if you have any questions or comments.

Sincerely,

Sue Pyles, P.E.
Senior Staff Engineer
(816) 969-1245
Sue.Pyles@cityofls.net

cc: Development Engineering Project File