



9801 Renner Boulevard,
Suite 300
Lenexa, KS 66219

April 21, 2020

Sue Pyles, P.E.
Senior Staff Engineer
(816) 969-1245
City of Lee's Summit, MO
220 SE Green Street
Lee's Summit, MO 64063

RE: PL2019334 – PARAGON STAR - PUBLIC SANITARY

We have received your comments dated April 9th, 2020 for the above referenced project. Our responses follow each comment. The comment responses have been organized by the review section they pertain to.

Engineering Review

Engineering Review - Corrections

1. There is a future stub shown at MH D-1 that needs removed, like was done at MH A-7. Please revise.

GBA Response: Revised

2. Please remove the Tee Orientation and Riser and Grease Interceptor details and add the Building Sewer Stub and Riser detail.

GBA Response: Revised. Detail added

We believe we have addressed all comments on this project. If you have any additional questions or concerns, please feel free to contact us.

Sincerely,

GEORGE BUTLER ASSOCIATES, INC.

Clint Loumaster, P.E.