



Application No. PL2020101

Application Name: The Townhomes of Chapel Ridge 2nd Plat - Public Sanitary

Engineering Review – Corrections

1. Please revise the off-site sanitary easement to a minimum of 2 feet wide for every foot of trench depth as required by Design and Construction Manual Section 6501.L.c. Submit a draft version of this easement for review. The easement will need to be recorded prior to issuance of Substantial Completion for the project.

Revised.

2. Revise the Total Cost, it appears that the last two items aren't included. When resubmitting, make sure the estimate is signed/sealed.

Revised.

Feel free to contact me should you have any addition questions regarding this project.

Thank You,

Matt Schlicht