

June 19th, 2020

Sue Pyles, PE
Sr. Staff Engineer
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

RE: WOODLAND GLEN 2ND PLAT PL 2020041 – WATER MAIN EXTENSION

Dear Sue:

This letter is regarding comments received March 12, 2020 for the above referenced project to which we have the following responses:

Engineering Review

1. Line 1 exceeds the allowable dead-end length of 700 feet. Please add a water line along the north side of SW14th Street that connects line 1 with the existing 8" main on the east side of Ward Road.

Response: Line 3 has been added to connect to existing main on the east side of Ward Road.

2. Please show and label the existing 30" main along the south side of SW 14th Street in plan view and show the crossing in profile view.

Response: The existing 36" water main has been labeled in all plan sheets and in the profile crossing for line 1.

3. Where the existing water main is being removed across Heartwood Drive, please show capping the existing cross.

Response: Note was added to cap the existing cross to the east where the existing line is being removed.

Please contact me if you have any questions or comments. If you have any further comments or questions regarding this survey, please do not hesitate to contact me. Thank you.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.

Mark A. Breuer, PE
Principal / Engineering Manager
Direct 913-322-7154
mab@schlagelassociates.com

/mdr
Enclosures

c: NLVC, LLC