

PROJECT DATA

ADDRESS: 2751 NE DOUGLAS ST, UNIT V
LEES SUMMIT, MO 64064

TYPE IIIB CONSTRUCTION
S-1 BUILDING TYPE
OCCUPANCY - S-1

SINGLE STORY W/ MEZZANINE
AREA: 125' X 95' = 11,875 sq.ft.
Type IIIB allowed 17,000 sq.ft.
55' above grade plan
2 story

NON SPRINKLERED
MAX HEIGHT- 31'-1"
OCCUPANCY
AIRCRAFT HANGER - 9,895sqFT/ 500 = 20 OCCUPANTS
BUSINESS AREA- 1,980sq.ft/ 150 = 13 OCCUPANTS
MEZZANINE BUSINESS AREA- 1,980/ 150 = 13 OCCUPANTS

TOTAL 46 OCCUPANTS

ZONING: AIRPORT ZONE

• THE FOLLOWING REQUIRE SPECIAL INSPECTIONS IN ACCORDANCE WITH THE BUILDING CODE:
CAST-IN-PLACE CONCRETE
STRUCTURAL STEEL
VERIFICATIONS OF SOILS AND INSPECTION OF FILL PLACEMENT
WOOD CONSTRUCTION
PAVEMENT INSPECTION (OWNER SHALL BE INFORMED OF INSPECTION AND SHALL ALSO BE ON SITE) DURING INSPECTION.
FOR ADDITIONAL INFORMATION SEE STRUCTURAL

• SPECIAL INSPECTIONS WILL BE PERFORMED BY A QUALIFIED AGENCY CONTRACTED BY THE OWNER. CONTRACTOR TO COORDINATE SCHEDULE WITH THE INSPECTOR. A COPY OF ALL SPECIAL INSPECTIONS, FIELD TEST, ETC. SHALL BE SENT TO CITY INSPECTIONS DEPARTMENT. SPECIAL INSPECTIONS TO BE PROVIDED ELECTRONICALLY TO THE CITY BUILDING OFFICIAL IN ACCORDANCE WITH IBC 1704.

NOTES:
• DRAWINGS ARE NOT TO BE SCALED.
• TERMITE CONTROL TO BE PROVIDED


DRAWING INDEX

A100 COVER SHEET, CODES & LS PLAN
A101 FLOOR PLAN
A102 MEZZANINE PLAN & ELEVATIONS
A103 ELEVATIONS,
A104 SECTIONS
A105 INTERIOR ELEVATIONS, DETAILS
WINDOW & DOOR SCHEDULE

S100 FOUNDATION PLAN
S200 DETAILS
S201 DETAILS
P101 PLUMBING PLAN
P201 SCHEDULES, RISER DIAGRAM & DETAILS

MP000 SPECIFICATIONS
M101 MECHANICAL PLAN
M201 SCHEDULES

E 000 SPECIFICATIONS
E 100 ELECTRICAL PLAN





LIFE SAFETY PLAN

SCALE 1/8"=1'-0"

Lee's Summit City Council adopted building code regulations ([Ordinance #8536](#)) and fire code ([Ordinance #8537](#)). These ordinances adopt provisions from the following nationally published construction codes:

- 2018 International Building Code
- 2018 International Plumbing Code
- 2018 International Mechanical Code
- 2018 International Fuel Gas Code
- 2018 International Residential Code
- 2018 International Fire Code
- 2017 National Electrical Code
- ICC/ANSI A117.1-2009, Accessible and Usable Buildings and Facilities

NATIONAL FIRE PROTECTION AGENCY (NFPA) 409 STANDARDS ON HAIRCRAFT HANGERS



UL U305	Fire Rating	System Thickness	STC
Interior Partitions - Wood Stud (Load-Bearing)	1 hours	4 3/4 in.	33

ASSEMBLY DETAILS

Gypsum Board: 5/8" Thick Gypsum Board (UL Type ULIX™)

Wood Studs: 2x4 Wood Studs, 16" O.C.

Gypsum Board: 5/8" Thick Gypsum Board (UL Type ULIX™)

UL U305	Fire Rating	System Thickness	STC
Interior Partitions - Wood Stud (Load-Bearing)	1 hours	4 3/4 in.	34


ASSEMBLY DETAILS

Gypsum Board: 5/8" Thick Gypsum Board (UL Type SCX)

Wood Studs: 2x4 Wood Studs, 16" O.C.

Insulation: 3-1/2" Glass Fiber Batt Insulation

Gypsum Board: 5/8" Thick Gypsum Board (UL Type SCX)




MEZZANINE PLAN

SCALE 1/8"=1'-0"

LEGEND
1 HR FIRE PARTITION WALL NFPA 409 UL 305
FIRE EXTINGUISHER

PLUMBING: IPC TABLE 403.1
WATERCLOSETS 1 PER 25 FOR FIRST 50 PROVIDED: 2
LAVATORY 1 PER 40 FIRST 80 PROVIDED: 2
DRINKING FOUNTAIN 1 PER 100 PROVIDED 1
SERVICE SINK 1 PROVIDED 1



Signature
BUILDERS
KC, LLC

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar
at Lees Summit Airport
2751 NE DOUGLAS ST, UNIT V
LEES SUMMIT, MO 64064

SHAW
ASSOCIATES

SHAW HOFSTRA + ASSOCIATES
1800 CENTRAL STREET, SUITE 203
KANSAS CITY, MISSOURI 64108
P: 816.421.0505

ARCHITECTURAL CORPORATION
Certificate of Authority No. 00111130

This document, and all plans, specifications, and other information contained therein, are the exclusive property of SHAW HOFSTRA + ASSOCIATES. These documents are delivered and accepted by you in trust and on the expressed condition that neither these documents or the information contained therein will be copied, reproduced, or delivered to others, except copies stamped "CONFIDENTIAL" NOT FOR CONSTRUCTION. PROPERTY OF SHAW HOFSTRA + ASSOCIATES. No reproducible copies shall be distributed without the express written consent of SHAW HOFSTRA + ASSOCIATES. The design represented by these documents and plans is the exclusive property, design, and concepts of SHAW HOFSTRA + ASSOCIATES and may not be used or copied without the express written consent of SHAW HOFSTRA + ASSOCIATES.

SHAW HOFSTRA + ASSOCIATES
© 2020

CAD Corporation Documents
Voice / Text: 913.628.3241
ngp@shawhofstra.com
Residential AutoCAD Drafting
and Design Services

No.	Description	Date
-----	-------------	------

--	--	--

CONSTRUCTION
DOCUMENTS

Project Number LS V


Date 2020 JUNE 19

Drawn By CCD


Checked By SBKC

COVER

SHEET SIZE: 24" x 36"



MAIN FLOOR PLAN
NORTH SCALE 3/16"=1'-0"



Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891
Website:
www.sb-kc.net

New Airplane Hangar
at Lees Summit Airport
2751 NE DOUGLAS ST., UNIT V
LEES SUMMIT, MO 64064



SHAW HOFSTRA + ASSOCIATES
1800 CENTRAL STREET, SUITE 203
KANSAS CITY, MISSOURI 64108
P: 816.421.0505
ARCHITECTURAL CORPORATION
Certificate of Authority No. 00111130
This document, and all plans, specifications and other information contained therein, are the exclusive property of SHAW HOFSTRA + ASSOCIATES. These documents are delivered and accepted by you in trust and on the expressed condition that neither these documents or the information contained therein will be copied, reproduced, or delivered to others, except copies stamped "CONFIDENTIAL" NOT FOR CONSTRUCTION. PROPERTY OF SHAW HOFSTRA + ASSOCIATES. No reproducible copies shall be distributed without the express written consent of SHAW HOFSTRA + ASSOCIATES. The design represented by these documents and plans is the exclusive property, design, and concepts of SHAW HOFSTRA + ASSOCIATES and may not be used or copied without the express written consent of SHAW HOFSTRA + ASSOCIATES.


SHAW HOFSTRA + ASSOCIATES
© 2020
CAD Corporation Documents
Voice / Text: 913.638.3241
info@sh-ha.com
Residential AutoCAD Drafting
and Design Services

No.	Description	Date

CONSTRUCTION DOCUMENTS


Project Number	LS V
Date	2020 JUNE 19
Drawn By	CCD
Checked By	SBKC

A 101
SHEET SIZE: 24" x 36"




MEZZANINE FLOOR PLAN

SCALE 3/16"=1'-0"



WEST ELEVATION

SCALE 3/16"=1'-0"



EAST ELEVATION

SCALE 3/16"=1'-0"



Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar
at Lees Summit Airport
2751 NE DOUGLAS ST., UNIT V
LEES SUMMIT, MO 64064



SHAW HOFSTRA + ASSOCIATES
1800 CENTRAL STREET, SUITE 203
KANSAS CITY, MISSOURI 64108
P: 816.421.0505

ARCHITECTURAL CORPORATION
Certificate of Authority No. 00111130
This document, and all plans, specifications, and other information contained therein, are the exclusive property of SHAW HOFSTRA + ASSOCIATES. These documents are delivered and accepted by you in trust and on the expressed condition that neither these documents or the information contained therein will be copied, reproduced, or delivered to others, except copies stamped "CONFIDENTIAL - NOT FOR CONSTRUCTION". No reproducible copies shall be distributed without the express written consent of SHAW HOFSTRA + ASSOCIATES. The design, represented by these documents and plans is the exclusive property, design, and concepts of SHAW HOFSTRA + ASSOCIATES and may not be used or copied without the express written consent of SHAW HOFSTRA + ASSOCIATES.

SHAW HOFSTRA + ASSOCIATES
© 2020

CAD Construction Documents
Voice / Text: 913.638.3241
Registration: B-6626461-001
Residential AutoCAD Drafting
and Design Services

No.	Description	Date

CONSTRUCTION DOCUMENTS

Project Number LS V


Date 2020 JUNE 19

Drawn By CCD

Checked By SBKC

A 102

SHEET SIZE: 24" x 36"



Website:
www.sb-kc.net



SH
ASSOCIATES


SHAW HOFSTRA + ASSOCIATE
© 202[illegible]


CONSTRUCTION
DOCUMENTS

Date 2020 JUNE 1


Checked By	SBK
------------	-----

A 103






BLDG SECTION
SCALE 1/4"=1'-0"



BLDG SECTION @ MEZZANINE
SCALE 1/4"=1'-0"



Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar
at Lees Summit Airport
2751 NE DOUGLAS ST, UNIT V
LEES SUMMIT, MO 64064



SH ASSOCIATES
SHAW HOFSTRA + ASSOCIATES
1800 CENTRAL STREET, SUITE 203
KANSAS CITY, MISSOURI 64108
P: 816.421.0505

ARCHITECTURAL CORPORATION
Certificate of Authority No. 00111130
This document, and all plans, specifications, and other information contained therein, are the exclusive property of SHAW HOFSTRA + ASSOCIATES. These documents are delivered and accepted by you in trust and on the expressed condition that neither these documents or the information contained therein will be copied, reproduced, or delivered to others, except copies stamped "CONFIDENTIAL - NOT FOR CONSTRUCTION". No reproducible copies shall be distributed without the express written consent of SHAW HOFSTRA + ASSOCIATES. The design represented by these documents and plans is the exclusive property, design, and concepts of SHAW HOFSTRA + ASSOCIATES and may not be used or copied without the express written consent of SHAW HOFSTRA + ASSOCIATES.

SHAW HOFSTRA + ASSOCIATES
© 2020

CAD Construction Documents
Voice / Text: 913.638.3241
mshaw@sb-kc.net
Residential AutoCAD Drafting
and Design Services

No.	Description	Date

CONSTRUCTION
DOCUMENTS

Project Number	LS V
Date	2020 JUNE 19
Drawn By	CCD
Checked By	SBKC

A 104
SHEET SIZE: 24" x 36"

BI-FOLD DOOR SPEC



PROVIDE AND INSTALL BATHROOM FIXTURES AND ACCESSORIES PER:
 2012 ICC A117.1 - 2009 604.5.1 - FIXED SIDE WALL GRAB BARS. FIXED SIDE WALL GRAB BARS SHALL BE 42 INCHES MINIMUM IN LENGTH LOCATED 12 INCHES MAXIMUM FROM THE REAR WALL AND EXTENDING 54 INCHES MINIMUM FROM THE REAR WALL. IN ADDITION, A VERTICAL GRAB BAR 18 INCHES MINIMUM IN LENGTH GTH SHALL BE MOUNTED WITH THE BOTTOM OF THE BAR LOCATED 39 INCHES MINIMUM AND 41 INCHES MAXIMUM ABOVE THE FLOOR, AND WITH THE CENTER LINE OF THE BAR LOCATED 39 INCHES MINIMUM AND 41 INCHES MAXIMUM FROM THE REAR WALL.
 ALL PLUMBING FIXTURES AND TOILET ACCESSORIES TO BE ADA COMPLIANT, INSTALLED AS INDICATED AND IN COMPLIANCE WITH THE ADA AND PER MANUFACTURER'S GUIDELINES. INSTALL STEEL BACKER PLATES IN WALL ASSEMBLY TO SUPPORT GRAB BARS. COMPLETED ASSEMBLY CAPABLE OF SUPPORTING A MINIMUM VERTICAL OR HORIZONTAL FORCE OF 250 LBS. WITHOUT DAMAGE TO ANY PART OF THE ASSEMBLY.

RESTROOM FIXTURES AND ACCESSORIES LEGEND AND SPECIFICATIONS



SCALE: 1/2"=1'-0"

INTERIOR DOOR
SOLID WOOD CORE
STAINED

PRIVACY LOCK @ BATHROOM

WINDOW SCHEDULE

DOOR SCHEDULE




D


C

B

A


- WOOD:**
- FRAMING MATERIAL:
A. NOMINAL STRUCTURAL LUMBER -- NO. 1 / NO.2 OR BETTER, S-DRY SPF, MIN Fb = 875 PSI, MIN E = 1400 KSI.
B. EXPOSED NOMINAL STRUCT LUMBER -- PRESS TREATED NO.2 OR BETTER, MIN Fb = 1000 PSI, MIN E = 1300 KSI.
C. MICROLAM LVL (LAMINATED VENEER LUMBER) BEAMS SHALL MEET TRUS JOIST SPECIFICATIONS: MINIMUM Fb = 2600 PSI AND MINIMUM E = 1900 KSI.
D. TIMBERSTRAND LSL (LAMINATED STRAND LUMBER) BEAMS SHALL MEET TRUS JOIST SPECIFICATIONS: MINIMUM Fb = 2600 PSI AND MINIMUM E = 1700 KSI.
E. GLULAM FRAMING: 24F-V4 DOUGLAS FIR, ARCHITECTURAL FINISH (COORDINATE WITH ARCH).
 - SUBSTITUTIONS OF SPECIFIED WOOD MEMBERS SHALL NOT BE MADE WITHOUT REVIEW OF THE ARCHITECT/ENGINEER.
 - WOOD SHEATHING:
A. ROOF SHEATHING SHALL BE 15/32" OR 1/2" APA RATED SHEATHING 40/20, EXPOSURE 1, MINIMUM 2 SPAN, FASTEN WITH 10d COMMON NAILS AT 6" CENTERS AT ALL PANEL EDGES AND 12" CENTERS MAXIMUM AT INTERMEDIATE FRAMING MEMBERS (IN THE FIELD). USE PLYCLIPS AT MIDSPAN.
B. WOOD FLOOR DECKING -- 3/4" APA RATED TOUNGE AND GROOVE SHEATHING, 48" SPAN RATING, EXPOSURE 1, MINIMUM 2 SPAN, FASTEN WITH APA APPROVED ADHESIVE AND 10d RING SHANKED NAILS AT 6" ON CENTERS AT ALL PANEL EDGES AND AT 10" ON CENTERS MAXIMUM AT INTERMEDIATE FRAMING MEMBERS (IN THE FIELD).
C. ALL EXTERIOR WOOD WALL SHEATHING EXCEPT WHERE NOTED SHALL BE APA RATED 7/16" SHEATHING. ALL PANEL EDGES SHALL BE BACKED WITH 2 INCH NOMINAL OR WIDER FRAMING. FASTEN WITH 8d COMMON NAILS AT 6" O.C. MAXIMUM AT ALL TOP PLATES, BLOCKING, BOUNDARIES AND 10" O.C. MAXIMUM IN THE FIELD.
 - ALL WOOD SHEATHING TO BE STAGGERED 4'X8' SHEETS. ORIENTED PERPENDICULAR TO SUPPORTING MEMBERS.
 - PROVIDE 1/8" GAP AT ALL SHEATHING PANEL EDGES AND END JOINTS UNLESS OTHERWISE SPECIFIED BY THE MANUFACTURER. DUE TO CONSTRUCTION CONDITIONS, TEMPORARY EXPANSION JOINTS MAY BE REQUIRED IN FLOOR/ROOF SHEATHING.
 - ALL HEADERS IN EXTERIOR OR INTERIOR BEARING WALLS SPANNING MORE THAN 3'-8" SHALL BE SUPPORTED ON DOUBLE STUDS UNLESS NOTED.
 - MINIMUM NAILING SHALL CONFORM TO IRC TABLE R602.3 (1). USE COMMON NAILS EXCEPT WHERE NOTED. ALL FASTENERS (BOLTS, SCREWS, NAILS, ETC) IN CONTACT WITH PRESSURE TREATED LUMBER SHALL BE HOT DIP GALVANIZED.
 - LIGHT GAGE WOOD FRAMING CONNECTORS AS NOTED ON THE PLANS FOR WOOD JOISTS, COLUMNS, BEAMS AND TRUSSES SHALL BE "STRONG - TIE" CONNECTORS BY THE SIMPSON CO. OR REVIEWED EQUIVALENT. CONNECTORS IN DIRECT CONTACT WITH PRESSURE TREATED LUMBER SHALL HAVE "ZMAX" G185 HOT DIP GALVANIZED COATING OR REVIEWED EQUIVALENT.
 - STAINLESS STEEL FASTENERS, ANCHOR BOLTS, LIGHT GAGE CONNECTORS, ETC. MAY BE SUBSTITUTED FOR HOT DIP GALVANIZED MATERIALS AT THE CONTRACTORS OPTION.





Stand
Structural
Engineering Inc

12417 Connell Dr
Overland Park, KS
66213
(913) 224-9115
www.stand-se.com



PROJECT INFORMATION:

AIRPLANE HANGER
2751 NE DOUGLAS RD
LEE'S SUMMIT, MO 64064

REVISIONS		
DATE	Δ	DESCRIPTION
01/28/2020	1	REV 1
CLIENT: BILL BARNARD		
JOB NO. : 19492		
DESIGN BY : Designer		
DRAWN BY : Author		
DATE: 01/28/2020		
SHEET NAME: WOOD FRAMING GENERAL NOTES AND DETAILS		
SHEET #:		

S201

MECHANICAL SPECIFICATIONS

1. GENERAL PROVISIONS:
- A. PROVIDE ALL LABOR, MATERIALS, EQUIPMENT, NECESSARY FOR THE COMPLETE INSTALLATION OF THE PLUMBING AND MECHANICAL SYSTEMS OUTLINED.
- B. OBTAIN ALL PERMITS, FEES, LICENSES, INSPECTIONS, AND CERTIFICATES OF COMPLIANCE OR APPROVAL AS REQUIRED BY THE AUTHORITIES.
- C. ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE LAWS, CODES AND REGULATIONS OF THE GOVERNMENTAL BODIES HAVING JURISDICTION OVER THE SITE.
- D. ALL TESTING REQUIRED BY AUTHORITIES SHALL BE CONSIDERED PART OF THIS WORK.
- E. DURING CONSTRUCTION, ALL FIXTURES, EQUIPMENT, PIPE, DUCT, ETC. SHALL BE COVERED, PLUGGED, OR CAPPED AS REQUIRED. ALL DAMAGED ITEMS SHALL BE RESTORED TO ORIGINAL CONDITION OR REPLACED. ALL PROTECTIVE COVERINGS SHALL BE REMOVED BEFORE FINAL ACCEPTANCE.
- F. PROVIDE ALL NECESSARY CUTTING AND PATCHING OF WALLS, FLOORS, CEILINGS, AND ROOFS AS NECESSARY. PATCH AROUND ALL OPENINGS SHALL MATCH ADJACENT AREA. COORDINATE ALL ROOFING WORK WITH OWNER OR RESPONSIBLE PARTY, SO THAT THE EXISTING ROOFING WARRANTY WILL BE MAINTAINED.
- G. CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS AGAINST DEFECTS FOR A PERIOD OF ONE YEAR FROM FINAL ACCEPTANCE.
2. OPERATION AND MAINTENANCE MANUALS:
- A. DURING THE COURSE OF CONSTRUCTION, COLLECT AND COMPILE OPERATING INSTRUCTIONS, WIRING DIAGRAMS, CATALOG CUTS, LUBRICATION AND PREVENTIVE MAINTENANCE INSTRUCTIONS, PARTS LISTS, ETC. FOR ALL EQUIPMENT FURNISHED UNDER THIS CONTRACT.
- B. ALL LITERATURE AND INSTRUCTIONS SHIPPED WITH THE EQUIPMENT SHALL BE SAVED FOR INCLUSION IN THE OPERATION AND MAINTENANCE MANUALS.
- C. ALL LITERATURE LISTED ABOVE AND ALL PAPERS LISTING WARRANTIES, ETC. SHALL BE BOUND IN A 3-RING BINDER AND LABELED WITH THE PROJECT NAME, ADDRESS, ARCHITECT, ENGINEER, CONTRACTORS, ETC.
3. MANUFACTURERS:
- A. MANUFACTURERS, MODEL NUMBERS, ETC. INDICATED OR SCHEDULED ON THE DRAWINGS SHALL BE INTERPRETED AS HAVING ESTABLISHED A STANDARD OF QUALITY AND SHALL NOT BE CONSTRUED AS LIMITING COMPETITION. ARTICLES, FIXTURES, ETC. OF EQUAL QUALITY BY MANUFACTURERS SHALL BE ACCEPTABLE. SUBJECT TO STRUCTURAL AND ELECTRICAL CONSTRAINTS OF THE PROJECT DESIGN, UNLESS NOTED OTHERWISE.
4. MOTORS:
- A. PROVIDE THERMAL OVERLOAD PROTECTION FOR EACH MOTOR PROVIDED BY THIS WORK.
5. TESTING, BALANCING, AND CLEANING:
- A. ALL PIPING SHALL BE TESTED FOR LEAKS BEFORE BEING CONCEALED IN WALL CONSTRUCTION OR COVERED WITH INSULATION.
- B. SEWER AND VENT PIPING SHALL BE HYDROSTATICALLY TESTED WITH NO LESS THAN 10 FEET OF HEAD FOR A PERIOD OF NOT LESS THAN 15 MINUTES, PER THE LOCAL PLUMBING CODE, WITH NO LEAKS.
- C. DOMESTIC WATER PIPING SHALL BE HYDROSTATICALLY TESTED AT A PRESSURE OF NOT LESS THAN 1-1/2 TIMES THE OPERATING PRESSURE, BUT NOT LESS THAN 60 PSI, FOR A PERIOD OF NOT LESS THAN 2 HOURS, WITH NO LEAKS.
- D. PROPANE GAS PIPING SHALL BE PNEUMATICALLY TESTED AT A PRESSURE OF NOT LESS THAN 1-1/2 TIMES THE OPERATING PRESSURE, BUT NOT LESS THAN 50 PSI, FOR A PERIOD OF NOT LESS THAN 2 HOURS, WITH NO LEAKS.
- E. DUCTWORK AND PIPING SHALL BE BALANCED BY QUALIFIED BALANCING PERSONNEL WHO HAVE PREVIOUS EXPERIENCE WITH BALANCING PROCEDURES.
- F. BEFORE DOMESTIC WATER PIPING IS PLACED IN SERVICE, ALL DOMESTIC WATER DISTRIBUTION SYSTEMS, INCLUDING THOSE FOR COLD WATER AND HOT WATER SYSTEMS, SHALL BE FLUSHED, STERILIZED AND CHLORINATED IN ACCORDANCE WITH HEALTH DEPARTMENT REGULATIONS. THE SYSTEMS SHALL BE THOROUGHLY FLUSHED OF ALL DIRT AND FOREIGN MATTER, THEN FILLED WITH WATER TREATED WITH 50 PPM OF CHLORINE. DURING THE FILLING PROCESS, VALVES AND FAUCETS SHALL BE OPENED SEVERAL TIMES TO ASSURE TREATMENT OF THE ENTIRE SYSTEM. THE TREATED WATER SHALL BE LEFT IN THE SYSTEM FOR 24 HOURS AFTER WHICH TIME THE SYSTEM SHALL BE FLUSHED. IF THE RESIDUAL CHLORINE IS NOT LESS THAN 10 PPM, THE FLUSHING SHALL BE REPEATED. AFTER STERILIZATION, SAMPLES OF WATER IN THE SYSTEM SHALL BE APPROVED BY THE BOARD OF HEALTH.
6. PLUMBING:
- A. PROVIDE AN APPROVED WATER HAMMER ARRESTOR FOR EACH PLUMBING FIXTURE SUPPLY AS REQUIRED BY FIXTURE MANUFACTURER.
- B. ALL EXPOSED WASTE PIPE SHALL BE CHROME PLATED BRASS PIPE, NO FERROUS PIPE.
- C. PROVIDE CLEANOUTS AT EACH CHANGE OF DIRECTION AND AT 100 FOOT INTERVALS IN STRAIGHT RUNS.
- D. PROVIDE ACCESS PANELS FOR ALL CONCEALED VALVES AND TRAPS.
- E. CLEANOUTS:
- 1) VINYL TILE FLOOR: JR SMITH #4140, OR EQUAL.
- 2) QUARRY TILE FLOOR: JR SMITH #4200, OR EQUAL.
- 3) CARPETED FLOOR: JR SMITH #4020-Y, OR EQUAL.
- 4) UNFINISHED FLOOR: JR SMITH #4020, OR EQUAL.
- 5) WALL: JR SMITH #4412, OR EQUAL. 24" ABOVE THE FLOOR.
- 6) GRADE: JR SMITH #4425, OR EQUAL. WITH HEAVY DUTY CAST IRON BODY AND COVER.
- F. PROVIDE DIELECTRIC UNIONS WITH APPROPRIATE END CONNECTIONS TO MATCH THE PIPE SYSTEM IN WHICH INSTALLED (SCREWED, SOLDERED, OR FLANGED). PROVIDE DIELECTRIC UNIONS ON ALL PIPING CONNECTIONS TO HOT WATER HEATERS AND EXPANSION TANKS.
- G. WATER HEATERS:
- 1) BOTTOM FED WATER HEATERS AND TANKS CONNECT TO WATER HEATERS SHALL HAVE A VACUUM RELIEF VALVE INSTALLED, ANSI Z21.22.
- 2) STORAGE HEATERS OPERATING ABOVE ATMOSPHERIC PRESSURE SHALL HAVE AN APPROVED PRESSURE RELIEF VALVE AND/OR TEMPERATURE RELIEF VALVE.
- H. ALL SEWER PIPING LOCATED INSIDE THE BUILDING SHALL BE INSTALLED WITH THE FOLLOWING SLOPES:
- 1) INSTALL 2-1/2" AND SMALLER PIPE AT 1/4" PER FOOT FALL.
- 2) INSTALL 3" AND LARGER PIPE AT 1/8" PER FOOT FALL.
- I. ALL SEWER PIPING LOCATED EXTERIOR TO THE BUILDING SHALL BE INSTALLED WITH THE FOLLOWING SLOPES:
- 1) INSTALL 4" AND SMALLER PIPE AT A MINIMUM OF 2% SLOPE.
- 2) INSTALL 6" AND LARGER PIPE AT A MINIMUM OF 1% SLOPE.
- J. PIPING:
- A. DOMESTIC COLD AND HOT WATER (ABOVEGROUND):
- 1) TYPE L HARD DRAWN COPPER TUBING, ASTM B-88.
- a) WROUGHT COPPER SOLDERED FITTINGS, ASTM B75 ALLOY C12200, ANSI B16.22, MSS SP-104.
- b) MECHANICAL PRESS COPPER FITTINGS FOR USE IN PLUMBING OR MECHANICAL APPLICATIONS, ASME B16.22, ASME B16.51, OR ASME B16.18. MECHANICAL PRESS COPPER FITTINGS SHALL CONFORM TO IAPMO PS-111 OR ASME B16.51.
- 2) PEK HIGH-DENSITY CROSS-LINKED POLYETHYLENE TUBING SHALL BE MANUFACTURED TO THE REQUIREMENTS OF ASTM F876 AND MEET THE STANDARD GRADE HYDROSTATIC PRESSURE RATINGS FROM PLASTIC PIPE INSTITUTE IN ACCORDANCE WITH TR-4-03.
- (MUST BE INSTALLED PER THE MANUFACTURERS REQUIREMENTS FOR PLENUM USE)
- a) PEK-A AND PEK-B MEETING AND EXCEEDING ANSI/ANSI22 STANDARDS FOR POTABLE WATER SAFETY AND LEAD-FREE STANDARDS AND MUST BE MARKED WITH "PEK", "NSF-61-01" OR OTHER NSF-APPROVED MARKING, ASTM F2023 FOR USE WITH CHLORINATED WATER.
- (MUST BE INSTALLED PER THE MANUFACTURERS REQUIREMENTS FOR PLENUM USE)
- b) PEK MECHANICAL EXPANSION FITTINGS INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. PIPE SIZES GIVEN ON THE DRAWINGS ARE NOMINAL COPPER PIPE SIZE. INCREASE PEK PIPING SIZE TO EQUAL OR EXCEED COPPER PIPE INSIDE DIAMETER FOR SUPPLY MAINS. (MUST BE INSTALLED PER THE MANUFACTURERS REQUIREMENTS FOR PLENUM USE)
- 3) VALVES:
- a) TO BE INSTALLED ON THE FIXTURE SUPPLY TO EACH PLUMBING FIXTURE.
- b) TO BE INSTALLED ON THE WATER SUPPLY SIDE TO EACH APPLIANCE OR MECHANICAL EQUIPMENT.
- c) TYPES:
1. GATE VALVE: JOMAR T-5-3016 OR EQUAL, LEAD-FREE NSF 61, ANSI B1.20.1.
2. GLOBE VALVE: JOMAR T-6 OR EQUAL.
3. BALL VALVE: JOMAR JF100PXP OR EQUAL COMPACT LEAD FREE BRASS BALL VALVE. UL42, CSA 3371-12, 14 3371-12, FM, CALIFORNIA CODE AB1493, NSF 61-01, OR OTHER NSF-APPROVED.
4. BALL VALVE: JOMAR T-1-009E OR EQUAL. UL42, FM, CSA, NSF 61-01, MSS SP-110.
- B. DOMESTIC WATER SERVICE
- 1) TYPE K SOFT DRAWN COPPER TUBING, ASTM B-88.
- a) Cast Copper Alloy Fittings for Flared Copper Tube, ASME/ANSI B16.26.
- 2) HDPE, PIGMENTED BLUE THROUGHOUT, CTS SIZES 1"-2" ANNA C401 4710 DR9 PC250 IPS SIZES 2"-3". ANNA C401 4710 DR11 PC200 MATERIAL AND INSTALLATION MUST CONFORM TO WATER DEPARTMENT REQUIREMENTS.
- C. LEAD CONTENT OF WATER SUPPLY PIPE AND FITTINGS:
- 1) PIPE AND PIPE FITTINGS, INCLUDING VALVES AND FAUCETS, UTILIZED IN THE WATER SUPPLY SYSTEM SHALL NOT HAVE MORE THAN 0% LEAD CONTENT.
- 2) PIPE, PIPE FITTINGS, JOINTS, VALVES, FAUCETS, AND FIXTURE FITTINGS UTILIZED TO SUPPLY WATER FOR DRINKING OR COOKING PURPOSES SHALL COMPLY WITH NSF 372 AND SHALL HAVE A WEIGHTED AVERAGE LEAD CONTENT OF 0.25% OR LESS.

MECHANICAL SPECIFICATIONS (CONTINUED)

- D. SANITARY SEWER AND VENTS (UNDERGROUND, INTERIOR TO THE BUILDINGS).
- 1) ABS SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM ABS COMPOUND WITH A CELL CLASS OF 42222 FOR PIPE AND 32222 FOR FITTINGS AS PER ASTM D 3465 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 628 FITTINGS SHALL CONFORM TO ASTM D 2661. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2235.
- 2) PVC SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 11432 PER ASTM D 4396 FOR PIPE AND 12454 PER ASTM D 1104 FOR FITTINGS AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 691. INJECTION MOLDED FITTINGS SHALL CONFORM TO ASTM D 2665. FABRICATED FITTINGS SHALL CONFORM TO ASTM F 1866. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564.
- 3) PVC SCHEDULE 40 SOLID WALL PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 12454 PER ASTM D 1104 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM D 1104 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 691. INJECTION MOLDED FITTINGS SHALL CONFORM TO ASTM D 2665. FABRICATED FITTINGS SHALL CONFORM TO ASTM F 1866. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564.
- 4) HUBLESS CAST IRON SOIL PIPE AND FITTINGS: HUBLESS CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 889 AND CSPI STANDARD 301. HUBLESS COUPLINGS SHALL CONFORM TO CSPI STANDARD 310 AND BE CERTIFIED BY NSF INTERNATIONAL. HUB AND SPIGOT CAST IRON SOIL PIPE AND FITTINGS: HUB AND SPIGOT CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 14.
- E. SANITARY SEWER AND VENTS (ABOVE GROUND, INTERIOR TO THE BUILDINGS).
- 1) ABS SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM ABS COMPOUND WITH A CELL CLASS OF 42222 FOR PIPE AND 32222 FOR FITTINGS AS PER ASTM D 3465 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 628 FITTINGS SHALL CONFORM TO ASTM D 2661. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2235. (NOT FOR USE IN A RETURN AIR PLENUM)
- 2) PVC SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 11432 PER ASTM D 4396 FOR PIPE AND 12454 PER ASTM D 1104 FOR FITTINGS AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 691. INJECTION MOLDED FITTINGS SHALL CONFORM TO ASTM D 2665. FABRICATED FITTINGS SHALL CONFORM TO ASTM F 1866. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564.
- 3) PVC SCHEDULE 40 SOLID WALL PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 12454 PER ASTM D 1104 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM D 1104 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 691. INJECTION MOLDED FITTINGS SHALL CONFORM TO ASTM D 2665. FABRICATED FITTINGS SHALL CONFORM TO ASTM F 1866. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564. (WHERE APPROVED BY LOCAL JURISDICTIONS)
- 4) HUBLESS CAST IRON SOIL PIPE AND FITTINGS: HUBLESS CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 889 AND CSPI STANDARD 301. HUBLESS COUPLINGS SHALL CONFORM TO CSPI STANDARD 310 AND BE CERTIFIED BY NSF INTERNATIONAL. HUB AND SPIGOT CAST IRON SOIL PIPE AND FITTINGS: HUB AND SPIGOT CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 14.
- F. SANITARY SEWER (UNDERGROUND, EXTERIOR TO THE BUILDING).
- 1) ABS SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM ABS COMPOUND WITH A CELL CLASS OF 42222 FOR PIPE AND 32222 FOR FITTINGS AS PER ASTM D 3465 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 2680 FITTINGS SHALL CONFORM TO ASTM D 2680. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2235.
- 2) PVC SCHEDULE 40 CELLULAR CORE (FOAM CORE) PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 11432 PER ASTM D 4396 FOR PIPE AND 12454 PER ASTM D 1104 FOR FITTINGS AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 194. FITTINGS SHALL CONFORM TO ASTM F 194. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564.
- 3) PVC SCHEDULE 40 SOLID WALL PIPE AND DWV FITTING SYSTEM: PIPE AND FITTINGS SHALL BE MANUFACTURED FROM PVC COMPOUND WITH A CELL CLASS OF 12454 PER ASTM D 1104 AND CONFORM WITH NATIONAL SANITATION FOUNDATION (NSF) STANDARD 14. PIPE SHALL BE IRON PIPE SIZE (IPS) CONFORMING TO ASTM F 194. FITTINGS SHALL CONFORM TO ASTM F 194. SOLVENT CEMENTS SHALL CONFORM TO ASTM D 2564.
- 4) HUBLESS CAST IRON SOIL PIPE AND FITTINGS: HUBLESS CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 889 AND CSPI STANDARD 301. HUBLESS COUPLINGS SHALL CONFORM TO CSPI STANDARD 310 AND BE CERTIFIED BY NSF INTERNATIONAL.
- 5) HUB AND SPIGOT CAST IRON SOIL PIPE AND FITTINGS: HUB AND SPIGOT CAST IRON PIPE AND FITTINGS SHALL BE MANUFACTURED FROM GRAY CAST IRON AND SHALL CONFORM TO ASTM A 14.
- 6) COPPER DWV DRAINAGE TUBE SHALL CONFORM TO ASTM B306, WROUGHT COPPER FITTINGS, ANSI B16.29.
- 7) GALVANIZED STEEL PIPE, WITH MALLEABLE IRON, THREADED FITTINGS, DRAINAGE PATTERN FOR SEWERS SHALL CONFORM TO ASTM A 53.
- G. CONDENSATE DRAINS (INDIRECT WASTE (ABOVEGROUND).
- 1) DWV, WROUGHT COPPER, ANSI B-16.29 (CONDENSATE INSIDE BUILDING).
- H. REFRIGERANT.
- 1) ASTM B 280, TYPE ACR, HARD-DRAWN STRAIGHT LENGTHS, AND SOFT-ANNEALED COILS, SEAMLESS COPPER TUBING.
- 2) WROUGHT COPPER, ANSI B16.22, STREAMLINED PATTERN, FITTINGS, BRAZED JOINTS, AYS A 5.8, CLASSIFICATION BAG-1 (SILVER).
- 3) TUBING SHALL BE FACTORY CLEANED, READY FOR INSTALLATION, AND HAVE ENDS CAPPED TO PROTECT CLEANLINESS PRIOR TO SHIPPING.
- 4) SIZE AND INSTALLATION OF PIPE SHALL BE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- I. PROPANE GAS.
- 1) BLACK STEEL PIPE, SCHEDULE 40, ASTM A53.
- a) PIPE 3" AND SMALLER, 150 LB. MALLEABLE IRON, THREADED FITTINGS.
- b) PIPE 4" AND SMALLER: VESGA MESA PRESS 6 FOR WATER AND GAS, CSA LC4, T59A/ASME B31 FOR USE WITH ASTM A53 SCHEDULE 40 BLACK IRON PIPE.
- c) PIPE 2-1/2" AND LARGER, WELDED.
- d) PLUG VALVE: ROCKWELL NORDSTROM FIGURE NO. 142 OR 143.
- e) BALL VALVE: JOMAR T-1-009E, APPROVALS- UL42, FM, CSA, NSF 61-01, MSS SP-110.
- 2) GAS PIPING PAINTING:
- a) ALL BLACK STEEL GAS PIPING LOCATED EXTERIOR TO THE BUILDING SHALL BE PRIMER AND PAINTED TO EITHER MATCH ADJACENT EXTERIOR WHERE LOCATED ON OR NEAR EXTERIOR WALL AND PAINTED SAFETY YELLOW WHERE LOCATED ON THE ROOF.
- J. ALL PIPE HANGERS AND SUPPORTS SHALL BE STANDARD PRODUCTS OF GRINNELL, FEE AND MASON, OR ELCEN. HANGER SPACING SHALL BE IN ACCORDANCE WITH MSS-SP-69.
- K. SLEEVES
- 1) PROVIDE, SET, AND PROPERLY LOCATE PIPE SLEEVES AS REQUIRED FOR THIS WORK. ALL SLEEVES SHALL BE OF SUFFICIENT SIZE TO PERMIT PIPE MOVEMENT DUE TO EXPANSION AND CONTRACTION AND TO ACCOMMODATE PIPE INSULATION.
- 2) INTERIOR PARTITIONS: 16 GAGE GALVANIZED STEEL, PACK BETWEEN PIPE AND SLEEVE WITH FIRE SAFING AND CAULK AT EACH END WITH FIRE RESISTANT SEALANT.
- 3) ROOF: PROSET OR EQUAL, MANUFACTURED PVC SCHEDULE 40 PIPE SLEEVE WITH WATERPROOF SEAL, COORDINATE WITH ROOFING CONTRACTOR AND FLASH AS REQUIRED TO MAINTAIN ROOF WARRANTY.
- 4) PROTECTION AGAINST CONTACT: METALLIC PIPING, EXCEPT FOR CAST IRON, DUCTILE IRON AND GALVANIZED STEEL, SHALL NOT BE PLACED IN DIRECT CONTACT WITH STEEL FRAMING MEMBERS, CONCRETE, OR GINDER WALLS AND FLOORS OR OTHER MASONRY. METALLIC PIPING SHALL NOT BE PLACED IN DIRECT CONTACT WITH CORROSIVE SOIL. SHEATHING USED TO PREVENT DIRECT CONTACT SHALL HAVE A THICKNESS OF GREATER THAN .008" AND THE SHEATHING SHALL BE MADE OF PLASTIC. ANY PIPE THAT PASSES THROUGH A FOUNDATION WALL OR FOOTING SHALL BE PROVIDED WITH A RELIEVING ARCH. OR A PIPE SLEEVE SHALL BE BUILT INTO THE FOUNDATION WALL. THE SLEEVE SHALL BE TWO SIZES GREATER THAN THE PIPE PASSING THOUGH THE WALL OR FOOTING.
- 5) PLUMBING VENTS: FLASH ROOF VENT INTO ROOFING SYSTEM AS REQUIRED BY THE ROOFING CONTRACTOR TO MAINTAIN EXISTING ROOF WARRANTY. ALL PLUMBING VENT TERMINALS SHALL TERMINATE A MINIMUM OF 12" ABOVE ROOF OR EQUAL TO HEIGHT OF PARAPET, WHICHEVER IS GREATER.
- L. PROVIDE CHROME PLATED ESCUTCHEONS ON ALL PIPE ENTERING FINISHED AREAS.


MECHANICAL SPECIFICATIONS (CONTINUED)

9. INSULATION AND DUCT LINING:
- A. ALL INSULATIONS AND ACCESSORIES SHALL HAVE A FIRE HAZARD CLASSIFICATION WITH A FLAME SPREAD RATINGS OF NOT OVER 25, A FUEL CONTRIBUTION RATINGS OF NOT OVER 50, AND A SMOKE DEVELOPED RATINGS OF NOT OVER 50, IN ACCORDANCE WITH NFPA.
- B. PIPE INSULATION - ABOVE GRADE:
- 1) THE PIPING INSULATION USED SHALL HAVE A THERMAL CONDUCTIVITY OF 0.21 Btu per in./hr./sq.ft./°F OR LESS.
- 2) FIBERGLASS INSULATION WITH FACTORY APPLIED VAPOR BARRIER, ASJ JACKET, FACTORY APPLIED PRESSURE SEALING LONGITUDE LAP JOINT, NO STAPLES, ZESTON PREMOULDED PVC FITTING COVERS. INSTALLATION SHALL BE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- 3) FLEXIBLE CLOSED CELL ELASTOMERIC THERMAL INSULATION, UNSLIT OR PRESLIT WITH PRESSURE SENSITIVE ADHESIVE SYSTEM FOR CLOSURE AND VAPOR SEALING, EQUAL TO ARMSTRONGS AP ARMAFLEX OR ARMAFLEX 2000.
- 4) FOR NON CIRCULATING SYSTEMS, THE FIRST 6 FEET OF INLET AND OUTLET PIPING BETWEEN THE TANK AND THE HEAT TRAP (INCLUDING THE HEAT TRAP) MUST BE INSULATED.
- 5) FOR CIRCULATING SYSTEMS, ALL HOT WATER PIPING IN THE CIRCULATION LOOP MUST BE INSULATED AS SPECIFIED BELOW.
- 6) INSULATION SCHEDULE:
- a) DOMESTIC COLD WATER 1/2" 1"
- b) DOMESTIC HOT WATER 1" 2"
- c) REFRIGERANT SUCTION 3/4"
- C. DUCTWORK: ACOUSTICAL INSULATION.
- 1) DUCT LINING: 2 LB/CF, THICKNESS AS SCHEDULED, AIR STREAM SIDE COATED, INSTALL PER SMACNA STANDARDS.
- a) DUCT LINING SCHEDULE:
- (1) RECTANGULAR SUPPLY DUCT 1/2" : THROUGHOUT THE FIRST 10 FEET OF DUCT.
- (2) RETURN AIR DUCT 1/2" : THROUGHOUT THE FIRST 10 FEET OF DUCT.
- D. DUCTWORK: THERMAL INSULATION.
- 1) DUCT COVERINGS: 3/4 LB/CF, FIBERGLASS BLANKET WITH FACTORY APPLIED VAPOR BARRIER AND FACINGS, THICKNESS AS SCHEDULED, INSTALLATION IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS.
- a) DUCT COVERING SCHEDULE: MINIMUM R-6
- (1) ROUND SUPPLY DUCT 2"
- (2) RECTANGULAR SUPPLY DUCT 2"
- (3) OUTDOOR AIR / MAKE-UP AIR DUCT 2"
10. DUCTWORK:
- A. ALL DUCTWORK, UNLESS OTHERWISE INDICATED, SHALL BE FABRICATED FROM GALVANIZED SHEET STEEL, COMPLYING WITH ASTM A 527, LOCKFORMING QUALITY, WITH 6 0Z ZINC COATING IN ACCORDANCE WITH ASTM A 525; AND MILL PHOSPHATIZED FOR EXPOSED LOCATIONS.
- B. DUCTWORK: METAL GAUGES, REINFORCING, ETC. SHALL BE CONSTRUCTED IN ACCORDANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS", LATEST EDITION FOR A 2 INCH WATER GAUGE STATIC PRESSURE.
- C. ALL FITTINGS SHALL BE CONSTRUCTED IN ACCORDANCE WITH SMACNA "HVAC DUCT CONSTRUCTION STANDARDS", LATEST EDITION.
- D. SEAL ALL CONCEALED DUCTWORK JOINTS WITH NON-HARDENING, NON-MISRATING MASTIC SEALANT, AS RECOMMENDED FOR SEALING SEAMS AND JOINTS IN DUCTWORK. OIL BASE CAULKING AND GLAZING COMPOUNDS SHALL NOT BE ACCEPTABLE. DUCTS SHALL BE SEALED TO THE GLASS LEVEL LISTED BELOW.
- | | CLASS B | CLASS A | CLASS C | CLASS B |
|--------------------------------|-----------------|-----------------|---------|---------|
| 1) UNCONDITIONED SPACES | CLASS B | CLASS B | CLASS B | CLASS B |
| 1) CONDITIONED SPACES (PLENUM) | CLASS C | CLASS B | CLASS B | CLASS C |
| | SUPPLY > 2" /C. | SUPPLY > 2" /C. | EXHAUST | RETURN |
- E. DUCT SIZES SHOWN ON THE DRAWINGS ARE SHEETMETAL SIZES, ALLOWANCE FOR DUCT LINER HAS BEEN MADE WHERE APPLICABLE.
11. FLEXIBLE DUCT:
- A. ATCO 1006 (R-6), OR EQUAL.
- B. FACTORY APPLIED INSULATION AND VAPOR BARRIER, 1-1/2" THICK.
- C. MAXIMUM LENGTH OF 5'-0".
12. FLUES AND ACCESSORIES:
- A. FLUES SHALL BE DOUBLE WALL TYPE B EQUAL TO METABESTOS. PROVIDE MANUFACTURER'S STANDARD FITTINGS AND ACCESSORIES (ROOF THIMBLE, STORM COLLAR, COUNTERFLASHING, ETC.) AS REQUIRED FOR A COMPLETE INSTALLATION.
13. EXHAUST FANS:
- A. CENTRIFUGAL CEILING EXHAUSTERS SHALL BE ELECTRICALLY POWERED CENTRIFUGAL TYPE FAN SUITABLE FOR MOUNTING IN THE CEILING WITH A PERFORATED OFF-WHITE METAL GRILLE WITH A THUMBSCREW ATTACHMENT FOR EASY ACCESS TO FAN HOUSING. UNIT SHALL CONSIST OF A GALVANIZED STEEL HOUSING LINED WITH ACOUSTICAL INSULATION AND SHALL INCLUDE AN INTEGRAL BACKDRAFT DAMPER ON FAN DISCHARGE. MOTOR SHALL BE A PERMANENT SPLIT-CAPACITOR TYPE MOTOR, PERMANENTLY LUBRICATED, WITH THERMAL OVERLOAD PROTECTION. PROVIDE DISCONNECT SWITCH OR OTHER MEANS OF DISCONNECT AT MOTOR IN FAN HOUSING.
- B. PROPELLER WALL EXHAUSTERS SHALL BE ELECTRICALLY POWERED PROPELLER TYPE FAN SUITABLE FOR MOUNTING IN THE WALL WITH A METAL GRILLE WITH A THUMBSCREW ATTACHMENT FOR EASY ACCESS TO FAN HOUSING. UNIT SHALL CONSIST OF A GALVANIZED STEEL HOUSING LINED WITH ACOUSTICAL INSULATION AND SHALL INCLUDE AN INTEGRAL BACKDRAFT DAMPER ON FAN DISCHARGE. MOTOR SHALL BE A PERMANENT SPLIT-CAPACITOR TYPE MOTOR, PERMANENTLY LUBRICATED, WITH THERMAL OVERLOAD PROTECTION. PROVIDE BALL SLEEVE, WEATHER HOOD, OSHA SCREEN, AND DISCONNECT SWITCH OR OTHER MEANS OF DISCONNECT AT MOTOR IN FAN HOUSING.
14. AIR HANDLING UNIT AND HEAT PUMP CONDENSING UNIT:
- A. AIR HANDLING UNIT SHALL BE FACTORY ASSEMBLED, PRE-WIRED UNIT CONSISTING OF SHEETMETAL CASING, FILTER, SUPPLY FAN, ELECTRIC RESISTANCE HEATER, AND CONTROLS. CAPACITY SHALL BE AS SCHEDULED.
- 1) THE UNIT SHALL BE EQUIPPED WITH THE MANUFACTURER'S STANDARD CONTROLS INCLUDING 24 VOLT CONTROL TRANSFORMER, HIGH TEMPERATURE LIMIT SWITCH, AND FAN TIMED DELAY RELAY.
- 2) RETURN AIR INLET ON UNIT SHALL BE PROVIDED WITH A 1" THROWAWAY TYPE FILTER AND SLIDE IN FRAME, MOUNTED ON THE UNIT.
- 3) FAN SHALL BE A DIRECT DRIVE MULTI-SPEED BLOWER, RESILIENTLY MOUNTED IN THE CASING. MOTOR SHALL BE PROVIDED WITH AUTOMATIC THERMAL OVERLOAD PROTECTION.
- 4) REFRIGERANT COIL: ALUMINUM FINS BONDED TO SEAMLESS COPPER TUBE BY MEANS OF MECHANICAL EXPANSION, AN EQUALIZING TYPE VERTICAL DISTRIBUTOR SHALL ENSURE EACH COIL CIRCUIT RECEIVES THE SAME AMOUNT OF REFRIGERANT.
- 5) ELECTRIC HEAT: ELECTRIC HEATER SHALL BE INSTALLED INTERNAL TO THE AIR HANDLING UNIT. HEATING ELEMENTS SHALL BE CONSTRUCTED OF HEAVY DUTY NICKEL CHROMIUM, EACH HEATER SHALL HAVE AUTOMATICALLY RESET HIGH LIMIT CONTROL OPERATING THROUGH HEATING ELEMENT CONTACTORS. EACH HEATER SHALL BE INDIVIDUALLY FUSED AND SHALL COMPLY WITH ALL NEC REQUIREMENTS. HEATERS SHALL BE UL LISTED.
- B. HEAT PUMP CONDENSING UNIT SHALL BE FACTORY-ASSEMBLED AND TESTED AIR-COOLED CONDENSING UNIT, CONDENSING COIL, CONDENSER COIL, FAN, MOTOR, REVERSING VALVE, SOLID-STATE DEFROST CONTROL UTILIZING THERMISTERS, REFRIGERANT RESERVOIR, OPERATING CONTROLS, ETC. CAPACITY AND ELECTRICAL CHARACTERISTICS SHALL BE AS SCHEDULED.
- 1) HERMETICALLY SEALED COMPRESSOR WITH BUILT-IN OVERLOADS AND VIBRATION ISOLATION. COMPRESSOR MOTOR, SHALL HAVE THERMAL AND CURRENT SENSITIVE OVERLOAD DEVICES, INTERNAL HIGH-PRESSURE PROTECTION, HIGH AND LOW PRESSURE CUTOFF SWITCHES, START CAPACITOR AND RELAY, OVERCURE CRANKCASE HEATER, AND TEMPERATURE ACTUATED SWITCH AND TIMER TO PREVENT COMPRESSOR RAPID CYCLE.
- 2) COIL SHALL BE COPPER TUBING WITH ALUMINUM FINS, COMPLETE WITH LIQUID ACCUMULATOR AND LIQUID SUBCOOLER. EXTEND REFRIGERANT PIPING WITH BRASS SERVICE VALVES, FITTINGS, AND GAGE PORTS TO EXTERIOR OF CASING.
- 3) ALUMINUM PROPELLER FAN SHALL BE DIRECT DRIVEN, WITH PERMANENTLY LUBRICATED FAN MOTOR HAVING THERMAL OVERLOAD PROTECTION.
- 4) PROVIDE REVERSING VALVE, SUCTION LINE ACCUMULATOR, DISCHARGE MUFFLER, FLOW CONTROL CHECK VALVE, AND SOLID-STATE DEFROST CONTROL UTILIZING THERMISTERS.

MECHANICAL SPECIFICATIONS (CONTINUED)

15. UNIT HEATERS:
- A. UNIT HEATERS SHALL BE FACTORY ASSEMBLED, PRE-WIRED UNITS CONSISTING OF CASING, SUPPLY FAN, GAS FIRED HEAT EXCHANGER, AND CONTROLS.
- B. MOTOR SHALL BE TOTALLY ENCLOSED, WITH BUILT-IN, AUTOMATIC THERMAL OVERLOAD PROTECTION. PROPELLER SHALL BE EQUIPPED WITH SAFETY FAN GUARD.
- C. THE HEAT EXCHANGER SHALL BE ALUMINIZED STEEL CONSTRUCTION.
- D. THE UNITS SHALL BE EQUIPPED WITH THE MANUFACTURER'S STANDARD CONTROLS INCLUDING 24 VOLT CONTROL TRANSFORMER, AUTOMATIC SPARK IGNITION, AUTOMATIC GAS VALVE WITH GAS TRAIN, SAFETY PILOT WITH 100% SHUTOFF, AND FAN TIMED DELAY RELAY.
- E. UNIT HEATERS SHALL BE ASA APPROVED.
16. CONTROL WIRING:
- A. ELECTRICAL WIRING AND WIRING CONNECTIONS REQUIRED FOR THE INSTALLATION OF THE TEMPERATURE CONTROL SYSTEM, SHALL BE PROVIDED BY THIS CONTRACTOR, UNLESS SPECIFICALLY SHOWN ON THE ELECTRICAL DRAWINGS OR SPECIFICATIONS.
- B. INSTALL CONTROL WIRING, WITHOUT SPLICES BETWEEN TERMINAL POINTS, COLOR CODED. INSTALL IN NEAT WORKMANLIKE MANNER, SECURELY FASTENED. INSTALL IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE AND THE ELECTRICAL SPECIFICATIONS.
- 1) INSTALL CIRCUITS OVER 25 VOLT WITH COLOR CODED NUMBER 12 WIRE.
- 2) INSTALL CIRCUITS UNDER 25 VOLT WITH COLOR CODED NUMBER 18 WIRE WITH 0.031 INCH HIGH TEMPERATURE 105 DEGREES F PLASTIC INSULATION ON EACH CONDUCTOR AND PLASTIC SHEATH OVER ALL.
- 3) INSTALL ELECTRONIC CIRCUITS WITH COLOR CODED NUMBER 22 WIRE WITH 0.028 INCH POLYETHYLENE INSULATION ON EACH CONDUCTOR WITH PLASTIC JACKETED COPPER SHIELD OVER ALL.
- 4) INSTALL LOW VOLTAGE CIRCUITS, LOCATED IN CONCRETE SLABS AND MASONRY WALLS, OR EXPOSED IN OCCUPIED AREAS, IN ELECTRIC CONDUIT.
- 5) ALL WIRING IN AREAS USED AS AIR PLENUMS SHALL BE IN ELECTRIC CONDUIT EXCEPT THAT LOW VOLTAGE WIRING MAY BE TEFLON COATED, ALUMINUM SHEATHED CABLE OR OTHER WIRE SPECIFICALLY APPROVED FOR INSTALLATION IN AIR PLENUMS, WHERE ACCEPTABLE BY LOCAL CODES.
- 6) ALL WIRING IN AREAS NOT USED FOR AIR MOVEMENT SHALL BE IN ELECTRIC METALLIC TUBING EXCEPT LOW VOLTAGE WIRING MAY BE IN APPROVED SIGNAL CABLE WHERE ACCEPTED BY LOCAL CODES.
- C. THERMOSTATIC CONTROLS TO HAVE A 5°F DEADBAND AND SETPOINT OVERLAP RESTRICTIONS.
- 1) TEMPERATURE CONTROLS SETBACK TO BE 55°F (HEAT) AND 85° (COOL), 2-HOUR OCCUPANT OVERRIDE, 10-HOUR BACKUP.

6/18/2020



Signature
BUILDERS
KC, LLC

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0801

Website:
www.sb-kc.net

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net

Residential AutoCAD Drafting
and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION DOCUMENTS

Project Number 2019.03

Date 2020 MAY 14

Drawn By SP/BH

Checked By EK/DS


BC PROJECT #: 20388
MISSOURI PE COA #2009003629

This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer/Engineer and is intended for use on this project only. Pursuant to the Architecture/Engine Copyright Protection Act of 1986, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of spaces and elements appearing hereon, are the property of the Designer/Engineer. No part of this drawing may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS
INCORPORATED

MP-000

Scale 3/16" = 1'-0"



UPPER FLOOR PLUMBING PLAN

SCALE: 3/16" = 1'-0"

PLUMBING PLAN NOTES:

- EXTEND AND CONNECT 4" WASTE TO SEPTIC TANK AND FIELD AS REQUIRED. COORDINATE WITH GC FOR EXACT LOCATION.
- EXTEND AND CONNECT 3/4" CW TO EXISTING WATER MAIN AS REQUIRED. VERIFY EXACT LOCATION PRIOR TO INSTALLATION OF ANY PIPING. MAINTAIN MINIMUM 48" COVER
- COORDINATE PROPANE GAS REGULATOR FOR TOTAL CAPACITY OF 400 MBTUH (160 CFH) AT 11" W.C.
- COORDINATE LOCATION AND SIZE OF PROPANE TANK WITH CIVIL/OWNER/ARCH. CODE DICTATES THAT LARGEST ALLOWABLE SIZE OF TANK IS TO BE 2,000 GALLONS WITH A 25' CLEARANCE FROM "ALL BUILDINGS, PUBLIC WAYS, OR LOT LINES OF ADJOINING PROPERTY THAT CAN BE BUILT UPON". IF THE TANK SIZE IS REDUCED TO 1,200 GALLONS, THAT CLEARANCE REQUIREMENT DROPS TO 10'.
- LOCATION OF 3" VTR. VERIFY 10' CLEARANCE FROM ALL OUTDOOR AIR INTAKES. SEAL PENETRATION WEATHERTIGHT.



MAIN FLOOR PLUMBING PLAN

SCALE: 3/16" = 1'-0"

FFE=100.0'

PLUMBING PLAN NOTES: (CONT.)

- ROUTE 3/4" CW UP FROM BELOW FLOOR AND CONNECT TO RPZ AS REQUIRED. ROUTE DRAIN FROM RPZ TO FLOOR DRAIN AND DISCHARGE WITH AIR GAP AS REQUIRED.
- SECURE (2) TANKLESS WATER HEATERS ON WALL ABOVE MOP BASIN AS PER MANUFACTURER RECOMMENDATIONS. CONNECT CW AND HW PIPING AS REQUIRED BY MANUFACTURER. REFER TO RISER DIAGRAM FOR ADDITIONAL INFORMATION.
- CONNECT GAS TO EQUIPMENT AS REQUIRED AND AS DETAILED.
- ROUTE CONDENSATE FROM AIR HANDLER TO FLOOR DRAIN AND DISCHARGE WITH AIR GAP AS REQUIRED.
- ROUTE 2" WASTE DOWN. SEE MAIN FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- ROUTE 3" WASTE DOWN. SEE MAIN FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- 2" VENT UP FROM MAIN FLOOR, SEE MAIN FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.

PLUMBING PLAN NOTES: (CONT.)

- ROUTE 3/4" CW UP FROM MAIN FLOOR, SEE MAIN FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- ROUTE 1/2" HW UP FROM MAIN FLOOR, SEE MAIN FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- ROUTE 1/2" CW, 1/2" HW, 1-1/2" WASTE AND 1-1/2" VENT IN WALL TO BELOW CASEWORK, EXTEND AND CONNECT TO SINK AS REQUIRED.
- ROUTE PIPING IN WALL. ALL CONCEALED JOINTS TO BE WELDED, OR APPROVED FOR CONCEALED INSTALLATION.
- 2" WASTE FROM FLOOR ABOVE, SEE UPPER FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- 3" WASTE FROM ABOVE, PROVIDE CLEANOUT AT BASE OF RISER. SEE UPPER FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- ROUTE 2" VENT UP TO FLOOR ABOVE, SEE UPPER FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.

PLUMBING PLAN NOTES: (CONT.)

- ROUTE 3/4" CW UP TO UPPER FLOOR, SEE UPPER FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.
- ROUTE 1/2" HW UP TO UPPER FLOOR, SEE UPPER FLOOR PLUMBING PLAN FOR ADDITIONAL INFORMATION.

BC PROJECT #: 20388
MISSOURI PE COA #2009003629

This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer/Engineer and is intended for use on the project only. Pursuant to the Architectural Notice Copyright Protection Act of 1980, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of space and elements appearing herein, constitute the original, copyrighted work of the Designer/Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS
INCORPORATED

5720 Reeder Shawnee, Ks, 66203 (913)262-1772



Signature
BUILDERS
— KC, LLC —

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net

Residential AutoCAD Drafting
and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION DOCUMENTS

Project Number 2019.03

Date 2020 MAY 14

Drawn By SP/BH

Checked By EK/DS

P-101

Scale 3/16" = 1'-0"

PLUMBING GENERAL NOTES:



1. INSTALL ALL PIPE, ETC. AS HIGH AS POSSIBLE.
2. COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS AS REQUIRED TO PROPERLY INSTALL ALL SYSTEMS AS INTENDED, WITHIN THE CONFINES OF THE SPACES AVAILABLE, AND WITHOUT INTERFERENCES.
3. REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATIONS AND MOUNTING HEIGHTS OF FIXTURES.
4. REFER TO ARCHITECTURAL & STRUCTURAL DRAWINGS FOR REQUIREMENTS FOR SUPPORTING PIPING, EQUIPMENT, ETC. FROM THE STRUCTURE. PROVIDE ADDITIONAL STEEL AS REQUIRED TO PROPERLY SUPPORT SYSTEMS FROM THE STRUCTURE.
5. NO PIPING SHALL BE ROUTED OVER THE TOP OF ELECTRICAL PANELS.
6. CONTRACTOR TO TEST WATER PRESSURE ON SITE AND PROVIDE PRESSURE REDUCING VALVE ON WATER SERVICE IF PRESSURE IS OVER 80 PSI.

PEX PIPING REQUIREMENTS

PIPE SIZES GIVEN ON THE DRAWINGS ARE NOMINAL COPPER PIPE SIZE. IF PEX PIPING IS USED, INCREASE PEX PIPING ONE SIZE ABOVE LISTED SIZES AS REQUIRED TO EQUAL OR EXCEED COPPER PIPE INSIDE DIAMETER.

PLUMBING SYMBOLS

	SOIL AND WASTE PIPING BELOW FLOOR/GRADE
	SOIL AND WASTE PIPING ABOVE FLOOR/GRADE
	SANITARY VENT PIPING ABOVE GRADE
	SANITARY VENT PIPING BELOW GRADE
	DOMESTIC COLD WATER PIPING
	DOMESTIC HOT WATER PIPING
	DOMESTIC HOT WATER RECIRCULATION PIPING
	PROPANE GAS PIPING
	EQUIPMENT DRAIN LINE
	PIPING TURNING DOWN
	PIPING TURNING UP
	TEE TOP CONNECTION
	UNION
	BACKFLOW PREVENTER
	FLOOR DRAIN
	FLOOR CLEAN OUT
	WALL CLEAN OUT
	GRADE CLEAN OUT
	VALVE
	BALANCING VALVE
	SOLENOID VALVE
	PRESSURE REGULATOR
	CHECK VALVE
	CONNECT TO EXISTING
	INVERT ELEVATION OF PIPE
	MATCH MARKS ON PLUMBING RISER DIAGRAM




WASTE & VENT

PLUMBING RISER DIAGRAMS

SCALE: NONE


PLUMBING FIXTURE SCHEDULE: (OR EQUAL)

HWC	HANDICAP WATER CLOSET: AMERICAN STANDARD, 1.6 GALLON FLUSH, 16-1/2" HIGH ELONGATED BOWL, FLOOR MOUNTED, FLOOR OUTLET, TANK TYPE, VITREOUS CHINA, SIPHON-JET ACTION, OPEN FRONT SEAT WITH CHECK HINGE AND LESS COVER, CHROME PLATED ANGLE STOP AND RISER, HANDLE ON WIDE SIDE OF FIXTURE.
L1	HANDICAP LAVATORY, WALL HUNG: AMERICAN STANDARD, 20"X 18", VITREOUS CHINA, FRONT OVERFLOW, FAUCET WITH SINGLE METAL LEVER HANDLE, 0.5 GPM AERATOR, OFFSET GRID ELBOW DRAIN AND 1-1/4" TAILPIECE, CHROME PLATED CAST BRASS P-TRAP WITH CLEANOUT (MOUNTED PARALLEL WITH WALL), CHROME PLATED ANGLE STOPS AND RISERS, INSULATE EXPOSED DRAIN, WATER SUPPLIES, AND VALVES WITH PROWRAP SEAMLESS MOLDED CLOSED CELL VINYL INSULATION.
S1	SINK:ELKAY, #LRAD-2222, 19"X18"x 6-1/2" DEEP BOWL,21-3/8"x 21-3/8" CUT-OUT, ADA COMPLIANT, SINGLE COMPARTMENT, SELF-RIMMING STAINLESS STEEL SINK WITH SATIN FINISH AND SOUND DAMPENING UNDERCOATING, #LK-1000CR FAUCET, SINK SPOUT, 1.0 GPM AERATOR, SINGLE LEVER HANDLE, CHROME PLATED CAST BRASS P-TRAP WITH CLEANOUT, CHROME PLATED ANGLE STOPS AND RISERS, IN-SINK-ERATOR #BADGER 5 DISPOSAL, 1/2 HP, 120 VOLT.
MB	MOP BASIN: FIAT, #MSB-2424, MOLDED STONE MOP BASIN, 2" DRAIN, 24"x 24" BASIN, VINYL BUMPER GUARD, STERN WILLIAMS #T-10-YB FAUCET, SPRING CHECKS, VACUUM BREAKER, INTEGRAL STOPS, WALL BRACE & PAIL HOOK, WALL BRACKET WITH 30" HOSE.
HB	HOSE BIBB: WOODFORD, #24, 3/4" HOSE NOZZLE OUTLET, BRASS FINISH, HANDWHEEL OPERATED, INTEGRAL VACUUM BREAKER.
FD	FLOOR DRAIN: JR SMITH, #2005-A, CAST IRON FLOOR DRAIN WITH ADJUSTABLE TOP, 6" NIKALLOY STRAINER. PROVIDE WITH #2692 QUAD CLOSE TRAP SEAL DEVICE.
EWH1	ELECTRIC TANKLESS HOT WATER HEATER: EEMAX #HA018240, 240 VOLT, 18.0 KW.
EWH2	ELECTRIC TANKLESS HOT WATER HEATER: EEMAX #HA018240, 240 VOLT, 18.0 KW.
MV	MIXING VALVE: WATTS, #LFUS6-B, THERMOSTATIC CONTROLLED MIXING VALVE, LEAD FREE BRONZE BODY, LOCKED TEMPERATURE ADJUSTMENT CAP (VANDAL RESISTANT), COPPER ENCAPSULATED THERMOSTAT ASSEMBLY WITH BRASS SHUTTLE, STAINLESSSTEEL SPRINGS, INTEGRAL CHECK VALVES ON HOT AND COLD INLETS. (SET TO 110°F). ASSE 1010 LISTED.
RPZ	REDUCED ZONE PRESSURE BACKFLOW PREVENTOR: WATTS #LF009, LEAD FREE BRONZE BODY CONSTRUCTION, TWO, IN-LINE INDEPENDENT CHECK VALVES, REPLACEABLE CHECK SEATS WITH AN INTERMEDIATE RELIEF VALVE, AND BALL VALVE TEST COCKS.
FCO/MCO	VINYL TILE FLOOR: JR SMITH #4140, OR EQUAL. QUARRY TILE FLOOR: JR SMITH #4200, OR EQUAL. CARPETED FLOOR: JR SMITH #4020-Y, OR EQUAL. UNFINISHED FLOOR: JR SMITH #4020, OR EQUAL. WALL: JR SMITH #4412, OR EQUAL, 24" ABOVE THE FLOOR.



CONDENSATE DRAIN DETAIL

SCALE: NONE



GAS CONNECTION DETAIL

SCALE: NONE

PLUMBING FIXTURE BRANCH PIPING SCHEDULE				
FIXTURE	WASTE	VENT	CN	HN
WATER CLOSET (TANK TYPE)	3"	2"	1/2"	--
LAVATORY	1-1/4"	1-1/4"	1/2"	1/2"
SINK	1-1/2"	1-1/2"	1/2"	1/2"
FLOOR DRAIN	2"	2"	--	--
MOP BASIN	2"	2"	1/2"	1/2"

NOTE: INDIVIDUAL VENTS FOR FIXTURES ON PLANS AND RISER DIAGRAMS HAVE BEEN INCREASED WHERE HORIZONTAL VENT LENGTH IS IN EXCESS OF THE MAXIMUM DISTANCE INDICATED BY THE CODE.

6/18/2020



Signature
BUILDERS
KC, LLC

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net

Residential AutoCAD Drafting
and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION DOCUMENTS

Project Number	2019.03
Date	2020 MAY 14
Drawn By	SP/BH
Checked By	EK/DS

P-201

Scale 3/16" = 1'-0"

BC PROJECT #: 20388
MISSOURI PE COA #2009003629

This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer/Engineer and is intended for use on the project only. Pursuant to the Architecture/Engineering/Copyright/Protection Act of 1986, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of space and elements appearing herein, constitute the original, copyrighted work of the Designer/Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS
INCORPORATED

5720 Reeder Shawnee, Ks, 66203 (913)262-1772

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net

Residential AutoCAD Drafting
and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION DOCUMENTS

Project Number	2019.03
Date	2020 MAY 14
Drawn By	SP/BH
Checked By	EK/DS

M-101


Scale 3/16" = 1'-0"

BC PROJECT #: 20388
MISSOURI PE COA #2009003629

This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer/Engineer and is intended for use on the project only. Pursuant to the Architecture/Engineering Copyright Protection Act of 1980, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of spaces and elements appearing herein, constitute the original, copyrighted work of the Designer/Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS
INCORPORATED


5720 Reeder Shawnee, Ka. 66203 (913)262-1772



UPPER FLOOR MECHANICAL PLAN
SCALE: 3/16" = 1'-0"

MECHANICAL PLAN NOTES:

- SUPPORT UNIT FROM STRUCTURE AS REQUIRED. ROUTE 6" Ø TYPE 'B' DOUBLE WALL FLEX UP THROUGH ROOF. PROVIDE ROOF THIMBLE, FLASHING, COUNTER FLASHING & WEATHERHEAD. LOCATE WEATHERHEAD 36" ABOVE EVERYTHING WITHIN 10'. VERIFY 10'-0" FROM ALL OUTDOOR AIR INTAKES. SEAL PENETRATION WEATHERTIGHT.
- HIGH/LOW RETURN AIR GRILLES - OFFICE SIDE GRILLE LOCATED AT 12" AFF. CENTRAL AREA SIDE LOCATED AT 8" AFF. TG-1, SEE DIFFUSER SCHEDULE.
- PROVIDE WALL VENT CAP WITH BACKDRAFT DAMPER FOR EXHAUST FAN. SEAL PENETRATIONS WEATHERTIGHT.
- REFRIGERANT PIPING THROUGH EXTERIOR WALL AT 18" ABOVE GRADE. SEAL WALL PENETRATION WEATHERTIGHT. ROUTE PIPE UP INSIDE WALL TO AS HIGH AS POSSIBLE AND ROUTE TO UNITS.
- CONNECT REFRIGERANT PIPING TO CONDENSING UNIT & COIL AS REQUIRED BY THE MANUFACTURER. PROVIDE AND INSTALL REFRIGERANT PIPING FOR CONDENSING UNIT AS REQUIRED BY MANUFACTURER.



MAIN FLOOR MECHANICAL PLAN
SCALE: 3/16" = 1'-0"

MECHANICAL PLAN NOTES:

- PROVIDE PREFABRICATED PAD FOR CONDENSING UNITS. NO SCREENING ALLOWED AROUND CONDENSING UNITS PER FAA REGULATIONS.
- SUPPORT FAN FROM STRUCTURE AS REQUIRED BY THE MANUFACTURER.
- PROVIDE WALL VENT CAP FOR OUTDOOR INTAKE WITH BIRD SCREEN. SEAL PENETRATIONS WEATHERTIGHT.
- CONNECT 10" Ø OUTDOOR AIR DUCT WITH BALANCING DAMPER AND FLEX DUCT TO RETURN AIR DUCT. REFER TO OUTDOOR AIR CALCULATIONS FOR MINIMUM OUTDOOR AIR VOLUME.
- PROVIDE WATERPROOF GALVANIZED SHEET METAL DRAIN PAN UNDER AIR HANDLER WITH CONDENSATE FLOAT SWITCH TO RE-ENERGIZE UNIT IF DRAIN PAN FILLS WITH WATER.
- INSTALL TRANSFER AIR GRILLES, TG-1, ABOVE DOOR ON BOTH SIDES OF WALL.

[illegible]

- NOTES:
1. PROVIDE TIME DELAY ON COMPRESSOR RE-START, CRANKCASE HEATER, AND COMPRESSOR LOCK-OUT WITH AMBIENT BELOW 35 °F. PROVIDE INDOOR COIL WITH THERMAL EXPANSION VALVE (TXV).
 2. MECHANICAL CONTRACTOR SHALL COORDINATE ALL UNIT MOP'S OF ACTUAL INSTALLED EQUIPMENT WITH ELECTRICAL CONTRACTOR.
 3. PROVIDE CONCRETE OR PRE-MANUFACTURED POLYOLEFIN PAD FOR EACH UNIT. SCREENING OF UNIT NOT ALLOWED PER FAA REQUIREMENTS
 4. PROVIDE HAIL GUARDS FOR EACH UNIT.

[illegible]

- NOTES:**
1. PROVIDE 1" THICK THROWAWAY TYPE FILTER FOR EACH UNIT.
 2. PROVIDE EACH UNIT WITH 7-DAY PROGRAMMABLE HEAT/COOL/AUTO CHANGEOVER THERMOSTAT.
 3. CONDENSING UNITS, AND AIR HANDLING UNITS SHALL ALL BE OF THE SAME MANUFACTURER.
 4. MECHANICAL CONTRACTOR SHALL COORDINATE ALL UNIT MOCPS OF ACTUAL INSTALLED EQUIPMENT WITH ELECTRICAL CONTRACTOR.
 5. EXTERNAL STATIC PRESSURE LISTED REPRESENTS STATIC PRESSURE REQUIRED FOR DUCTWORK AND DIFFUSERS OUTSIDE THE HVAC UNIT COMPLETELY INDEPENDENT OF ANY PRESSURE DROP THROUGH THE HVAC EQUIPMENT INCLUDING BUT NOT LIMITED TO FILTERS AND COILS.
 6. PROVIDE GALVANIZED WATERTIGHT DRAIN PAN AND CONDENSATE FLOAT SWITCH TO DE-ENERGIZE THE AHU IF THE DRAIN PAN FILLS WITH WATER.
 7. PROVIDE MANUFACTURER'S UNIT STAND FOR SIDE RETURN.
 8. PROVIDE SINGLE-POINT POWER CONNECTION.

[illegible]

- NOTES:
1. PROVIDE EACH UNIT ELECTRONIC DIRECT SPARK IGNITION & ALUMINIZED STEEL HEAT EXCHANGER.
 2. PROVIDE EACH UNIT WITH UNIT MOUNTED THERMOSTAT & CONTROL VOLTAGE TRANSFORMER.
 3. PROVIDE WITH PROPANE CONVERSION KIT.

[illegible]

- NOTES: 1. PROVIDE CEILING GRILLE, INTEGRAL BACK DRAFT DAMPER, VARI-SPEED CONTROLLER (NEAR FAN AND ABOVE CEILING) AND WALL CAP.
2. PROVIDE WALL SLEEVE, REAR GUARD HOUSING, BACKDRAFT DAMPER, WEATHER HOOD, BIRD SCREEN.




















2. PROVIDE WALL SLEEVE, REAR GUARD HOUSING, BACKDRAFT DAMPER, WEATHER HOOD, BIRD SCREEN.

MECHANICAL GENERAL NOTES:

1. COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS AS REQUIRED TO PROPERLY INSTALL ALL SYSTEMS AS INTENDED, WITHIN THE CONFINES OF THE SPACES AVAILABLE, AND WITHOUT INTERFERENCES.
2. THIS CONTRACTOR SHALL PERFORM ALL WORK INDICATED AND/OR AS REQUIRED FOR THE OFFER INSTALLATION AND OPERATION OF THE MECHANICAL SYSTEMS.
3. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF DIFFUSERS.
4. INSTALL ALL DUCT, PIPE, ETC. AS HIGH AS POSSIBLE.
5. DUCT SIZES SHOWN ARE ACTUAL SHEET METAL SIZES AND INCLUDE AN ALLOWANCE FOR DUCT LINER WHERE APPLICABLE.
6. PROVIDE FLEXIBLE CONNECTION BETWEEN DUCTWORK AND AIR HANDLING UNITS, EXHAUST FANS, AND OTHER MOTORIZED EQUIPMENT.
7. NO DUCT SHALL BE ROUTED OVER THE TOP OF ELECTRICAL PANELS.
8. ALL MECHANICAL SYSTEMS SHALL BE BALANCED BY A CERTIFIED BALANCING CONTRACTOR. REFER TO SPECIFICATIONS FOR DETAILS.

DIFFUSER SCHEDULE						
MARK	MFGR	MODEL	NECK SIZE	FACE SIZE	FINISH	NOTES
SR-1	TITUS	30ORS	12"x6"	-	WHITE	W O.B.D.
SR-2		30ORS	8"x6"	-		W O.B.D.
SR-3		30ORS	16"x6"	-		W O.B.D.
TS-1		35ORL	14"x8"	-		-
RG-1		PAR/3	22"x22"	24"x24"		W TRM

MECHANICAL SYMBOLS

	NEW SUPPLY DIFFUSER
	NEW RETURN AIR GRILLE
	EXHAUST GRILLE/FAN
	THERMOSTAT, MOUNTED AT 45° AFF
	MOTORIZED DAMPER/LOUVER
	NEW DUCTWORK
32"x14"	SIZE OF RECTANGULAR DUCT
6"Ø	SIZE OF ROUND DUCT
	FLEXIBLE DUCTWORK
	FLEXIBLE CONNECTION TO FAN
	FLOOR PLAN NOTE DESIGNATION
S.A.	SUPPLY AIR
R.A.	RETURN AIR
EXH.	EXHAUST AIR
	TRANSITION IN DUCT SIZE
	ELBOW WITH TURNING VANES
	MANUAL VOLUME DAMPER
	MANUAL VOLUME DAMPER
	MOTORIZED CONTROL DAMPER
	SPLITTER DAMPER WITH HORIZONTAL REGULATOR
	SUPPLY AIR DUCT UP/DOWN
	RETURN AIR DUCT UP/DOWN
	EXHAUST AIR DUCT UP/DOWN
	CHANGE IN ELEVATION UP (UP) DOWN (DN) IN DIRECTION OF FLOW
RTU-1	SCHEDULED MECHANICAL EQUIPMENT



Signature
BUILDERS
— KC, LLC —

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891

Website:
www.sb-kc.net

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net

Residential AutoCAD Drafting and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION
DOCUMENTS

Project Number	2019.03
----------------	---------

Date 2020 MAY 14

Drawn By SP/BH

Checked By EK/DS

M-201

Scale $3/16" = 1'-0"$

BC PROJECT #:	20388
MISSOURI	PE COA #2009003629

This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer/Engineer and is intended for use on this project only. Pursuant to the Architectural Works Copyright Protection Act of 1990, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of spaces and elements appearing herein, constitute the original, copyrighted work of the Designer/Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS
INCORPORATED

5720 Reeder Shawnee, Ks. 66203 (913)262-1772

No.	Description	Date
1	City Comments	6/18/20


CONSTRUCTION
DOCUMENTS

Project Number	2019.03
Date	2020 MAY 14
Drawn By	SP/BH
Checked By	EK/DS

LIGHT FIXTURE SCHEDULE				
MARK NO.	MANUFACTURER & CATALOG NUMBER	VOLTS WATTS	LIGHT SOURCE	DESCRIPTION
A	8' LED FIXTURE	120 150	LED	8' LED FIXTURE IN HANGER. VERIFY MOUNTING WITH OWNER/ARCHITECT.
B	8' LED FIXTURE	120 150	LED	8' LED FIXTURE IN HANGER. VERIFY MOUNTING WITH OWNER/ARCHITECT.
C	WALL MOUNTED FIXTURE	120 50	LED	EXTERIOR RATED EXTERIOR FIXTURE. VERIFY LOCATION WITH OWNER/ARCHITECT.
D	WALL MOUNTED FIXTURE	120 25	LED	WALL MOUNTED FIXTURE FOR STORAGE UNDER STAIRS.
F	WALL MOUNTED FIXTURE	120 25	LED	WALL MOUNTED FIXTURE ABOVE VANITY MIRROR IN RESTROOM.
R	6" IC RATED LED CAN	120 20	LED	6" IC RATED LED CAN
WP	EXTERIOR WALL PACK	120 75	LED	EXTERIOR WALL PACK WITH INTEGRAL PHOTOCELL. VERIFY EXACT LOCATION WITH OWNER/ARCHITECT
⚡	WALL MOUNTED EMERGENCY LIGHT	120 1	INCL	EMERGENCY LIGHT WITH TWIN ADJUSTABLE LED HEADS AND BATTERY, MOUNT AT 7'-6", TO CLEAR OBSTACLES.
⚡	WALL MOUNTED COMBINATION EXIT/EMERGENCY LIGHT	120 3	INCL	COMBINATION EMERGENCY/EXIT LIGHT WITH LED LAMPS, RED LETTERS ON WHITE BACKGROUND, TWIN LED EMERGENCY LIGHT HEADS, UNIVERSAL MOUNT, BATTERY BACKUP
⚡	WALL MOUNTED COMBINATION EXIT/EMERGENCY LIGHT AND REMOTE TWIN HEAD EMERGENCY LIGHT	120 5	INCL	COMBINATION EMERGENCY/EXIT LIGHT WITH LED LAMPS, RED LETTERS ON WHITE BACKGROUND, TWIN EMERGENCY LIGHT HEADS, UNIVERSAL MOUNT, HIGH CAPACITY BATTERY BACKUP AND REMOTE TWIN HEAD OUTDOOR RATED FIXTURE


PANEL: F		VOLTS: 120/208V			PH: 3Ø		WIRE: 4W		LOCATION: HANGER			MOUNTING: SURFACE		MOUNTING: SURFACE			
BUS: 400A		MAIN: 400A MCB			IG: 22,000		RMS SYM AMPS						FEEDER: SEE RISER DIAGRAM				
CKT	DESCRIPTION	AMPS	POLE	WIRE	ØA	ØB	ØC	ØA	ØB	ØC	WIRE	POLE	AMPS	DESCRIPTION	CKT NO		
1	BNH-1	100	2	3	9,000			840			12	1	20	UH-1	2		
3						9,000			840		10	1	20	UH-2	4		
5							9,000			7,020	4	2	70	AHU-1	6		
7	BNH-2	100	2	3	9,000					7,020					8		
9						2,600			7,020	4	2	70	AHU-2	10			
11							2,600			7,020					12		
13	CU-2	40	2	6	2,600			646			12	1	20	EF-3	14		
15						2,600			1,000	10	1	20	EXT LTS	16			
17					OVERHEAD DOOR	20	2	10			1,200		500	12	1	20	SMOKE DETECTORS [HL]
19					1,200				720		12	1	20	MAIN FLR GEN/RR RECS	20		
21	HANGER QUAD	20	1	10		360				1,000	12	1	20	MAIN FLR COUNTER/DISP [GF]	22		
23	HANGER QUAD	20	1	10			360				1,500	10	1	20	MAIN FLR MICROWAVE [GF]	24	
25	HANGER QUAD	20	1	10	360				1,500		10	1	20	MAIN FLR MICROWAVE [GF]	26		
27	HANGER QUAD	20	1	10		360				1,440	10	1	20	MAIN FLR OFFICE RECS	28		
29	HANGER QUAD	20	1	10			360				1,440	8	1	20	MAIN FLR OFFICE RECS	30	
31	HANGER QUAD	20	1	10	360					1,440		8	1	20	MAIN FLR OFFICE RECS	32	
33	HANGER QUAD	20	1	10		360				1,440		8	1	20	MAIN FLR OFFICE RECS	34	
35	EXT REC	20	1	12			180				900	12	1	20	UPPER FLR GEN/RR RECS	36	
37	SPARE	20	1						1,500			10	1	20	UPPER FLR MICROWAVE [GF]	38	
39	OFFICE LTS	20	1	12		1,315				1,500		10	1	20	UPPER FLR MICROWAVE [GF]	40	
41	HANGER LTS	20	1	12			1,650				1,260	10	1	20	UPPER FLR OFFICE RECS	42	
43	SPARE	20	1						1,260			10	1	20	UPPER FLR OFFICE RECS	44	
45	SPARE	20	1							1,260		8	1	20	UPPER FLR OFFICE RECS	46	
47	SPARE	20	1								1,260	8	1	20	UPPER FLR OFFICE RECS	48	
49	BUSSED SPACE												1	20	SPARE	50	
51	BUSSED SPACE												1	20	SPARE	52	
53	BUSSED SPACE												1	20	SPARE	54	
55	BUSSED SPACE														BUSSED SPACE	56	
57	BUSSED SPACE														BUSSED SPACE	58	
59	BUSSED SPACE														BUSSED SPACE	60	
NOTES:					22,520	16,545	15,350	14,976	15,500	20,900							
[HL]-HANDLE LOCK, [GF]-GFCI BRKR 5ma					37,446		32,045		36,250		TOTAL CONNECTED LOAD:					105,841	VA
										NEG DEMAND LOAD:					104,712	VA	
										DEMAND AMPS @ 208 VOLT / 3Ø:					240.82	A	

- ELECTRICAL GENERAL NOTES:
- COORDINATE ALL WORK WITH OTHER TRADES AND EXISTING CONDITIONS AS REQUIRED TO PROPERLY INSTALL ALL SYSTEMS AS INTENDED, WITHIN THE CONFINES OF THE SPACES AVAILABLE, AND WITHOUT INTERFERENCES.
 - IT IS THE ELECTRICAL CONTRACTORS RESPONSIBILITY TO PROPERLY BALANCE ALL BRANCH CIRCUITS BETWEEN THE PHASES OF THE SYSTEM REGARDLESS OF CIRCUITING INDICATED.
 - ALL EXPOSED RACEWAYS SHALL BE EMT CONDUIT, MC CABLE IS NOT PERMITTED IN EXPOSED AREAS.
 - ELECTRICAL CONTRACTOR TO COORDINATE MANUFACTURER ELECTRICAL REQUIREMENTS FOR HVAC EQUIPMENT BEING FURNISHED WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN. EQUIPMENT DISCONNECTS TO BE PROVIDED BY ELECTRICAL CONTRACTOR UNLESS NOTED OTHERWISE IN MECHANICAL SCHEDULES.
 - REFER TO ARCHITECTURAL DRAWINGS FOR EXACT LOCATION OF LIGHT FIXTURES AND DEVICES.
 - ELECTRICAL CONTRACTOR TO COORDINATE MANUFACTURER REQUIREMENTS FOR SUPPORTING TRANSFORMERS, EQUIPMENT, ETC. FROM THE STRUCTURE. PROVIDE ADDITIONAL STEEL AS REQUIRED TO PROPERLY SUPPORT SYSTEMS FROM THE STRUCTURE.
 - ALL MATERIALS EXPOSED WITHIN PLENUMS SHALL BE NONCOMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE-DEVELOPED INDEX OF NOT MORE THAN 50 WHEN TESTED IN ACCORDANCE WITH ASTM E 84.
 - EACH BRANCH CIRCUIT SHALL HAVE A DEDICATED NEUTRAL PER NEC 210.4.
 - ALL BRANCH CIRCUITS SHALL BE SIZED TO ALLOW FOR A MAXIMUM OF 3% VOLTAGE DROP. ALL FEEDERS SHALL BE SIZED TO ALLOW FOR A MAXIMUM OF 2% VOLTAGE DROP. ELECTRICAL CONTRACTOR SHALL VERIFY WIRING INDICATED IS SUFFICIENT AND INCREASE CONDUCTOR SIZE AS REQUIRED BASED OFF ACTUAL INSTALLED LENGTH OF CONDUCTORS.
 - REFER TO ELECTRICAL SCOPE OF WORK ON SHEET A102 FOR MORE INFORMATION.
 - ALL WIRING SHALL BE IN ACCORDANCE WITH 2017 NEC ARTICLE 513 FOR AIRCRAFT HANGARS.



ELECTRICAL SYMBOLS LIST	
CIRCUITING & NOTES	
+48"	SPECIAL MOUNTING HEIGHT FOR ASSOCIATED DEVICE (CENTERLINE OF DEVICE)
GFI	GROUND FAULT CIRCUIT INTERRUPTER DEVICE
WP	WEATHERPROOF ENCLOSURE ON DEVICE
WR	WEATHERPROOF RESISTANT DEVICE
X	ELECTRICAL FLOOR PLAN NOTE WITH DESIGNATION
2 LP	CONDUIT CONCEALED WHERE POSSIBLE OR AS NOTED, ARROWS INDICATE HOME RUN TO PANEL. CIRCUIT NUMBERS INDICATED
⚡	#12 WIRE IN CONDUIT, UNLESS NOTED OTHERWISE ON DRAWINGS OR SPECIFICATION
⚡	GROUNDING CONDUCTOR, #12 WIRE UNLESS NOTED OTHERWISE ON DRAWINGS OR SPECIFICATION
⚡	CONDUIT ROUTED UNDER FLOOR/GRADE
LIGHTING	
⚡	EMERGENCY TWIN HEAD LIGHT FIXTURE
⚡	EXIT LIGHT WITH DIRECTIONAL ARROWS INDICATED
⚡	STRIP FIXTURE WITH TYPE DESIGNATION
⚡	RECESSED OR SURFACE MOUNTED FIXTURE WITH TYPE DESIGNATION
⚡	NIGHT LIGHT, CONNECT TO UNSWITCHED CIRCUIT
⚡	CEILING OR RECESSED FIXTURE WITH TYPE DESIGNATION
⚡	WALL MOUNTED FIXTURE WITH TYPE DESIGNATION
POWER DEVICES	
⚡	DUPLEX RECEPTACLE, BOTTOM OF BOX AT 16" AFF, UNLESS NOTED OTHERWISE
⚡	FOURPLEX RECEPTACLE, BOTTOM OF BOX AT 16" AFF, UNLESS NOTED OTHERWISE
⚡	DEVICE MOUNTED ABOVE COUNTER AND/OR SPLASH GUARD
⚡	HEAVY DUTY OUTLET - NEMA CONFIGURATION SIZE PER EQUIPMENT MANUFACTURER'S RECOMMENDATION
⚡	PANEL BOARD, TOP OF BOX 6'-0" AFF
⚡	JUNCTION BOX
⚡	NON-FUSED DISCONNECT SWITCH
⚡	FUSED DISCONNECT SWITCH
⚡	MOTOR WITH DESIGNATION
CONTROLS	
S	SINGLE POLE WALL SWITCH, TOP OF BOX AT 48" AFF
S ₂	TWO POLE WALL SWITCH, TOP OF BOX AT 48" AFF
S ₃	THREE-WAY WALL SWITCH, TOP OF BOX AT 48" AFF
S ₄	FOUR-WAY WALL SWITCH, TOP OF BOX AT 48" AFF
S _m	MANUAL MOTOR STARTER WITH OVERLOADS
COMMUNICATIONS	
▼	DATA/TELEPHONE OUTLET WITH MINIMUM 3/4" CONDUIT STUBBED UP TO ABOVE ACCESSIBLE CEILING, BOTTOM OF BOX AT 16", UNLESS NOTED OTHERWISE. PROVIDE WITH PULL STRING
MISCELLANEOUS	
⚡	120V AUDIBLE BASE CEILING MOUNT SMOKE DETECTOR, WIRE TO CIRCUIT F-18 WITH #12AWG.


- ELECTRICAL SPECIFICATIONS
- GENERAL PROVISIONS:
 - PROVIDE ALL LABOR, MATERIALS, EQUIPMENT, NECESSARY FOR THE COMPLETE INSTALLATION OF THE ELECTRICAL SYSTEMS OUTLINED.
 - OBTAIN ALL PERMITS, FEES, LICENSES, INSPECTIONS, AND CERTIFICATES OF COMPLIANCE OR APPROVAL AS REQUIRED BY THE AUTHORITIES.
 - ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE LATEST APPROVED EDITION OF THE NATIONAL ELECTRIC CODE (NEC) AND ALL APPLICABLE AWS, CODES AND REGULATIONS OF THE GOVERNMENTAL BODIES HAVING JURISDICTION OVER THE SITE.
 - ALL TESTINGS REQUIRED BY AUTHORITIES SHALL BE CONSIDERED PART OF THIS WORK.
 - DURING CONSTRUCTION, ALL FIXTURES, EQUIPMENT, CONDUIT, ETC. SHALL BE COVERED, PLUGGED, OR CAPPED AS REQUIRED TO KEEP DRY AND UNDAMAGED. ALL DAMAGED ITEMS SHALL BE RESTORED TO ORIGINAL CONDITION OR REPLACED. ALL PROTECTIVE COVERINGS SHALL BE REMOVED BEFORE FINAL ACCEPTANCE.
 - PROVIDE ALL NECESSARY CUTTING AND PATCHING OF WALLS, FLOORS, CEILINGS, AND ROOFS AS NECESSARY. PATCH AROUND ALL OPENINGS STRIKEMAN ADJACENT AREA. COORDINATE WITH ROOFING WORK WITH OWNER OR RESPONSIBLE PARTY, SO THAT THE EXISTING ROOFING WARRANTY WILL BE MAINTAINED.
 - CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS AGAINST DEFECTS FOR A PERIOD OF ONE YEAR FROM FINAL ACCEPTANCE.
 - CONTRACTOR SHALL PROVIDE ACCESS PANELS WHERE NECESSARY FOR CONCEALED ELECTRICAL COMPONENTS.
 - OPERATION AND MAINTENANCE MANUALS:
 - DURING THE COURSE OF CONSTRUCTION, COLLECT AND COMPILE OPERATING INSTRUCTIONS, WIRING DIAGRAMS, CATALOG CUTS, LIBERATION AND PREVENTATIVE MAINTENANCE INSTRUCTIONS, PARTS LISTS, ETC. FOR ALL EQUIPMENT FURNISHED UNDER THIS CONTRACT.
 - ALL LITERATURE AND INSTRUCTIONS SHIPPED WITH THE EQUIPMENT SHALL BE SAVED FOR INCLUSION IN THE OPERATION AND MAINTENANCE MANUALS.
 - ALL LITERATURE LISTED ABOVE AND ALL PAPERS LISTING WARRANTIES, ETC. SHALL BE COLLATED AND LABELED WITH THE PROJECT NAME, ADDRESS, ARCHITECT, ENGINEER, CONTRACTORS, ETC. CONTRACTORS, ETC. DOCUMENTS SHALL BE COMPILED AND BOUND IN DIGITAL FILE OR 3 RING BINDER.
 - MANUFACTURERS:
 - MANUFACTURERS, MODEL NUMBERS, ETC. INDICATED OR SCHEDULED ON THE DRAWINGS SHALL BE INTERPRETED AS HAVING ESTABLISHED A STANDARD OF QUALITY AND SHALL NOT BE CONSTRUED AS LIMITING COMPETITION. ARTICLES, FIXTURES, ETC. OF EQUAL QUALITY BY MANUFACTURERS SHALL BE ACCEPTABLE, SUBJECT TO STRUCTURAL AND ELECTRICAL CONSTRAINTS OF THE PROJECT DESIGN, UNLESS NOTED OTHERWISE.
 - TESTING, AND BALANCING:
 - ALL CIRCUITS SHALL BE TESTED FOR CONTINUITY, SHORTS, AND GROUNDS BEFORE CONNECTING TO THE PROPER PHASE AS DESIGNED TO BALANCE THE LOADS BETWEEN PHASES.
 - POWER AND LIGHTING PANELS SHALL BE PROPERLY PHASED TO DISTRIBUTE THE LOAD AND SHALL BE CONNECTED AND ADJUSTED TO OPERATE AS SPECIFIED.
 - ALL MOTORS AND SIMILAR EQUIPMENT SHALL BE CHECKED FOR PROPER PHASE ROTATION AND OPERATION.
 - RACEWAYS:
 - CONDUIT INSIDE THE BUILDING SHALL BE METALLIC TUBING (EMT), BEARING THE UL LABEL, WITH COMPRESSION TYPE FITTINGS OR SCREW SET FITTINGS.
 - CONDUIT EXPOSED TO THE WEATHER, INSTALLED UNDERGROUND, IN CONCRETE, OR USED FOR SERVICE ENTRANCE SHALL BE STANDARD RIGID CONDUIT (GALVANIZED) WITH THREADED FITTINGS.
 - UNDERGROUND CONDUIT MAY BE POLYVINYL CHLORIDE WITH A DEFLECTION TEMPERATURE, UNDER LOAD AT 204 PSI, OF 10 DEGREES C, AND A TENSILE STRENGTH OF 5,200 PSI. JOINTS SHALL BE FUSED SOLVENT WELDED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS. CONDUIT SHALL BE EQUAL TO CARLON POWER AND COMMUNICATIONS DUCT TYPE DB (DIRECT BURIAL). CONDUIT AND FITTINGS SHALL BE PROVIDED BY THE SAME MANUFACTURER.
 - FLEXIBLE METAL CONDUIT SHALL ONLY BE USED FOR CONNECTIONS TO MOTORS, TRANSFORMERS, AND LIGHT FIXTURES. MAXIMUM LENGTH SHALL BE 6'-0".
 - CONDUCTORS:
 - WIRES SHALL BE CONTINUOUS WITHOUT SPLICES OR TAPS IN CONDUIT RUNS. ALL SPLICES SHALL BE MADE IN JUNCTION, PULL, OR OUTLET BOXES. ALL WIRE SHALL BE INSTALLED IN CONDUIT, RACEWAYS, OR OTHER PROTECTIVE COVER SANCTIONED BY CODES.
 - CONDUCTORS FOR LIGHTING AND POWER SHALL BE COPPER, MINIMUM NO. 12 A.M.S., 600 VOLT.
 - NO. 10 GAUGE AND SMALLER CONDUCTORS SHALL BE TYPE THHN (WET LOCATIONS) OR THHN (DRY LOCATIONS), SOLID CONDUCTOR, UNLESS OTHERWISE INDICATED.
 - NO. 8 GAUGE AND LARGER CONDUCTORS SHALL BE TYPE THWN (WET LOCATIONS) OR THHN (DRY LOCATIONS), STRANDED, UNLESS OTHERWISE INDICATED.
 - SERVICE ENTRANCE AND PANEL FEEDER CONDUCTORS, NO. 3 GAUGE AND LARGER SHALL BE TYPE XHHW-2 (WET LOCATIONS) OR THHN (DRY LOCATIONS), STRANDED COPPER, UNLESS OTHERWISE INDICATED.
 - MC CABLE:
 - MC CABLE SHALL CONSIST OF INTERLOCK ARMORED CABLE MADE OF THREE OR FOUR TYPE THIN SOLID (16 AWG AND LARGER MAY BE STRANDED) COPPER CONDUCTORS RATED 90°C FOR DRY LOCATIONS, WITH NYLON LISTED JACKET, PER UL STANDARD 83. THE THREE CONDUCTORS SHALL BE TWISTED TOGETHER WITH THE COPPER GROUNDING CONDUCTOR, SUITABLE FILLERS, AND WRAPPED IN BINDER TAPE. THE ASSEMBLY SHALL BE ARMORED WITH SPIRALLY WRAPPED INTERLOCKED ARMOR OF ALUMINUM OR GALVANIZED STEEL.
 - CABLES SHALL BE TESTED IN ACCORDANCE WITH UL STANDARD 1564 FOR TYPE MC CABLE AND RATED AT 600 VOLTS, 90 DEG. C FOR DRY LOCATIONS AND 75 DEG. C FOR WET LOCATIONS.
 - WIRING DEVICES:
 - WALL SWITCHES SHALL BE SPECIFICATION GRADE, QUIET TYPE, FLUSH TOGGLE SWITCH, RATED FOR 20 AMPS, WITH THERMOPLASTIC COVER PLATES.
 - 1) SINGLE POLE: HUBBELL HCS1221-X, OR EQUAL.
 - 2) THREE-WAY: HUBBELL HCS1223-X, OR EQUAL.
 - RECEPTACLES SHALL BE SPECIFICATION GRADE, DUPLEX, GROUNDING, THREE-WIRE TYPE, RATED FOR 20 AMPS, WITH THERMOPLASTIC COVER PLATES. HUBBELL HCS9523-X, OR EQUAL.
 - GROUND FAULT INTERRUPTER RECEPTACLES (GFI) SHALL BE HUBBELL HGF20-XL. DEVICE COVER PLATES SHALL BE AS HEREINBEFORE SPECIFIED.
 - ISOLATED GROUND RECEPTACLES (IG) SHALL BE HUBBELL HCS9523, ORANGE COLOR. DEVICE COVER PLATES SHALL BE AS HEREINBEFORE SPECIFIED.
 - RECEPTACLES OUTSIDE BUILDINGS AND WHERE NOTED AS WEATHERPROOF, SHALL BE LISTED WEATHER-RESISTANT HUBBELL HGFTR20-X OR EQUAL AND SHALL BE INSTALLED IN A WEATHERPROOF ENCLOSURE WHICH SHALL BE INTERMATIC WPI1010XND OR WPI1010XNDX DIECAST METAL WEATHERPROOF RECEPTACLE COVER. COVER SHALL BE WEATHER PROOF RATED WHILE IN USE.
 - VERIFY DEVICES AND DEVICE COVERPLATES COLOR AND STYLE WITH ARCHITECT.
 - BOXES:
 - HOT DIPPED GALVANIZED STEEL BOXES. PROVIDE TYPE TO SUIT CONDITIONS FOR INSTALLATION.
 - ALL BOXES SHALL BE FLUSH MOUNTED, UNLESS INDICATED OTHERWISE.
 - PANELBOARDS:
 - FURNISH AND INSTALL CIRCUIT BREAKER PANELBOARDS AS SHOWN ON THE DRAWINGS. PANELBOARDS SHALL BE LISTED BY UL AND SO LABELED, AND SHALL BE FULLY RATED FOR THE VOLTAGE AND CURRENT CAPACITY INDICATED ON THE PANEL SCHEDULE. PANELBOARDS SHALL BE EQUAL TO SQUARE D TYPE NG OR NF WITH BOLT-IN TYPE BREAKERS. PANELBOARD LUGS SHALL BE RATED AT 75°C.
 - 1) CIRCUIT BREAKER INTERRUPTING CAPACITIES SHALL MEET OR EXCEED THE AVAILABLE RMS SYMMETRICAL FAULT CURRENTS INDICATED AND AS REQUIRED TO MEET OR EXCEED THE AVAILABLE FAULT CURRENT FROM LOCAL UTILITY.
 - 2) CIRCUIT BREAKERS SHALL MEET APPLICABLE PORTIONS OF UL STANDARD 484 AND NEMA AB-1. CIRCUIT BREAKERS SHALL BE BOLT-ON, GROUND MOUNTED, AMBIENT MAGNETIC, WITH COMMON TRIP, UL RATED TO CARRY 80% OF NAMEPLATE RATING CONTINUOUSLY IN FREE AIR AT 40° C. CIRCUIT BREAKERS SHALL BE TRIP INDICATING AND FULLY INTERCHANGEABLE WITHOUT DISTURBING ADJACENT UNITS. WIRE TERMINALS SHALL BE RATED TO DEGREESS C. THE OPERATING MECHANISM SHALL BE TRIP-FREE SO THAT CONTACTS CANNOT BE HELD CLOSED AGAINST ANY ABNORMAL OVERCURRENT OR SHORT CIRCUIT CONDITION.
 - 3) BREAKERS SHALL MEET APPLICABLE NEMA AND/OR UL SPECIFICATIONS.
 - PANELBOARD BOXES SHALL BE GALVANIZED SHEET STEEL WITH AMPLE WIRING GUTTER SPACE IN ACCORDANCE WITH NEC. FRONTS SHALL BE OF SHEET STEEL PAINTED LIGHT GREY OVER A SUITABLE RUST INHIBITOR PRIMER. PANELBOARDS SHALL BE EQUIPPED WITH ONE REECE DOOR, CYLINDER TUMBLER TYPE LOCK, DIRECTORY CARD-HOLDER AND QUARTER-TURN ADJUSTABLE TRIM CLAMPS.
 - PANELBOARD INTERIORS SHALL CONSIST OF REINFORCED GALVANIZED SHEET STEEL FRAMES WITH ALUMINUM BUS BARS AND CIRCUIT BREAKERS, PROPERLY SUPPORTED TO PREVENT VIBRATIONS AND BREAKAGE IN HANDLING. BUS BARS SHALL BE SEQUENCE PHASED. PANELBOARD SHALL HAVE A FULL SIZED SOLID ALUMINUM NEUTRAL AND GROUND BUS.
 - BUS BAR BRACING SHALL BE UL LISTED AS INDICATED ON DRAWINGS. ADDITIONAL BRACING SHALL BE PROVIDED AS REQUIRED TO MEET OR EXCEED INDICATED AVAILABLE FAULT CURRENTS.
 - DIRECTORY CARDS SHALL BE COMPLETELY FILLED IN BY TYPEWRITER, LISTING CIRCUIT NUMBERS AND LOAD SERVICE, INCLUDING EXISTING CIRCUITS. CIRCUIT BREAKERS SHALL BE IDENTIFIED BY CIRCUIT NUMBER LABELS AS HEREINBEFORE SPECIFIED.



ELECTRICAL RISER DIAGRAM
SCALE: NONE

BC PROJECT #: 20398
MISSOURI PE COA #2009003629


This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Design-Engineer and is intended for use on the project only. Pursuant to the Architecture-Engine Copyright Protection Act of 1986, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of spaces and elements appearing herein, constitute the original, copyrighted work of the Design-Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.



UPPER FLOOR ELECTRICAL PLAN
SCALE: 3/16" = 1'-0"

ELECTRICAL PLAN NOTES:

- 1 CONNECT EXTERIOR LIGHT TO CIRCUIT P-16 WITH #10AWG.
- 2 CONNECT TO OVERHEAD DOOR OPERATOR PER MANUFACTURERS INSTRUCTIONS. INSTALL COMPLETE. VERIFY EXACT LOCATION AND ELECTRICAL REQUIREMENTS.
- 3 MAKE CONNECTION BETWEEN 3-WAY/4-WAY SWITCHES CONTROLLING HANGER LIGHTS AS INDICATED BY (a,b).
- 4 LIGHT FIXTURE AND RECEPTACLE SHOWN ON BOTH MAIN FLOOR AND UPPER FLOOR PLAN.



MAIN FLOOR ELECTRICAL PLAN
SCALE: 3/16" = 1'-0"

BC PROJECT #: 20388
MISSOURI PE COA #2009003629
This drawing has been prepared by the Engineer, or under his supervision. This drawing is provided as an instrument of service by the Designer-Engineer and is intended for use on this project only. Pursuant to the Architecture-Engineering Copyright Protection Act of 1980, all drawings, specifications, ideas and designs, including the overall form, arrangement and composition of space and elements appearing herein, constitute the original, copyrighted work of the Designer-Engineer. Any reproduction, use, or disclosure of information contained herein without prior written consent of the Engineer is strictly prohibited. © 2020 BC Engineers, Inc.

BC ENGINEERS INCORPORATED



Signature BUILDERS KC, LLC

Signature Builders KC, LLC
2751 NE Douglas St. - Suite R
Lee's Summit, Missouri 64064
Phone: (816) 215-0891
Website:
www.sb-kc.net

New Airplane Hangar

CAD Construction Documents
Voice / Text : 913.638.3241
mgspencer@sbcglobal.net
Residential AutoCAD Drafting
and Design Services

No.	Description	Date
1	City Comments	6/18/20

CONSTRUCTION DOCUMENTS

Project Number 2019.03
Date 2020 MAY 14
Drawn By SP/BH
Checked By EK/DS

E-100

Scale 3/16" = 1'-0"