

Hook Farm First Plat With Fire Flow At Maximum Day Demand

	ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	<input type="checkbox"/> 7868	0.00	97.80	1,193.70	1,000.00	94.57	8,663.41	20.00
2	<input type="checkbox"/> 7870	0.00	102.58	1,193.73	1,000.00	99.53	9,479.42	20.00
3	<input type="checkbox"/> 7872	0.00	100.84	1,193.72	1,000.00	95.98	5,727.04	20.00
4	<input type="checkbox"/> 7874	0.00	100.84	1,193.72	1,000.00	95.12	4,995.80	20.00
5	<input type="checkbox"/> 7876	0.00	95.63	1,193.71	1,000.00	91.23	6,049.28	20.00
6	<input type="checkbox"/> 7878	0.00	93.90	1,193.70	1,000.00	87.86	4,600.35	20.00
7	<input type="checkbox"/> 8410	24.83	92.15	1,193.67	1,000.00	70.31	2,000.11	20.00
8	<input type="checkbox"/> 8412	0.00	100.41	1,193.73	1,000.00	96.66	7,308.61	20.00
9	<input type="checkbox"/> 8414	0.00	97.37	1,193.71	1,000.00	93.07	6,258.79	20.00



Hook Farms First Plat Without Fire Flow At Peak Hour Flow

	ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	<input type="checkbox"/> 7868	0.00	80.49	1,153.77	0.00	80.49	6,545.61	20.00
2	<input type="checkbox"/> 7870	0.00	85.31	1,153.88	0.00	85.31	7,257.84	20.00
3	<input type="checkbox"/> 7872	0.00	83.55	1,153.83	0.00	83.55	4,581.99	20.00
4	<input type="checkbox"/> 7874	0.00	83.55	1,153.83	0.00	83.55	4,039.21	20.00
5	<input type="checkbox"/> 7876	0.00	78.33	1,153.79	0.00	78.33	4,717.18	20.00
6	<input type="checkbox"/> 7878	0.00	76.60	1,153.77	0.00	76.60	3,637.51	20.00
7	<input type="checkbox"/> 8410	49.66	74.80	1,153.64	0.00	74.80	1,657.09	20.00
8	<input type="checkbox"/> 8412	0.00	83.13	1,153.86	0.00	83.13	5,711.64	20.00
9	<input type="checkbox"/> 8414	0.00	80.08	1,153.81	0.00	80.08	4,902.56	20.00

SW POST OAK RD

SW PRY

