



Date: July 2nd, 2020

City of Lee's Summit, MO
Development Services
220 SE Green Street
Lee's Summit, MO 64063

RE: Osage First Plat – Water

We are responding to your comments dated June 23rd, 2020 and are submitting with this letter revised plans. Please find the original comments below; our responses are below in ***bold italics***.

If you have any questions or need additional information, please do not hesitate to contact us.

Thank you,

A handwritten signature in blue ink that reads "Brock Worthley".

Brock Worthley

Engineering Review – Corrections

1. Pipe insulation detail appeared to be missing from the plans. Previously-approved pipe insulation details involved construction of a “doghouse” type structure beneath grade. Please provide the detail in the final submittal.

Per conversations with city, insulation is only required when the pipe is less than 36” deep. All pipes are greater than 36” deep so insulation is no longer needed.

2. Ductile iron pipe must be zinc-coated in all instances.

Ductile iron pipe labels changed to ductile iron pipe with zinc-coating.