

**DEVELOPMENT SERVICES**

**Commercial Final Development Plan  
Applicant's Letter**

**Date:** Monday, July 20, 2020

**To:**

**Property Owner:** CITY OF LEE'S SUMMIT      Email:  
MISSOURI

**Applicant:** THOMPSON BUILDERS LLC      Email: TSLAMIN@GMAIL.COM

**Other:** RL SALLEE REAL ESTATE INVESTMENTS LLC      Email:

**Engineer:** LOVELACE & ASSOCIATES LLC      Email: ADT@LOVELACEASSOCIATES.COM

**From:** Hector Soto Jr., Planning Division Manager

**Re:**

**Application Number:** PL2020120

**Application Type:** Commercial Final Development Plan

**Application Name:** Lee's Summit Airport - Hangar V

**Location:** 2751 NE DOUGLAS ST, Unit:V, LEES SUMMIT, MO 64064

---

**Electronic Plans for Resubmittal**

---

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

**Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

**Review Status:**

Approved: See below for any conditions of approval.

**Required Corrections:**

<b>Planning Review</b>	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	No Comments
------------------------	-----------------------------------	---	-------------

---

<b>Engineering Review</b>	Loic Nguinguiri, E.I.	Staff Engineer Loic.Nguinguiri@cityofls.net	Approved with Conditions
---------------------------	-----------------------	--	--------------------------

---

1. The Engineer’s Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$5,506.54
2. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
3. Please contact the Field Engineering Inspector at (816) 969-1200 at least 48 hours prior to the onset of construction.

<b>Fire Review</b>	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

---

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.
2. As the fire area of the building is greater than 12,000 square feet, the building shall be provided with an automatic fire sprinkler system or divided into fire areas in accordance with Chapter 7 of the 2018 IBC.

<b>Traffic Review</b>	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

---

<b>Building Codes Review</b>	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------

---