



July 7th, 2020

Sue Pyles, PE
Sr. Staff Engineer
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

RE: WOODLAND GLEN 2ND PLAT PL 2020041 – WATER MAIN EXTENSION

Dear Sue:

This letter is regarding comments received June 25, 2020 for the above referenced project to which we have the following responses:

Engineering Review

1. There is a 30" water main along the south side of SW 14th Street in addition to the 36" main. Please show and label in the Plan view and show the crossing in the Profile view.

Response: The 30" DIP watermain has been added to the plan and profile views.

2. Design and Construction Manual Section 6901.E.1.b requires 2 valves at every tee, on opposite lines. Please revise the plans accordingly. Also verify that the labels are all correct.

Response: Valves for the tees have been updated.

3. Revise the estimate and Summary of Quantities table accordingly.

Response: Quantities have been updated.

Please contact me if you have any questions or comments. If you have any further comments or questions regarding this survey, please do not hesitate to contact me. Thank you.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.

Mark A. Breuer, PE
Principal / Engineering Manager
Direct 913-322-7154
mab@schlagelassociates.com

/mdr
Enclosures

c: NLVC, LLC