



October 8, 2020

Gene Williams  
Senior Staff Engineer  
City of Lee's Summit, Missouri  
220 SE Green Street  
Lee's Summit, MO 64063

RE: Whispering Woods 2<sup>nd</sup> Plat – Public Sanitary

Dear Mr. Williams,

1. *Notes are shown on the revised profile views which mention the use of unapproved private lateral materials. If using notes, please refer to the approved standard drawing provided in the standard details section. Tees are not allowed, only wye connections.*  
**The note referencing the lateral has been updated to state wye connections only and to refer to Lee's Summit standard details.**

If you have any additional questions or comment do not hesitate to contact me.

Thank you,  
SNYDER & ASSOCIATES, INC.

A handwritten signature in blue ink, appearing to read 'Shawn Duke', is placed over the printed name.

Shawn Duke, PE  
Project Manager/Engineer