

Whispering Woods 2nd Plat With Fire Flow At Maximum Day Demand

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	☐	7978	0.00	91.96	1,195.23	1,000.00	88.42	5,375.16	20.00
2	☐	7980	0.00	83.29	1,195.23	1,000.00	71.78	2,553.47	20.00
3	☐	7982	0.00	79.83	1,195.23	1,000.00	67.05	2,335.27	20.00
4	☐	7984	8.62	81.13	1,195.23	1,000.00	68.45	2,382.77	20.00



Whispering Woods 2nd Plat Without Fire Flow At Peak Hour Demand

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	☐	7978	0.00	90.41	1,191.64	0.00	90.41	5,197.60	20.00
2	☐	7980	0.00	81.73	1,191.63	0.00	81.73	2,479.13	20.00
3	☐	7982	0.00	78.27	1,191.63	0.00	78.27	2,266.67	20.00
4	☐	7984	17.24	79.57	1,191.63	0.00	79.57	2,321.72	20.00

