



Date: October 5, 2020

City of Lee's Summit, Missouri
Attn: Gene Williams
220 SE Green Street
Lee's Summit, MO 64063

RE: Hawthorn Ridge 2nd Plat – Street, Stormwater, Master Drainage Plan, and Erosion and Sediment Control (PL2019235)

We are responding to your comments dated October 5, 2020 and are submitting with this letter revised plans. Please find the original comments below; our responses are below in bold italics.

If you have any questions or need additional information, please do not hesitate to contact us.

Thanks,

A handwritten signature in blue ink that reads "Julie Sellers". The signature is written in a cursive, flowing style.

Julie Sellers

Engineering Review - Corrections

1. Sheet C103: The grading at the end of the rip rap does not appear to make sense from an elevation standpoint, nor from an erosion standpoint. There does not appear to be any form of swale created for the discharge, and it appears there is a long, flat area just downstream of the rip rap. If this area will have a sediment basin, then shouldn't it be shown in this area, along with the grading.

The sediment basin grading has been added to the proposed surface shown on the grading plan.