

DEVELOPMENT SERVICES

**Commercial Preliminary Development Plan
Applicant's Letter**

Date: Friday, November 06, 2020

To:

Property Owner: CITY OF LEES SUMMIT

Email:

Applicant: STREETS OF WEST PRYOR LLC

Email:

Engineer: SM ENGINEERING

Email: SMCIVILENGR@GMAIL.COM

From: Jennifer Thompson, Planner

Re:

Application Number: PL2020280

Application Type: Commercial Preliminary Development Plan

Application Name: LOTS 1 AND 2 STREETS OF WEST PRYOR

Location: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

Tentative Schedule

Submit revised plans by noon on Monday, October 26, 2020 (4 full size paper copies, 1 reduced 8 ½" x 11" copy, and 4 copies of the comment response letter).

Applicant Meeting: October 13, 2020 at 09:00 AM

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plat - All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided as multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided as multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Planning Commission and City Council Presentations

Presentations before the Planning Commission and City Council shall be (1) in electronic format or (2) reduced drawings for use on the document camera to display on the screen. Electronic presentations shall be on a laptop, CD-ROM, DVD, or flash drive. The City's presentation system can support Word, Excel, PowerPoint, Adobe, Windows Media Player and Internet Explorer applications. Presentation boards will no longer be allowed. The presentation(s) shall be submitted to Development Services Department staff no later than the day of the Planning Commission meeting by 4:00 pm.

Notice Requirements

1. Notification of Surrounding Property Owners.

- **Mail Notices.** The applicant must mail letter notices to all property owners within 300 feet from the boundaries of the property for which the application is being considered at least 15 days prior to the hearing. Sample notices are available. The notice must include:
 - time and place of hearing,
 - general description of the proposal,
 - location map of the property,
 - street address, or general street location
 - statement explaining that the public will have an opportunity to be heard
- **File Affidavit.** An affidavit must be filed with the Planning and Codes Administration Department prior to the public hearing certifying the notices have been sent. Provide a list of the property owners notified and a copy of the sent notice .

2. Notice Signs.

- **Post Sign.** The applicant shall post a sign on the premises, at least 15 days prior to the date of the hearing, informing the general public of the time and place of the public hearing. When revised plans are submitted, staff will prepare the sign and provide it to the applicant for posting.
- **Maintain Sign.** The applicant shall make a good faith effort to maintain the sign for at least the 15 days immediately preceding the date of the hearing, through the hearing, and through any continuances of the hearing. The sign shall be placed within 5 feet of the street right-of-way line in a central position on the property that is the subject of the hearing. The sign shall be readily visible to the public. If the property contains more than one street frontage, one sign shall be placed on each street frontage so as to face each of the streets abutting the land. The sign may be removed at the conclusion of the public hearing(s) and must be removed at the end of all proceedings on the application or upon withdrawal of the application.

3. Neighborhood Meeting. One neighborhood meeting is required for each application, which must occur within the initial 10 day review period and prior to re-submission of the application. More than one neighborhood meeting may be held on an application, at the option of the applicant

- **Timing and location:** Within two miles of the project site, Monday through Thursday, excluding holidays, and start between 6:00P.M. and 8:00 P.M. If location for the meeting is not available within [2] miles of the subject property. The applicant shall select a location outside this area that is reasonably close to these boundaries.

- **Notification:** Shall be sent by certified mail or delivered to property owners within 300 feet of the project site. Mailed notices shall be postmarked at least seven days prior to the meeting. Hand deliveries must occur at least five (5) days prior to the meeting.
- **Notes:** The Applicant shall take sufficient notes at the neighborhood meeting to recall issues raised by the participants, in order to report on and discuss them at public hearings before City governmental bodies on the application. The notes shall be turned in with the application re-submittal.

Analysis of Commercial Preliminary Development Plan:

| | | | |
|------------------------|-------------------------------------|---|-------------|
| Planning Review | Jennifer Thompson (816) 969-1239 | Planner Jennifer.Thompson@cityofls.net | Corrections |
|------------------------|-------------------------------------|---|-------------|

1. The Lot 1 street tree requirement isn't met within the table, please revise.

Lot 2 street shrub requirement isn't met within the table, please revise.

2. The elevations for Shake Shack has changed dramatically. Staff has concerns the roof line may be too flat. Additional articulation is needed. There is alot of metal proposed, paticularly the west elevation. I don't believe we received a material sample for the metal, please provide.

| | | | |
|---------------------------|-----------------------------------|---|--------------------------|
| Engineering Review | Sue Pyles, P.E. (816) 969-1245 | Senior Staff Engineer Sue.Pyles@cityofls.net | Approved with Conditions |
|---------------------------|-----------------------------------|---|--------------------------|

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final development plan. All public infrastructure must be substantially complete, prior to the issuance of any certificates of occupancy.

2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any infrastructure permits or the start of construction (excluding land disturbance permit).

3. Certain aspects of the development plan will be further reviewed during the Final Development Plan phase of the project. This includes detailed aspects of the design to help ensure that the plan meets the design criteria and specifications contained in the Design and Construction Manual.

| | | | |
|--------------------|----------------------------|--|--------------------------|
| Fire Review | Jim Eden (816) 969-1303 | Assistant Chief Jim.Eden@cityofls.net | Approved with Conditions |
|--------------------|----------------------------|--|--------------------------|

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. IFC 903.3.7 - Fire department connections. The location of fire department connections shall be approved by the fire code official. Connections shall be a 4 inch Storz type fitting and located within 100 feet of a fire hydrant, or as approved by the code official.

Action required: On Lot 2, bring the FDC to the front (NW) corner of the building and move the fire hydrant to the end of drive-up lane.

3. Do not obstruct access to fire hydrants and FDC's with landscaping vegetation.

Action required: Make adjustments to the landscaping plan.

Traffic Review

Michael Park
(816) 969-1820

City Traffic Engineer
Michael.Park@cityofls.net

Approved with Conditions

1. Lowenstien will require roadway improvements to urban standards west of Blacktwig to the western most property line of the development in compliance with the City's Unimproved Road Policy (similar to required improvements to Blacktwig by earlier development phase). This condition will be reflected on the staff recommendations for approval on the staff prepared Traffic Impact Analysis.