

LITTLE BLUE VALLEY SEWER DISTRICT
INTERCEPTOR CONNECTION PERMIT

Connection Point No.: 670E-430
Issue Date: February 26, 2021

In accordance with all terms and conditions of the Little Blue Valley Sewer District's connection policies, or as otherwise stated in this permit:

Permission is hereby granted to: THE CITY OF LEE'S SUMMIT, MISSOURI


For the connection of: SANITARY SEWER

To the District's Interceptor at:


CONNECTION POINT NUMBER 670-430, AN EXISTING MANHOLE LOCATED APPROXIMATELY 1150 FEET NORTH AND 2320 FEET WEST OF THE INTERSECTION OF HOOK ROAD AND PRYOR ROAD; LOCATED IN LEE'S SUMMIT, MO.

This permit is granted in accordance with the application filed at the Little Blue Valley Sewer District, and in conformity with all information and data submitted in support of the above stated application, including approved plans and specifications, all of which are filed with and considered a part of this permit, together with the following named conditions and requirements:

1. No wastewater or pollutant shall be discharged which will directly or indirectly interfere with the operation or performance of the Little Blue Valley Sewer District's System. No wastewater shall be discharged in violation of the District's Pretreatment Rules.
2. The Little Blue Valley Sewer District shall provide a construction inspector to observe that construction of the connection is in accordance with the approved plans and specifications.
3. Connection shall be made in the following manner:
 - a. Field verify all measurements for the connection.
 - b. Protect breached facilities against the intrusion of deleterious substances and against damage.
 - c. All activities pertaining to the connection will be thoroughly planned in advance and all equipment, materials and labor required therefor will be on hand at the time undertaking of said connection shall occur. Arrangements will be made to work continuously to complete connection within the minimum time.
4. Any damage to existing Little Blue Valley Sewer District facilities resulting from connection operations shall be reported immediately by the Customer to the District, and repair, along with all expenses associated with same, shall be the responsibility of the Customer.
5. The District shall be informed of connection 1 day prior to the act. A District representative must be present during the actual connection.
6. The Little Blue Valley Sewer District shall maintain inspection and sampling rights at this connection point and at the location of flow contribution from any industrial flow sources serviced by this connection point.
7. The Customer shall comply with the District's requirements and policies for metering.
8. The first 20 feet of pipe upstream of the connection shall be ductile iron pipe.



Assistant Director



District Engineer