

March 3, 2021

Sue Pyles, PE
Senior Staff Engineer
City of Lee's Summit
220 SE Green St
Lee's Summit, MO 64063

RE: OAKVIEW STORAGE LOT 5 – PRIVATE WATER

Dear Sue:

This letter is regarding staff comments dated March 3, 2021 for the above-referenced project's engineering plan review to which we have the following response:

- Resubmit one (1) comments response letter and one (1) digital copy following the electronic plan submittal guides as stated below:
Response: Acknowledged.
- Revised plans will be reviewed within five (5) business days of the date received.
Response: Acknowledged

Engineering Review – Corrections

1. Please specify which type of FH to be used in the plan view, and only include the relevant standard detail.
Response: Please note we have clarified our callout for the fire hydrant to be a 90-degree hydrant and removed the straight-line hydrant detail from Sheet 3.

Should you have additional comments or questions, please do not hesitate to contact me. Thank you for your review of this project.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.



Jeffrey T. Skidmore, PE
Principal / Sr. Project Engineer
Direct Dial 913-322-7145
JS@schlagelassociates.com

/mr
Enclosures