

March 3, 2021

Sue Pyles, PE  
Senior Staff Engineer  
City of Lee's Summit  
220 SE Green St  
Lee's Summit, MO 64063

**RE: OAKVIEW STORAGE LOT 5 – SANITARY MAIN EXTENSION  
PL2021044**

Dear Sue:

This letter is regarding staff comments dated March 3, 2021 for the above-referenced project's engineering plan review to which we have the following response:

- Resubmit one (1) comments response letter and one (1) digital copy following the electronic plan submittal guides as stated below:  
**Response: Acknowledged**
- Revised plans will be reviewed within five (5) business days of the date received.  
**Response: Acknowledged**

Engineering Review – Corrections

1. Minimum lateral spacing required is 4' outside edge of MH to edge of wye fitting. Review the lateral spacing and revised as needed. Please add enough information to ensure it can be located correctly during construction.  
**Response: Please note we have revised the "wye" location and clarified in the callout that the service connection is to be installed a minimum of 4' from the outside face of the new manhole.**

Should you have additional comments or questions, please do not hesitate to contact me. Thank you for your review of this project.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.



Jeffrey T. Skidmore, PE  
Principal / Sr. Project Engineer  
Direct Dial 913-322-7145  
[JS@schlagelassociates.com](mailto:JS@schlagelassociates.com)

/mr

Enclosures