

March 4, 2021

**Re: Highland Meadows 6<sup>th</sup> Plat**

Anderson Engineering has received your comments dated March 1, 2021 and have the following responses:

City of Lee's Summit – Engineering Plan Review – Public Sanitary  
Pyles, Sue – (816) 969-1245

1. The plans don't require any revisions. Please add items for wyes, trench checks, and tracer wire to the estimate. You can email the revised signed/sealed estimate to me.  
**Estimate items added. Please see attached.**

City of Lee's Summit – Engineering Review – Public Water  
Pyles, Sue – (816) 969-1245

1. Please revise the Line 6-A 90-degree bend with 2–45-degree bends. Update the estimate to reflect this change. I apologize for not getting this comment on the previous review. **Bends added to plans and revised in the cost estimate.**

City of Lee's Summit – Engineering Plan Review – Erosion Control Plan  
Nguinguri, Loic – (816) 969-1200

1. Please break down cost item No.8.03. Also, make sure to provide accurate quantities, and prices, for each BMP shown on the plans. FYI, maintenance associated costs can be omitted in the estimation. **Per phone call discussion, quantities and costs are acceptable as shown.**

If you have any further questions, feel free to contact me at 816-777-0400 or by email at [gcates@andersonengineeringinc.com](mailto:gcates@andersonengineeringinc.com).

Sincerely,



Garrett Cates, EI  
Anderson Engineering Inc.  
941 W 141st Terr, Suite A  
Kansas City, MO 64145