

March 30, 2021

City of Lee's Summit Development Services 4800 E 63rd Street Kansas City, MO 64130

RE: Hook Farms 1st Plat

Engineering Plan Review

We are responding to your comments dated March 25, 2021, and are submitting with this letter, the revised plans. Please find our responses to your plan markups below.

If you have any questions or need additional information, please do not hesitate to contact me by phone at (816) 442-6044 or by email at jsellers@olsson.com.

Thank You,

Julie Sellers

Street, Storm, Mass Grading - PL2020110

Wele Seller

1. Please remove the wings. We would expect grading up to 3:1 to the sidewalk/ramp. Any higher slope should be a straight-back curb, tapered towards the top of ramp to "nothing".

Response: Wings have been removed and curb has been called out to be transitioned over 2-ft distance along curb. Slopes are not anticipated to exceed 3:1.

2. Sheet C122: Is the tapered ADA-route across intersection necessary? Is it possible to provide the full 5 feet width across the intersection?

Response: ADA route across intersection has been revised to be full 5-ft width.