

**Final Development Plan Changes:**

**CIVIL**

**Sheet C0.1 GENERAL NOTES**

1. General Note 15 added stating: "All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code."

**Sheet. C0.2 GENERAL DETAILS**

1. Heavy Asphalt Pavement detail description of '9" subgrade compacted to 95% max. density per APWA Section 2201' replaced with '9" subgrade treated with 5% Portland (not Lime) to a depth of 9". Density per APWA Section 2201.'

**Sheet C2.0 SITE PLAN**

1. Update '5" concrete sidewalk' hatch description to '5" thick concrete sidewalk'

**Sheet C4.0 GRADING PLAN**

1. Font size of information increased to improve and ease visibility.
2. Concrete sidewalk hatching updated to match one shown on paving plan.

**Sheet C5.0 PAVING PLAN**

1. Update '5" concrete sidewalk' hatch description to '5" thick concrete sidewalk'

**Sheet C6.0 LANDSCAPE PLAN**

1. Remove hatching from plan view for areas that do not represent areas to be vegetated only.

**END OF ASI #13 NARRATIVE**