

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Tuesday, October 12, 2021

To:

Property Owner: HUNT MIDWEST REAL ESTATE Email: kzane@huntmidwest.com
DEV INC

Engineer: OLSSON ASSOCIATES Email:

Applicant: HUNT MIDWEST REAL EST DEV INC Email: bholland@huntmidwest.com

Other: Julie Sellers Email: jsellers@olsson.com

From: Shannon McGuire, Planner

Re:

Application Number: PL2021087

Application Type: Commercial Final Development Plan

Application Name: Hook Farms Subdivision Amenities

Location: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
Engineering Review	Loic Nguinguiri, E.I.	Staff Engineer Loic.Nguinguiri@cityofls.net	Approved with Conditions

1. The Engineer’s Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$19,063.64
2. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
3. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
4. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
5. Stamp and sign the set of plans, submitted on 10/01/2021.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments