

DEVELOPMENT SERVICES

**Final Plat
Applicant's Letter**

Date: Wednesday, October 13, 2021

To:

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Property Owner: ACH DEVELOPMENT LLC

Email:

From: Victoria Nelson, Long Range Planner

Re:

Application Number: PL2021098

Application Type: Final Plat

Application Name: Park Ridge 8th Plat - Lots 362 - 391

Location: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

Tentative Schedule

City Council date will be set after all subdivision related public improvements have been completed and a Certificate of Final Acceptance has been issued. In lieu of completion of public improvements, an escrow secured with cash or an irrevocable letter of credit shall be deposited with the City to secure the completion of all public improvements prior to scheduling a City Council date.

Electronic Plans for Re-submittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns you may have.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at 816-969-1200.

Voluntary Residential Development Surcharge

In a combined effort with both the R-4 and the R-7 School Districts the City of Lee's Summit is working together to educate the development community on a new program, the "Lee's Summit Voluntary Residential Development Surcharge." This is a program which will help raise capital to build new schools for our community. Brochures are available at the front counter of both the Development Services Department. You can also find more information on the City of Lee's Summit web site at www.cityofls.net. (For more information please contact the Board of Education at 986-2400).

Analysis of Final Plat:

Planning Review	Victoria Nelson (816) 969-1605	Long Range Planner Victoria.Nelson@cityofls.net	Approved with Conditions
------------------------	-----------------------------------	--	--------------------------

1. Legal Description. Please submit the legal description in Microsoft Word format.
2. We are still working on addressing. They will be provided once they have been determined.

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final plat and approved prior to the approval of the final plat. All public infrastructure must be substantially complete, prior to the issuance of any building permits.
2. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.
3. The As-graded Master Drainage Plan shall be submitted to and accepted by the City prior to the issuance of a Certificate of Substantial Completion and prior to the issuance of any building permits for the development.
4. A restriction note shall be included on the final plat stating: "Individual lot owner(s) shall not change or obstruct the drainage flow paths on the lots, as shown on the Master Drainage Plan, unless specific application is made and approved by the City Engineer."

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
--------------------	----------------------------	--	-------------

Traffic Review	Michael Park	City Traffic Engineer	No Comments
-----------------------	--------------	-----------------------	-------------

(816) 969-1820

Michael.Park@cityofls.net

GIS Review

Kathy Kraemer
(816) 969-1277

GIS Technician
Kathy.Kraemer@cityofls.net

No Comments