

DEVELOPMENT SERVICES

**Final Plat
Applicant's Letter**

Date: Tuesday, October 19, 2021

To:

Property Owner: SHERRARD LAWRENCE III & MARY Email:

Applicant: CLAYTON PROPERTIES GROUP INC Email:

Engineer: JEFFREY MEANS (OLSSON ASSOCIATES) Email: jmeans@olssonassociates.com

Other: Nelson Willoughby Email: nwilloughby@olsson.com

From: Shannon McGuire, Planner

Re:

Application Number: PL2021261

Application Type: Final Plat

Application Name: OSAGE 3RD PLAT

Location: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

Tentative Schedule

Submit revised plans by 4pm on Monday, August 16, 2021. Revised documents shall be uploaded to the application through the online portal.

City Council date will be set after all subdivision related public improvements have been completed and a Certificate of Final Acceptance has been issued. In lieu of completion of public improvements, an escrow secured with cash or an irrevocable letter of credit shall be deposited with the City to secure the completion of all public improvements prior to scheduling a City Council date.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Re-submittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns you may have.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at 816-969-1200.

Voluntary Residential Development Surcharge

In a combined effort with both the R-4 and the R-7 School Districts the City of Lee's Summit is working together to educate the development community on a new program, the "Lee's Summit Voluntary Residential Development Surcharge." This is a program which will help raise capital to build new schools for our community. Brochures are available at the front counter of both the Development Services Department. You can also find more information on the City of Lee's Summit web site at www.cityofls.net. (For more information please contact the Board of Education at 986-2400).

Analysis of Final Plat:

| | | | |
|---------------------------|---------------------------------------|---|--------------------------|
| Planning Review | Shannon McGuire (816) 969-1237 | Planner Shannon.McGuire@cityofls.net | No Comments |
| Engineering Review | Gene Williams, P.E. (816) 969-1223 | Senior Staff Engineer Gene.Williams@cityofls.net | Approved with Conditions |

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final plat and approved prior to the approval of the final plat. All public infrastructure must be substantially complete, prior to the issuance of any building permits.
2. A Master Drainage Plan (MDP) shall be submitted and approved in accordance with the City's Design and Construction Manual for all areas of the development, including all surrounding impacted areas, along with the engineering plans for the development. The MDP shall address drainage level of service issues on an individual lot basis.
3. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).
4. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.

5. The As-graded Master Drainage Plan shall be submitted to and accepted by the City prior to the issuance of a Certificate of Substantial Completion and prior to the issuance of any building permits for the development.

6. A restriction note shall be included on the final plat stating: "Individual lot owner(s) shall not change or obstruct the drainage flow paths on the lots, as shown on the Master Drainage Plan, unless specific application is made and approved by the City Engineer."

7. All ADA sidewalk ramps shall be constructed by the developer at the time the street is constructed.

8. All sidewalks adjacent to a common area tract, unplatted land or any land where no structure is intended to be built, and is required, shall be constructed by the developer at the time the street is constructed.

9. The applicant shall submit and the City shall accept an "As-built / As-graded" detention basin plan prior to issuance of any occupancy permit for the proposed development.

| | | | |
|-----------------------|---------------------------------|--|-------------|
| Fire Review | Jim Eden (816) 969-1303 | Assistant Chief Jim.Eden@cityofls.net | No Comments |
| Traffic Review | Michael Park (816) 969-1820 | City Traffic Engineer Michael.Park@cityofls.net | No Comments |
| GIS Review | Kathy Kraemer (816) 969-1277 | GIS Technician Kathy.Kraemer@cityofls.net | No Comments |