

**DEVELOPMENT SERVICES**

**Commercial Final Development Plan  
Applicant's Letter**

**Date:** Thursday, October 28, 2021

**To:**

**City Staff:** Scott Ready

Email: Scott.Ready@cityofls.net

**Applicant:** Jerry Celeste

Email: jcsparkey@wmconnect.com

**From:** Hector Soto Jr., Planning Division Manager

**Re:**

**Application Number:** PL2021402

**Application Type:** Commercial Final Development Plan

**Application Name:** DISH Wireless Co-Locate

**Location:** 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

**Electronic Plans for Resubmittal**

---

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

**Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

---

**Review Status:**

**Required Corrections:**

**Fire Review**

Jim Eden  
(816) 969-1303

Assistant Chief  
Jim.Eden@cityofls.net

No Comments

---

<b>Planning Review</b>	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	Corrections
------------------------	-----------------------------------	---	-------------

---

1. PROOF OF INSURANCE. Provide proof of general liability insurance for claims from injury or death and property damage in an amount approved by the City, but not less than \$2,000,000.00 per occurrence for personal injury and \$2,000,000.00 per occurrence for property damage with the City listed and endorsed as an additional insured. The policy shall also include an endorsed waiver of subrogation against the City.

2. OUSTANDING MAINTENANCE ITEMS. A recent report provided to the City on the subject tower indicates there are outstanding maintenance/safety items that need to be remedied on the tower. Use the following link to view the report with an upload date of 10/6/21: <https://devservices.cityofls.net/Planning/Status?planningId=6259>.

Staff cannot approve the subject application until documentation is provided that the outstanding maintenance/safety items listed in the report have been remedied.

<b>Engineering Review</b>	Loic Nguingiri, E.I.	Staff Engineer Loic.Nguingiri@cityofls.net	Corrections
---------------------------	----------------------	---	-------------

---

1. Please provide a structural analysis letter that confirm whether the new equipment addition meets ANSI/TIA-222-H design code requirements.

<b>Traffic Review</b>	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

---

<b>Building Codes Review</b>	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions
------------------------------	------------------------------	---	--------------------------

---

1. Building/electrical permit not required.