

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date:	Thursday, January	ry 13, 2022			
To: Property Owner: MSE PROPERTY HOLDINGS GROUP, LLC		MSE PROPERTY HOLDINGS	Email:		
	Applicant: ROSE DESIGN BUILD - CHRIS BELL		Email: CHRIS@BUILDWITHROSE.COM		
	Engineer: PHELPS	ENGINEERING, INC	Email: DOUGUBBEN@PHELPSENGINEERING.COM		
From:	Mike Weisenborn	born			
Re: Application Number: Application Type: Application Name: Location:		PL2021414 Commercial Final Development Plan Crash Champions 451 SE OLDHAM PKWY, LEES SUMMIT, MO 64081			

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon. McGuire@cityofls.net	No Comments
Engineering Review	Sue Pyles, P.E. (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions

1. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.

2. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee of \$4,293.62 (which is based on 3% of the total infrastructure cost plus a water test inspection fee(s)) must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit

3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. IFC 503.2.3 - Fire apparatus access roads shall be designed and maintained to support the imposed loads of fire apparatus and shall be surfaced so as to provide all-weather driving capabilities.

Action required- The fire department access to the south building shall be capable of supporting a 75,000- pound fire apparatus. Confirm constructon type.

raffic Review Brad Cooley			No Comments
		Brad.Cooley@cityofls.net	
Building Codes Review	Joe Frogge	Plans Examiner	No Comments
	(816) 969-1241	Joe.Frogge@cityofls.net	