

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date: Friday, January 14, 2022

To:

Property Owner: MARION RIDGE SAFETY Email:

STORAGE LLC

Applicant: WARD DEVELOPMENT & INVESTMENT Email: DAVID@SAFETYMINISTORAGE.COM

Engineer: POWELL CWM INC Email: BPOWELL@POWELLCWM.COM

From: Mike Weisenborn, Project Manager

Re:

Application Number: PL2021376

Application Type: Commercial Final Development Plan

Application Name: LOT 10 I-470 BUSINESS & TECHNOLOGY CENTER --- LOT 10

Location: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	No Comments
Engineering Review	Sue Pyles, P.E. (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	No Comments

- 1. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
- 2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
- 3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	

- 1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 nternational Fire Code.
- 2. IFC 903.3.7 Fire department connections. The location of fire department connections shall be approved by the fire code official. Connections shall be a 4 inch Storz type fitting and located within 100 feet of a fire hydrant, or as approved by the code official.

Action required- Show the location of the FDC.

Traffic Review	Brad Cooley		No Comments
		Brad.Cooley@cityofls.net	
Building Codes Review	Joe Frogge	Plans Examiner	No Comments
	(816) 969-1241	Joe.Frogge@cityofls.net	