



Date: January 18, 2022

City of Lee's Summit, MO
Development Services
220 SE Green Street
Lee's Summit, MO 64063

RE: Hawthorn Ridge 3rd Plat – Street & Storm Sewer As-Built Plans

We are responding to your comments dated January 12, 2022 and are submitting with this letter revised plans. Please find the original comments below; our responses are below in ***bold italics***.

If you have any questions or need additional information, please do not hesitate to contact us.

Thank you,

A handwritten signature in blue ink that reads "Brock Worthley".

Brock Worthley

Street & Storm Sewer As-Built Plan Review

1. Sheet C121: Storm line between curb inlet 5-2 and 5-3 does not make sense. Rim, flowline in and out, and slope does not appear to make sense. Suspect a typo. Please review and revise as appropriate.

Rim and flowline elevations shown for C.I. 5-2 were typed incorrectly. The top elevation was typed in as 1023.66 but should've been 1032.66 which caused all of the other elevations to be incorrect. Elevations and pipe slopes for connected pipes have been corrected. This change did not affect the as-built surface.