

Chase Bank 291 And Langsford With Fire Flow At Maximum Day Demand

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	<input type="checkbox"/>	909	5.80	90.01	1,199.73	1,500.00	77.60	4,187.50	20.00
2	<input type="checkbox"/>	910	0.00	86.54	1,199.73	1,500.00	80.59	7,072.31	20.00



Chase Bank 291 And Langsford With No Fire FLOW At Peak Hour Demand

		ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Hydrant Available Flow (gpm)	Hydrant Pressure at Available Flow (psi)
1	<input type="checkbox"/>	909	11.60	77.91	1,171.81	0.00	77.91	3,604.37	20.00
2	<input type="checkbox"/>	910	0.00	74.45	1,171.82	0.00	74.45	5,884.43	20.00

