

# **DEVELOPMENT SERVICES**

# Commercial Final Development Plan Applicant's Letter

Date:	Monday, January 31, 2022				
То:	Property Owner: PARKER JEANNIE MICHELLE		Email:		
	City Staff: Scott R	eady	Email: Scott.Ready@cityofls.net		
	Applicant: Nick Fore		Email: nfore@crossdevelopment.net		
	<b>Property Owner</b> : TRUST	KRAFT THOMAS ANTHONY	Email:		
From:	Victoria Nelson, L	ong Range Planner			
Re: Application Number: Application Type:		PL2021426 Commercial Final Development Plan			
Application Name:		Caliber Collision			
Location:		710 SE BLUE PKWY, LEES SUMMIT, MO 64063			

## **Electronic Plans for Resubmittal**

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

#### **Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1600 | 816.969.1619 Fax | cityofLS.net/Development

## **Review Status: Approved with Conditions**

#### **Required Corrections: N/A**

Planning Review	Victoria Nelson (816) 969-1605	Long Range Planner Victoria.Nelson@cityofls.net	No Comments
Engineering Review	Sue Pyles, P.E. (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions

1. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.

2. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$33,081.43

3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

4. An As-Graded and As-Built drawing shall be submitted to and reviewed by the City for the detention basin. This shall be required prior to issuance of a Certificate of Substantial Completion. All precautions should be taken to ensure detention pond and outlet structure are constructed according to the approved plans; volumes and elevations are critical for As-Built approval.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
Traffic Review	Brad Cooley, P.E., RSPI	Brad.Cooley@cityofls.net	Approved with Conditions
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments