



Application Number: PL2021298  
Application Type: Engineering Plan Review  
Application Name: NAPA VALLEY 5TH PLAT- ESC

**Engineering Review Comments**

1. Would it be possible to add the area inlet protection symbol? To the legend, as shown in the correspondence email. **Added.**
2. The grading plan sheet already shows ESC protection added to the four (4) area/field inlets located right on the other side of the southern property line, as secondary ESC measure. Would it be possible to show them as well on sheets C.051 and C.052 ? **Added.**
3. The proposed grading contour lines shown over the proposed swales do not appear to reflect the 5 feet wide base, as indicated in the 100 year overflow swale table. Please revise, accordingly. **Added.**
4. Doesn't a \$35,000 item cost for clearing/grubbing (over 9.65 acres) and disturbing/grading (37,000+ C.V. of soil) appear low? Please clarify/revise. **The number is low because most of the grading was done with the pond.**
5. Please submit a SWPPP report. **Provided with submittal.**

Feel free to contact me should you have any additional questions regarding this project.

Thank You,

Matt Schlicht