







- METER VAULT NOTES**
1. POUR FOOTING ON FIRM UNDISTURBED EARTH
  2. ALL PIPING IN METER PIT SHALL BE DUCTILE IRON PIPE.
  3. WALLS TO BE DOUBLE FORMED
  4. ALL REBAR TO 3/4" COVER
  5. HATCH TO BE CENTERED DIRECTLY ABOVE METER

**WATER METER VAULT DETAIL**  
NOT TO SCALE

**RELEASED FOR CONSTRUCTION**  
As Noted on Plans Review  
Development Services Department  
Lee's Summit, Missouri  
02/11/2022

DWG: F:\2020\0001-0500\020-0103\40-Design\AutoCAD\Final Plans\CONSTRUCTION DOCUMENTS\C\_DTL01\_0200103.dwg  
 DATE: Feb 11, 2022 2:30pm  
 XREFS: C:\4LS\_XBASE\_80330  
 USER: lperson  
 L\_PBASE\_61023  
 TE DETAIL  
 C\_PBASE\_80330  
 C\_PTBK\_0200103

**DLR Group**  
© DLR Group  
82020, DLR Group, Inc. Missouri corporation.  
Missouri State Certificate of Authority #00989

**olsson**  
OLSSON, CIVIL ENGINEERING  
MISSOURI CERTIFICATE OF AUTHORITY #001992  
7301 West 133rd Street, Suite 200  
Overland Park, KS 66221-4750  
TEL 913.381.1170  
www.olsson.com

STATE OF MISSOURI  
TERRY M. PARSONS  
NUMBER  
PE-2018010505  
2/14/22  
PROFESSIONAL ENGINEER

LEE'S SUMMIT MIDDLE SCHOOL #4  
LEE'S SUMMIT R-7 SCHOOL DISTRICT  
1001 SE BAILEY ROAD  
LEE'S SUMMIT, MO 64881

PACKAGE 2-  
STRUCTURAL & SITE  
UTILITIES  
ISSUED FOR PERMIT  
08/28/20

PR002R 01.14.21  
CPR 1 12.16.21  
ASI-40 02.10.22

13-20102-00

STANDARD  
DETAILS

**C1050A**