

March 1st, 2022

Development Services
City of Lee's Summit, Missouri

Application Number: PL2022032
Development Name: Town Centre – Lot 1

Ms. Pyles,

The following changes have been made to the submitted public sanitary main extension documents at the request of City Staff:

Engineering Review

1. Submit an Engineer's Estimate of Probable Construction Costs.

Included.

2. Show location of all oil/gas wells, or indicate none are present, and cite the source. Field survey evidence isn't sufficient.

Please see the revised note on Sheet CSS 1.

3. Revise the mislabeled flowline information at the existing MH at Sta. 0+00 in Profile View. Verify there is 0.5' of fall across the structure.

Revised. Please see profile view on Sheet CSS 2. FL elevations of the existing 2" & 12" dia. sanitary lines were taken from the Lee's Summit Subaru Sanitary Main Extension As-Built Survey dated July 21, 2007.

4. Include the following note: "Compacted Fill shall be placed to a minimum 18" above the top of the pipe prior to installation." Show and label the limits of the compacted fill placement in the Profile view. Use hatching for clarity.

Please see note on Sheet CSS 2.

Respectfully submitted,



Jon Prueter, E.I.T.,
Davidson Architecture and Engineering